

LICENSEE EVENT REPORT

CONTROL BLOCK: 1

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 WIKNP1 200-000000-000 341111 4 5
8 9 14 15 25 26 30 37 CAT 58
 LICENSE CODE LICENSE NUMBER LICENSE TYPE

CONT 01 L 605000305 7031083 8040883 9
60 61 68 69 74 75 80
 REPORT SOURCE DOCKET NUMBER EVENT DATE REPORT DATE

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES 10

02 During full power operation, while performing surveillance testing on the containment
03 pressure transmitters, several transmitters were found out of specification such that
04 the safety injection actuation signal would have occurred 0.47% later than required by
05 T.S.3.5.a. The other safety function setpoints provided by these transmitters would
06 have occurred within T.S. limits. This event is reportable per T.S. 6.9.2.b.(1) Due
07 to the availability of redundant safety injection actuation signals, there was no
08 effect on the health and safety of the public or plant operation.
8 9

09 IB 11 X 12 Z 13 INSTRU 14 T 15 Z 16
9 10 11 12 13 18 19 20
 SYSTEM CODE CAUSE CODE CAUSE SUBCODE COMPONENT CODE COMP. SUBCODE VALVE SUBCODE
17 83 008 03 L 0
21 22 24 26 27 28 29 30 31 32
 LER-RO REPORT NUMBER EVENT YEAR SEQUENTIAL REPORT NO. OCCURRENCE CODE REPORT TYPE REVISION NO.
E Z Z Z 0000 N N N F180
33 34 35 36 37 40 41 42 43 44 47
 ACTION TAKEN FUTURE ACTION EFFECT ON PLANT SHUTDOWN METHOD HOURS ATTACHMENT SUBMITTED NPD-4 FORM SUB PRIME COMP. SUPPLIER COMPONENT MANUFACTURER

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS 27

10 Transmitter drifting has been determined to be the cause of this event. The trans-
11 mitters were recalibrated in accordance with the surveillance procedures. No further
12 action is required at this time, although these transmitters will be monitored for
13 future drifting.
14

15 E 100 NA B 31 Surveillance test.
8 9 10 12 13 44 45 46 60
 FACILITY STATUS % POWER OTHER STATUS METHOD OF DISCOVERY DISCOVERY DESCRIPTION

16 Z Z NA NA NA
8 9 10 11 44 45 80
 RELEASED OF RELEASE AMOUNT OF ACTIVITY LOCATION OF RELEASE

17 000 Z NA
8 9 11 12 13 80
 PERSONNEL EXPOSURES NUMBER TYPE DESCRIPTION

18 000 NA
8 9 11 12 80
 PERSONNEL INJURIES NUMBER DESCRIPTION

19 Z NA
8 9 10 12 80
 LOSS OF OR DAMAGE TO FACILITY TYPE DESCRIPTION

20 N NA
8 9 10 80
 PUBLICITY ISSUED DESCRIPTION

8304150481 830408
 PDR ADOCK 05000305
 S PDR

NRC USE ONLY

NAME OF PREPARER: M. L. Marchi

PHONE: (414) 388-2560