



AVERAGE DAILY UNIT POWER LEVEL

DOCKET NO. 50-387

UNIT One

DATE 3-9-83

COMPLETED BY L.A. Kuczynski

TELEPHONE (717) 542-2181

MONTH February, 1983

DAY	AVERAGE DAILY POWER LEVEL (MWe-Net)
1	<u>922</u>
2	<u>958</u>
3	<u>978</u>
4	<u>882</u>
5	<u>892</u>
6	<u>1037</u>
7	<u>1039</u>
8	<u>1032</u>
9	<u>1036</u>
10	<u>892</u>
11	<u>1008</u>
12	<u>1053</u>
13	<u>0</u>
14	<u>0</u>
15	<u>0</u>
16	<u>0</u>

DAY	AVERAGE DAILY POWER LEVEL (MWe-Net)
17	<u>0</u>
18	<u>0</u>
19	<u>0</u>
20	<u>0</u>
21	<u>0</u>
22	<u>0</u>
23	<u>0</u>
24	<u>0</u>
25	<u>0</u>
26	<u>184</u>
27	<u>562</u>
28	<u>896</u>
29	<u></u>
30	<u></u>
31	<u></u>

INSTRUCTIONS

On this format, list the average daily unit power level in MWe-Net for each day in the reporting month. Compute to the nearest whole megawatt.

(9/77)



OPERATING DATA REPORT

DOCKET NO. 50-387
 DATE 3-9-83
 COMPLETED BY L. A. Kuczynski
 TELEPHONE (717) 542-2181

OPERATING STATUS

Unit One

1. Unit Name: Susquehanna Steam Electric Station
2. Reporting Period: February, 1983
3. Licensed Thermal Power (MWt): 3293
4. Nameplate Rating (Gross MWe): $1280 \times 0.9 = 1152$
5. Design Electrical Rating (Net MWe): $1152 - 41 = 1111$
6. Maximum Dependable Capacity (Gross MWe): *
7. Maximum Dependable Capacity (Net MWe): *
8. If Changes Occur in Capacity Ratings (Items Number 3 Through 7) Since Last Report, Give Reasons:

Recalculation of existing data

Notes First achieved 100% reactor power at 0617 on February 4, 1983

* MDC to be determined
 ** Revised

9. Power Level To Which Restricted, If Any (Net MWe): None
10. Reasons For Restrictions, If Any: None

	This Month	Yr.-to-Date	Cumulative
11. Hours In Reporting Period	<u>672</u>	<u>1416</u>	<u>2508.5</u>
12. Number Of Hours Reactor Was Critical	<u>383.3</u>	<u>1029.2</u>	<u>1959.2</u>
13. Reactor Reserve Shutdown Hours	<u>15</u>	<u>66.3</u>	<u>130.9</u>
14. Hours Generator On-Line	<u>357.5</u>	<u>938.6</u>	<u>1791.2</u>
15. Unit Reserve Shutdown Hours	<u>0</u>	<u>0</u>	<u>0</u>
16. Gross Thermal Energy Generated (MWH)	<u>988,690</u>	<u>2,148,959**</u>	<u>3,443,424**</u>
17. Gross Electrical Energy Generated (MWH)	<u>332,590</u>	<u>718,720</u>	<u>1,063,140</u>
18. Net Electrical Energy Generated (MWH)	<u>316,633</u>	<u>681,500</u>	<u>1,002,805</u>
19. Unit Service Factor	<u>N/A</u>		
20. Unit Availability Factor	<u>N/A</u>		
21. Unit Capacity Factor (Using MDC Net)	<u>N/A</u>		
22. Unit Capacity Factor (Using DER Net)	<u>N/A</u>		
23. Unit Forced Outage Rate	<u>N/A</u>		

24. Shutdowns Scheduled Over Next 6 Months (Type, Date, and Duration of Each):

None.

25. If Shut Down At End Of Report Period, Estimated Date of Startup:

26. Units In Test Status (Prior to Commercial Operation):

INITIAL CRITICALITY
 INITIAL ELECTRICITY
 COMMERCIAL OPERATION

Forecast

Achieved

9-7-82 9-10-82
11-19-82 11-16-82
5-15-83 _____



UNIT SHUTDOWNS AND POWER REDUCTIONS

REPORT MONTH February, 1983

DOCKET NO. 50-387
 UNIT NAME Che
 DATE 3-9-83
 COMPLETED BY L.A. Kuczynski
 TELEPHONE (717) 542-2181

No.	Date	Type ¹	Duration (Hours)	Reason ²	Method of Shutting Down Reactor ³	Licensee Event Report #	System Code ⁴	Component Code ⁵	Cause & Corrective Action to Prevent Recurrence
5	830212	S	314.5	B	3	N/A	ZZ	ZZZZZZ	As part of scheduled startup testing, generator sync. breaker was opened to simulate a load rejection. This caused a reactor scram on turbine control valve fast closure. A planned outage commenced at 1500 on 2-13-83.

¹
 F: Forced
 S: Scheduled

²
 Reason:
 A-Equipment Failure (Explain)
 B-Maintenance or Test
 C-Refueling
 D-Regulatory Restriction
 E-Operator Training & License Examination
 F-Administrative
 G-Operational Error (Explain)
 H-Other (Explain)

³
 Method:
 1-Manual
 2-Manual Scram.
 3-Automatic Scram.
 4-Other (Explain)

⁴
 Exhibit G - Instructions for Preparation of Data Entry Sheets for Licensee Event Report (LER) File (NUREG-0161)

⁵
 Exhibit I - Same Source

SUSQUEHANNA STEAM ELECTRIC STATION
Docket Number 50-387 Date 3-9-83
Completed By: L.A. Kuczynski Telephone (717) 542-2181
February, 1983

Challenges to Main Steam Safety Relief Valves

During the first four minutes of the scheduled High Power Generator Load Rejection Startup Test, main steam safety relief valves (SRV) D, E and H lifted and re-seated. SRV E automatically opened a second time and re-seated. SRV A was opened manually to provide pressure control and was properly re-seated.

Changes to Offsite Dose Calculation Manual

None.

Major Changes to Radioactive Waste Treatment Systems

None.