



South Carolina Electric & Gas Company
P.O. Box 88
Jenkinsville, SC 29065
(803) 345-4001

John L. Skolds
Senior Vice President
Nuclear Operations

September 26, 1994
Refer to: RC-94-0252

Document Control Desk
U. S. Nuclear Regulatory Commission
Washington, DC 20555

Attention: Mr. G. F. Wunder

Gentlemen:

Subject: VIRGIL C. SUMMER NUCLEAR STATION (VCSNS)
DOCKET NO. 50/395
OPERATING LICENSE NO. NPF-12
TECHNICAL SPECIFICATION CHANGE - TSP 930002
LIMITING SAFETY SYSTEMS SETTINGS - REACTOR TRIP SYSTEM
INSTRUMENTATION TRIP SETPOINTS
ENGINEERED SAFETY FEATURES ACTUATION SYSTEM
INSTRUMENTATION SETPOINTS

On March 11, 1994, South Carolina Electric & Gas Company (SCE&G) submitted in accordance with 10 CFR 50.90, an amendment request to Tables 2.2-1 and 3.3-4 of the Virgil C. Summer Nuclear Station (VCSNS) Technical Specifications (TS). This change was to revise the format of these tables from five column to two column and also include additional PMA uncertainties in the Model D-3 steam generator water level low-low trip function.

Per our previous discussions, the two column format was requested as part of another amendment request (TSP 930015 Supplement 1, RC-94-0185, dated July 20, 1994). Additionally, the D-3 PMA uncertainties will no longer be valid for VCSNS with the replacement of the Model D-3 steam generators with the newer Model Delta 75 steam generators during the outage that began September 9, 1994. Accordingly, SCE&G desires to withdraw the request made in the application dated March 11, 1994 (TSP 930002).

I declare that the statements and matters set forth herein are true and correct to the best of my knowledge, information, and belief.

Should you have any questions concerning this issue, please call Mr. Philip Rose at (803) 345-4052 at your convenience.

Very truly yours,

John L. Skolds

PAR:lcd

9410030130 940926
PDR ADDCK 05000395
PDR

c: O.W. Dixon
R.R. Mahan
R.J. White
S.D. Ebner
NRC Resident Inspector

J.B. Knotts Jr.
M. K. Batavia (DHEC)
Central File System
RTS (TSP 930002)
File (813.20)



NUCLEAR EXCELLENCE - A SUMMER TRADITION!

ADD 1/0