



Public Service Electric and Gas Company P.O. Box 236 Hancocks Bridge, New Jersey 08038

Hope Creek Generating Station

September 22, 1994

Chief George Corporale
Bureau of Information Systems
P. O. Box CN-029
Trenton, N. J. 08625

RE: NEW JERSEY POLLUTANT DISCHARGE
ELIMINATION SYSTEM
DISCHARGE MONITORING REPORT
HOPE CREEK GENERATING STATION
NJPDES PERMIT NJ0025411

Dear Sir:

Attached is the Discharge Monitoring Report for the Hope Creek Generating Station for the month of August 1994.

This report is required by and prepared specifically for the Environmental Protection Agency (EPA) and the New Jersey Department of Environmental Protection and Energy (NJDEPE). It presents only the observed results of measurements and analysis required to be performed by the above agencies. The choice of the measurement devices and analytical methods are controlled by the EPA and the NJDEPE, not by the company, and there are limitations on the accuracy of such measurement devices and analytical techniques even when used and maintained as required. Accordingly, this report is not intended as an assertion that any instrument has measured, or that any reading analytical result represents the true value with absolute accuracy, nor is it an endorsement of the suitability of any analytical or measurement procedure.

If you have any questions concerning this report, please feel free to contact Mr. C. E. White.

Sincerely,

Robert J. Hovey
General Manager -
Hope Creek Operations

300007

The Energy People

9410030163 940831
PDR ADDCK 05000354
R PDR

95-2173 (25M) 12-89

NJPDES

2

9/22/94

For
CW:ej
Attachments

C Executive Director, DRBC
 USEPA - Dr. Richard Baker
 USNRC



Strand Management Solutions, Inc.

569 Abbington Drive

East Windsor, New Jersey 08520

(609) 448-1200

Fax - BBS: (609) 448-2642

Ms. Debra Hammond
Chief, Bureau of Permit Management
Wastewater Facility Regulation
P.O. Box CN029
Trenton, N.J. 08625

December 11, 1992

Dear Ms. Hammond:

I am enclosing copies of our laser-generated Discharge Monitoring Report (DMR) and Industrial Process Wastewater Sludge Report (IPWSR) forms, as we discussed on the telephone today. We foresee using these forms for the following permit holders:

DMR

NJ0000621	PSE&G Bergen Generating Station
NJ0000639	PSE&G Essex Generating Station
NJ0000647	PSE&G Hudson Generating Station
NJ0000655	PSE&G Kearny Generating Station
NJ0000663	PSE&G Linden Generating Station
NJ0000680	PSE&G Sewaren Generating Station
NJ0003603	PSE&G Edison Generating Station
NJ0004995	PSE&G Mercer Generating Station
NJ0005002	PSE&G Burlington Generating Station
NJ0005045	Monsanto Delaware River Plant
NJ0005622	PSE&G Salem Generating Station
NJ0025411	PSE&G Hope Creek Generating Station

IPWSR

0000663	PSE&G Linden Generating Station
---------	---------------------------------

We will inform you in like manner of permittees we may wish to add in the future. Please indicate your acceptance by signing and returning this letter or a copy.

Very truly yours,
Strand Management Solutions, Inc.

Arnold S. Rosner
Vice President

Debra Ann Hammond
Chief, Bureau of Permit Management

12/20/92
Date

**Strand Management Solutions, Inc.**569 Abbington Drive
East Windsor, New Jersey 08520(609) 448-1200
Fax - BBS: (609) 448-2642Ms. Debra Hammond
Chief, Bureau of Permit Management
Wastewater Facility Regulation
P.O. Box CN029
Trenton, N.J. 08625

May 13, 1993

Dear Ms. Hammond:

In order to increase readability of the "Comment" section of our laser-generated DMR's, we would like to remove the following text from the form:

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

I am enclosing a copy of the form incorporating our suggested modification.

We will use this form for the following permit holder:

NJ0005045 Monsanto Delaware River Plant

Please indicate your acceptance by signing and returning this letter or a copy.

Very truly yours,
Strand Management Solutions, Inc.

Arnold S. Rosner
Arnold S. Rosner
Vice President

Debra Ann Hammond
Debra Ann Hammond
Chief, Bureau of Permit Management

5/13/93
Date

NEW JERSEY DEPARTMENT OF ENVIRONMENTAL PROTECTION
DIVISION OF WATER RESOURCESMONITORING REPORT — TRANSMITTAL SHEET

NJDES NO.

REPORTING PERIOD

MO. YR.

MO. YR.

[0][0][2][5][4][1][1]

[0][8][9][4] THRU [0][8][9][4]

PERMITTEE: Name Public Service Electric & Gas CompanyAddress P.O. Box 236Hancocks Bridge, NJ 08038FACILITY: Name Hope Creek Generating StationAddress P.O. Box 236Hancocks Bridge, NJ (County) SalemTelephone (609) 339-3463

FORMS ATTACHED (Indicate Quantity of Each)

SLUDGE REPORTS - SANITARY

☐ T-VWX-007 ☐ T-VWX-008 ☐ T-VWX-009

SLUDGE REPORTS - INDUSTRIAL

☐ T-VWX-010A ☐ T-VWX-010B

WASTEWATER REPORTS

☐ T-VWX-011 ☐ T-VWX-012 ☐ T-VWX-013

GROUNDWATER REPORTS

☐ VWX-015(A,B) ☐ VWX-016 ☐ VWX-017

NPDES DISCHARGE MONITORING REPORT

☒ EPA FORM 3320-1OPERATING EXCEPTIONS

YES NO

DYE TESTING ☐ ☒TEMPORARY BYPASSING ☐ ☒DISINFECTION INTERRUPTION ☐ ☒MONITORING MALFUNCTIONS ☐ ☒UNITS OUT OF OPERATION ☐ ☒OTHER ☐ ☒(Detail any "Yes" on reverse side
in appropriate space.)NOTE: The "Hours Attended at Plant" on the
reverse of this sheet must also be completed.

AUTHENTICATION - I certify under penalty of law that I have personally examined and am familiar with the information submitted in this document and all attachments and that, based on my inquiry of those individuals immediately responsible for obtaining the information, I believe the submitted information is true, accurate and complete. I am aware that there are significant penalties for submitting false information including the possibility of fine and imprisonment.

LICENSED OPERATOR

Name (Printed) Christopher E. WhiteGrade & Registry No. (N-2) N0956Signature [Signature]Date 9/22/94PRINCIPAL EXECUTIVE OFFICER or
DULY AUTHORIZED REPRESENTATIVEName (Printed) Robert J. HoveyTitle (Printed) General Manager
Hope Creek OperationsSignature [Signature]Date 9/22/94

OPERATING EXCEPTIONS DETAILED

* Please refer to the attached Transmittal Sheet Addenda.

HOURS ATTENDED AT PLANT

Month 018

Year 914

Day of Month	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16
Licensed Operator	7.5	13.3	8	8	8	-	-	8	8	8	8	8	-	-	8	8
Others	10	10	10	10	10	3	3	10	10	10	10	10	3	3	10	10
Day of Month	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31	
Licensed Operator	8	8	8	-	-	8	9	10	8	8	-	-	8	9	8	
Others	10	10	10	3	3	10	10	10	10	10	3	3	10	10	10	

OPERATING EXCEPTIONS DETAILED

* Please refer to the attached Transmittal Sheet Addenda.

HOURS ATTENDED AT PLANT

Month 08

Year 194

Day of Month	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16
Licensed Operator	7.5	13.3	8	8	8	-	-	8	8	8	8	8	-	-	8	8
Others	10	10	10	10	10	3	3	10	10	10	10	10	3	3	10	10
Day of Month	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31	
Licensed Operator	8	8	8	-	-	8	9	10	8	8	-	-	8	9	8	
Others	10	10	10	3	3	10	10	10	10	10	3	3	10	10	10	

DIVISION OF WATER RESOURCES

MONITORING REPORT - TRANSMITTAL SHEET

NJPDES NO.

REPORTING PERIOD

MO. YR.

MO. YR.

0101215141111

08/94 THRU 08/94

PERMITTEE: Name Public Service Electric & Gas Company

Address P.O. Box 236

Hancocks Bridge, N.J. 08038

FACILITY: Name Hope Creek Generating Station

Address P.O. Box 236

Hancocks Bridge, N.J. (County) Salem

Telephone 609 1 339-3463

FORMS ATTACHED (Indicate Quantity of Each)

SLUDGE REPORTS - SANITARY

☐ T-VWX-007 ☐ T-VWX-008 ☐ T-VWX-009

SLUDGE REPORTS - INDUSTRIAL

☐ T-VWX-010A ☐ T-VWX-010B

WASTEWATER REPORTS

☐ T-VWX-011 ☐ T-VWX-012 ☐ T-VWX-013

GROUNDWATER REPORTS

☐ VWX-015(A,B) ☐ VWX-016 ☐ VWX-017

NJPDES DISCHARGE MONITORING REPORT

☒ EPA FORM 3320-1

OPERATING EXCEPTIONS

	YES	NO
DYE TESTING	<input type="checkbox"/>	<input checked="" type="checkbox"/>
TEMPORARY BYPASSING	<input type="checkbox"/>	<input checked="" type="checkbox"/>
DISINFECTION INTERRUPTION	<input type="checkbox"/>	<input checked="" type="checkbox"/>
MONITORING MALFUNCTIONS	<input checked="" type="checkbox"/>	<input type="checkbox"/>
UNITS OUT OF OPERATION	<input type="checkbox"/>	<input checked="" type="checkbox"/>
OTHER	<input checked="" type="checkbox"/>	<input type="checkbox"/>

(Detail any "Yes" on reverse side in appropriate space.)

NOTE: The "Hours Attended at Plant" on the reverse of this sheet must also be completed.

AUTHENTICATION - I certify under penalty of law that I have personally examined and am familiar with the information submitted in this document and all attachments and that, based on my inquiry of those individuals immediately responsible for obtaining the information, I believe the submitted information is true, accurate and complete. I am aware that there are significant penalties for submitting false information including the possibility of fine and imprisonment.

LICENSED OPERATOR

Name (Printed) ANDREW NURK

Grade & Registry No. S-4 (54542)

Signature [Signature]

Date 9/1/94

PRINCIPAL EXECUTIVE OFFICER or
DULY AUTHORIZED REPRESENTATIVE

Name (Printed) Robert J. Hovey
General Manager

Title (Printed) Hope Creek Operations

Signature [Signature]

Date 9/22/94

OPERATING EXCEPTIONS DETAILED

8/1-8/4 and 8/20-8/31 flow totalizer Digital read out not working. Daily flow a sum of estimated volume each hour from flow chart

East clarifier off line due to rapid settling rate

#1 filter off line due to influent valve being stuck in shut position

HOURS ATTENDED AT PLANT

Month 08

Year 94

Day of Month	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16
Licensed Operator	8	8	8	8	8	8		8	8	8	8	8	8		8	8
Others							8							8		
Day of Month	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31	
Licensed Operator	8	8	8	8		8	8	8	8	8	8			8	8	
Others					8							8	8			

OPERATING EXCEPTIONS DETAILED

8/1-8/4 and 8/20-8/31 flow totalizer Digital read out not working. Daily flow a sum of estimated volume each hour from flow chart

East clarifier off line due to rapid settling rate

#1 filter off line due to influent valve being stuck in shut position

HOURS ATTENDED AT PLANT

Month 08

Year 94

Day of Month	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16
Licensed Operator	8	8	8	8	8	8		8	8	8	8	8	8		8	8
Others							8							8		
Day of Month	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31	
Licensed Operator	8	8	8	8		8	8	8	8	8	8			8	8	
Others					8							8	8			

NJPDES
Explanation of conditions
August 1994

9/22/94

The following explanations are included to clarify possible deviation from permit conditions.

General - The columns labeled "No. Ex", on the enclosed DMR, tabulate the number of daily discharge values outside the indicated limits.

Data reporting and accuracy reflect the working environment, the design capabilities and reliability of the monitoring instruments and operating equipment.

Analytical values performed by the following NJDEPE certified laboratories:

NET Atlantic, Inc. (08153)
Hope Creek Generating Station (17451)
Talbot Laboratory, Inc. (77535)
South Jersey Testing, Inc. (06431)
Princeton Testing Laboratory, Inc. (11118)

Deviations from required sampling, analysis monitoring and reporting methods and periodicities are noted on the respective transmittal sheet.

Frequency for discharge point 461A, the Cooling Tower Blowdown, and the River were done at approximately 5 hour intervals to provide for the cycles of concentration in the system.

As per the Administrative Consent Order the TSS limit for discharge points 462A, 463A and 464 have been lifted and the interim thermal limits for discharge point 461A have been changed to 443 MBTU/hr (June - September) and 731 MBTU/hr (October - May).

Results reported on the Discharge Monitoring Report forms are consistent with permit limits, data supplied from contract laboratories, the December 1993 revision of the NJDEPE DMR Instruction manual and specific guidance from DEP personnel.

Please note the use of the laser generated style of EPA form 3320-1. This format is now being used at Hope Creek and a copy of the letter indicating NJDEPE acceptance is included for your reference.

ADDENDA TO MONITORING REPORT - TRANSMITTAL SHEET

DISCHARGE NUMBER

PAGE	PARAMETER	COMMENTS
<u>461A</u>	NOTES	
2 of 5	00665 2 1 * 00680 2 1	Net values calculated from grab samples.
<u>461C</u>		
1 of 2	00680 1 1 *	Samples obtained were composites in accordance with permit requirements.

NJPDES
Explanation of Exceedances
August 1994

9/22/94

The following exceedances are included in the attached report and explained below. Exclusions have not endangered nor significantly impacted public health or the environment.

DSN No.


EXPLANATION

No Exceedances

COUNTY OF SALEM
STATE OF NEW JERSEY


I, Robert J. Hovey, of full age, being duly sworn according to law, upon my oath depose and say:

1. I am the General Manager of the Hope Creek Generating Station, and as such am authorized to sign Discharge Monitoring Reports submitted to the New Jersey Department of Environmental Protection pursuant to the Station's New Jersey Pollutant Discharge Elimination System permit.
2. I certify under penalty of law that I have personally examined and am familiar with the information submitted in this document and all attachments and that, based on my inquiry of those individuals immediately responsible for obtaining the information, I believe the submitted information is true, accurate and complete. I am aware that there are significant penalties for submitting false information including the possibility of fine and imprisonment.
3. The signature on the attached Discharge Monitoring Reports is my signature and I am submitting this affidavit in satisfaction of the requirement that my signature be notarized.



Robert J. Hovey
General Manager -
Hope Creek Operations

Sworn and subscribed before me
this 22 day of Sept 1994.



SHERI L. HUSTON
NOTARY PUBLIC OF NEW JERSEY
My Commission Expires Dec. 30, 1998

PERMITTEE NAME/ADDRESS

NAME PSE&G

ADDRESS P.O. BOX 236/N21

HANCOCKS BRIDGE, NJ 08038

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)
(2-16) (17-19)

NJ0025411

PERMIT NUMBER

461A

DISCHARGE NUMBER

MONITORING PERIOD

FACILITY PSE&G HOPE CREEK GENERATING STATION

LOCATION LOWER ALLOWAYS CREEK, NJ 08038

DMR NUMBER: 081994

COOLING TOWER BLOWDOWN

MAJOR

SALEM

SOUTHERN REGION

FROM


YEAR MO DAY
94 08 01

TO

YEAR MO DAY
94 08 31

(20-21)(22-23)(24-25)

(26-27)(28-29)(30-31)

PARAMETER (32-37)	SAMPLE MEASUREMENT (38-41)	(3 Card Only) QUANTITY OR LOADING (46-53)		UNITS	(4 Card Only) QUALITY OR CONCENTRATION (54-61)		UNITS	NO. EX. (62-63)	FREQ. OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)	
		QUANTITY OR LOADING (46-53)	UNITS (54-61)		QUALITY OR CONCENTRATION (54-61)	UNITS (54-61)					
TEMPERATURE, WATER DEG. CENTIGRADE 00010 1 1	SAMPLE MEASUREMENT	*****	*****		*****	29.7	32.8		0	CONTINUOUS	
EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	****	*****	REPORT MNTH AVG	35.6 DLY MAX	DEG.C	CONTINUOUS		
TEMPERATURE, WATER DEG. CENTIGRADE 00010 7 1	SAMPLE MEASUREMENT	*****	*****		*****	26.6	28.0		0	CONTINUOUS	
INTAKE FROM STREAM	PERMIT REQUIREMENT	*****	*****	****	*****	REPORT MNTH AVG	REPORT DLY MAX	DEG.C	CONTINUOUS		
PH	SAMPLE MEASUREMENT	*****	*****		8	*****	8		0	TWICE/GRAB WEEK	
EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	****	6	*****	9	SU	TWICE/GRAB WEEK		
SOLIDS, TOTAL SUSPENDED 000530 1 0	SAMPLE MEASUREMENT	*****	*****		*****	94	130		0	TWICE/GRAB MONTH	
EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	****	*****	REPORT MNTH AVG	REPORT DLY MAX	MG/L	TWICE/GRAB MONTH		
SOLIDS, TOTAL SUSPENDED 000530 2 0	SAMPLE MEASUREMENT	*****	*****		*****	66	95		0	TWICE/CALCTD MONTH	
EFFLUENT NET VALUE	PERMIT REQUIREMENT	*****	*****	****	*****	REPORT MNTH AVG	REPORT DLY MAX	MG/L	TWICE/CALCTD MONTH		
SOLIDS, TOTAL SUSPENDED 000530 7 0	SAMPLE MEASUREMENT	*****	*****		*****	28	35		0	TWICE/GRAB MONTH	
INTAKE FROM STREAM	PERMIT REQUIREMENT	*****	*****	****	*****	REPORT MNTH AVG	REPORT DLY MAX	MG/L	TWICE/GRAB MONTH		
HYDROCARBONS, IN H2O, IR, CC14 EXT. CHROMAT 000551 1 0	SAMPLE MEASUREMENT	*****	*****		*****	< 0.20	< 0.20		0	TWICE/GRAB MONTH	
EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	****	*****	REPORT MNTH AVG	REPORT DLY MAX	MG/L	TWICE/GRAB MONTH		
NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN, AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 USC § 1001 AND 33 USC § 1310. (Penalties under these statutes may include fines up to \$10,000 and/or maximum imprisonment of between 6 months and 5 years.)							TELEPHONE		DATE	
ROBERT J. HOVEY GENERAL MANAGER HOPE CREEK OPERATIONS	 SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT							609.339-3463		94 09 22	
TYPED OR PRINTED								AREA CODE	NUMBER	YEAR	MO DAY

SAMPLING FOR CO, ZN, & CR IS REQUIRED ONLY IF MAINTENANCE CHEMICALS CONTAINING THESE METALS ARE USED. IF NOT USED, ENTER "NODI" FOR THESE METALS.

PERMITTEE NAME/ADDRESS

NAME PSE&G

ADDRESS P.O. BOX 236/N21

HANCOCKS BRIDGE, NJ 08038

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)
(2-16) (17-19)

NJ0025411

PERMIT NUMBER

461A

DISCHARGE NUMBER

MONITORING PERIOD

FACILITY PSE&G HOPE CREEK GENERATING STATION

LOCATION LOWER ALLOWAYS CREEK, NJ 08038

FROM

YEAR MO DAY

94 08 01

TO

YEAR MO DAY

94 08 31

(20-21)(22-23)(24-25)

(26-27)(28-29)(30-31)

COOLING TOWER BLOWDOWN

MAJOR

SALEM

SOUTHERN REGION

DMR NUMBER: 081994

PARAMETER (32-37)	* * * * *	(3 Card Only) QUANTITY OR LOADING (46-53)			(4 Card Only) QUALITY OR CONCENTRATION (38-45)			QUALITY OR CONCENTRATION (54-61)			NO. EX (62-63)	FREQ. OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
				UNITS						UNITS			
HYDROCARBONS, IN H ₂ O, IR, CC14 EXT. CHROMAT 00551 2 0 EFFLUENT NET VALUE	SAMPLE MEASUREMENT	*****	*****		*****		< 0.2	< 0.2				OTWICE/MONTH	CALCTD
	PERMIT REQUIREMENT	*****	*****	****	*****	REPORT MNTH AVG	10 DLY MAX	MG/L				TWICE/MONTH	CALCTD
HYDROCARBONS, IN H ₂ O, IR, CC14 EXT. CHROMAT 00551 7 0 INTAKE FROM STREAM	SAMPLE MEASUREMENT	*****	*****		*****		< 0.20	< 0.20				OTWICE/MONTH	GRAB
	PERMIT REQUIREMENT	*****	*****	****	*****	REPORT MNTH AVG	REPORT DLY MAX	MG/L				TWICE/MONTH	GRAB
PHOSPHORUS, TOTAL (AS P) 00665 1 1 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****		*****		0.14	0.16				OTWICE/MONTH	GRAB
	PERMIT REQUIREMENT	*****	*****	****	*****	REPORT MNTH AVG	REPORT DLY MAX	MG/L				TWICE/MONTH	GRAB
PHOSPHORUS, TOTAL (AS P) 00665 2 1 EFFLUENT NET VALUE	SAMPLE MEASUREMENT	*****	*****		*****		0.04	0.06				OTWICE/MONTH	CALCTD **
	PERMIT REQUIREMENT	*****	*****	****	*****	REPORT MNTH AVG	REPORT DLY MAX	MG/L				TWICE/MONTH	GRAB
PHOSPHORUS, TOTAL (AS P) 00665 7 1 INTAKE FROM STREAM	SAMPLE MEASUREMENT	*****	*****		*****		0.10	0.10				OTWICE/MONTH	GRAB
	PERMIT REQUIREMENT	*****	*****	****	*****	REPORT MNTH AVG	REPORT DLY MAX	MG/L				TWICE/MONTH	GRAB
CARBON, TOT ORGANIC (TOC) 00680 1 1 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****		*****		13.0	15.0				OTWICE/MONTH	GRAB
	PERMIT REQUIREMENT	*****	*****	****	*****	REPORT MNTH AVG	REPORT DLY MAX	MG/L				TWICE/MONTH	GRAB
CARBON, TOT ORGANIC (TOC) 00680 2 1 EFFLUENT NET VALUE	SAMPLE MEASUREMENT	*****	*****		*****		6	7				OTWICE/MONTH	CALCTD **
	PERMIT REQUIREMENT	*****	*****	****	*****	REPORT MNTH AVG	20 DLY MAX	MG/L				TWICE/MONTH	GRAB

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER

ROBERT J. HOVEY
GENERAL MANAGER
HOPE CREEK OPERATIONS

TYPED OR PRINTED

I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN, AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 USC § 1001 AND 33 USC § 1319. (Penalties under these statutes may include fines up to \$10,000 and/or maximum imprisonment of between 6 months and 5 years.)

SIGNATURE OF PRINCIPAL
EXECUTIVE OFFICER OR
AUTHORIZED AGENT

TELEPHONE

DATE

609 339-3463 94 09 22

AREA
CODE

NUMBER

YEAR MO DAY

SAMPLING FOR CO, ZN, & CR IS REQUIRED ONLY IF MAINTENANCE CHEMICALS CONTAINING THESE METALS ARE USED. IF NOT USED, ENTER "NODI" FOR THESE METALS.

** PLEASE REFER TO THE ATTACHED TRANSMITTAL SHEET ADDENDA

PERMITTEE NAME/ADDRESS

NAME **PSE&G**ADDRESS **P.O. BOX 236/N21**
HANCOCKS BRIDGE, NJ 08038NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)
(2-16) (17-19)

NJ0025411

PERMIT NUMBER

461A

DISCHARGE NUMBER

MONITORING PERIOD

FROM	YEAR	MO	DAY	TO	YEAR	MO	DAY
	94	08	01		94	08	31

(20-21)(22-23)(24-25)

(26-27)(28-29)(30-31)

COOLING TOWER BLOWDOWN

MAJOR

SALEM

SOUTHERN REGION

FACILITY **PSE&G HOPE CREEK GENERATING STATION**LOCATION **LOWER ALLOWAYS CREEK, NJ 08038**DMR NUMBER: **081994**

DMR NUMBER: 081994														
PARAMETER (32-37)	* * * *	(3 Card Only) QUANTITY OR LOADING (46-53)			(4 Card Only) QUALITY OR CONCENTRATION (38-45)			QUALITY OR CONCENTRATION (54-61)			NO. EX (62 63)	FREQ. OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)	
				UNITS					UNITS					
CARBON, TOT ORGANIC (TOC)	SAMPLE MEASUREMENT	*****	*****		*****	6.4	8.1					0	TWICE/MONTH	GRAB
00680 7 1 INTAKE FROM STREAM	PERMIT REQUIREMENT	*****	*****	****	*****	REPORT MNTH AVG	REPORT DLY MAX	MG/L					TWICE/MONTH	GRAB
CHROMIUM, TOTAL (AS CR)	SAMPLE MEASUREMENT	*****	*****		*****	NODI	NODI					0	NODI	NODI
01034 1 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	****	*****	REPORT MNTH AVG	REPORT DLY MAX	MG/L					TWICE/MONTH	GRAB
CHROMIUM, TOTAL (AS CR)	SAMPLE MEASUREMENT	*****	*****		*****	NODI	NODI					0	NODI	NODI
01034 2 0 EFFLUENT NET VALUE	PERMIT REQUIREMENT	*****	*****	****	*****	REPORT MNTH AVG	.2 DLY MAX	MG/L					TWICE/MONTH	CALCTD
CHROMIUM, TOTAL (AS CR)	SAMPLE MEASUREMENT	*****	*****		*****	NODI	NODI					0	NODI	NODI
01034 7 0 INTAKE FROM STREAM	PERMIT REQUIREMENT	*****	*****	****	*****	REPORT MNTH AVG	REPORT DLY MAX	MG/L					TWICE/MONTH	GRAB
COPPER, TOTAL (AS CU)	SAMPLE MEASUREMENT	*****	*****		*****	NODI	NODI					0	NODI	NODI
01042 1 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	****	*****	REPORT MNTH AVG	REPORT DLY MAX	MG/L					TWICE/MONTH	GRAB
COPPER, TOTAL (AS CU)	SAMPLE MEASUREMENT	*****	*****		*****	NODI	NODI					0	NODI	NODI
01042 2 0 EFFLUENT NET VALUE	PERMIT REQUIREMENT	*****	*****	****	*****	REPORT MNTH AVG	.2 DLY MAX	MG/L					TWICE/MONTH	CALCTD
COPPER, TOTAL (AS CU)	SAMPLE MEASUREMENT	*****	*****		*****	NODI	NODI					0	NODI	NODI
01042 7 0 INTAKE FROM STREAM	PERMIT REQUIREMENT	*****	*****	****	*****	REPORT MNTH AVG	REPORT DLY MAX	MG/L					TWICE/MONTH	GRAB

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER

ROBERT J. HOVEY
GENERAL MANAGER
HOPE CREEK OPERATIONS

TYPED OR PRINTED

I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN, AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 USC § 1001 AND 33 USC § 1319. (Penalties under these statutes may include fines up to \$10,000 and/or maximum imprisonment of between 6 months and 5 years.)

SIGNATURE OF PRINCIPAL
EXECUTIVE OFFICER OR
AUTHORIZED AGENT

TELEPHONE

DATE

609 339-3463

94 09 22

AREA
CODE

NUMBER

YEAR MO DAY

SAMPLING FOR CO, ZN, & CR IS REQUIRED ONLY IF MAINTENANCE CHEMICALS CONTAINING THESE METALS ARE USED. IF NOT USED, ENTER "NODI" FOR THESE METALS.

PERMITTEE NAME/ADDRESS

NAME PSE&G

ADDRESS P.O. BOX 236/N21

HANCOCKS BRIDGE, NJ 08038

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)
(2-16) (17-19)

NJ0025411

PERMIT NUMBER

461A

DISCHARGE NUMBER

MONITORING PERIOD

FACILITY PSE&G HOPE CREEK GENERATING STATION

LOCATION LOWER ALLOWAYS CREEK, NJ 08038

DMR NUMBER: 081994

COOLING TOWER BLOWDOWN

MAJOR

SALEM

SOUTHERN REGION

PARAMETER (32-37)	SAMPLE MEASUREMENT PERMIT REQUIREMENT	(3 Card Only) QUANTITY OR LOADING (46-53) (54-61)		UNITS	(4 Card Only) QUALITY OR CONCENTRATION (38-45) (46-53) (54-61)		UNITS	NO. EX. (62-63)	FREQ. OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		QUANTITY OR LOADING	UNITS		QUALITY OR CONCENTRATION	UNITS				
ZINC, TOTAL (AS ZN) 01092 1 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	*****	*****	NODI	NODI	0	NODI	NODI
	PERMIT REQUIREMENT	*****	*****	*****	*****	REPORT MNTH AVG	REPORT DLY MAX	MG/L	TWICE/MONTH	GRAB
ZINC, TOTAL (AS ZN) 01092 2 0 EFFLUENT NET VALUE	SAMPLE MEASUREMENT	*****	*****	*****	*****	NODI	NODI	0	NODI	NODI
	PERMIT REQUIREMENT	*****	*****	*****	*****	REPORT MNTH AVG	REPORT DLY MAX	MG/L	TWICE/MONTH	CALCTD
ZINC, TOTAL (AS ZN) 01092 7 0 INTAKE FROM STREAM	SAMPLE MEASUREMENT	*****	*****	*****	*****	NODI	NODI	0	NODI	NODI
	PERMIT REQUIREMENT	*****	*****	*****	*****	REPORT MNTH AVG	REPORT DLY MAX	MG/L	TWICE/MONTH	GRAB
ASBESTOS (FIBROUS) 34225 1 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	*****	*****	<0.000004	<0.000004	UG/L	TWICE/MONTH	GRAB
	PERMIT REQUIREMENT	*****	*****	*****	*****	REPORT MNTH AVG	REPORT DLY MAX	UG/L	TWICE/MONTH	GRAB
ASBESTOS (FIBROUS) 34225 2 0 EFFLUENT NET VALUE	SAMPLE MEASUREMENT	*****	*****	*****	*****	<0.000004	<0.000004	UG/L	TWICE/MONTH	CALCTD
	PERMIT REQUIREMENT	*****	*****	*****	*****	REPORT MNTH AVG	REPORT DLY MAX	UG/L	TWICE/MONTH	CALCTD
ASBESTOS (FIBROUS) 34225 7 0 INTAKE FROM STREAM	SAMPLE MEASUREMENT	*****	*****	*****	*****	<0.000004	<0.000004	UG/L	TWICE/MONTH	GRAB
	PERMIT REQUIREMENT	*****	*****	*****	*****	REPORT MNTH AVG	REPORT DLY MAX	UG/L	TWICE/MONTH	GRAB
FLOW, IN CONDUIT OR THRU TREATMENT PLANT 50050 1 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	44.54	84.66	MGD	*****	*****	*****	0	CONTINUOUS	
	PERMIT REQUIREMENT	REPORT MNTH AVG	REPORT DLY MAX	MGD	*****	*****	*****	CONTINUOUS		

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER

ROBERT J. HOVEY

GENERAL MANAGER

HOPE CREEK OPERATIONS

TYPED OR PRINTED

I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN, AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 USC § 1001 AND 33 USC § 1310. (Penalties under these statutes may include fines up to \$10,000 and/or maximum imprisonment of between 6 months and 5 years.)

SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT

TELEPHONE

DATE

609 339-3463

94 09 22

AREA CODE

NUMBER

YEAR

MO

DAY

SAMPLING FOR CO, ZN, & CR IS REQUIRED ONLY IF MAINTENANCE CHEMICALS CONTAINING THESE METALS ARE USED. IF NOT USED, ENTER "NODI" FOR THESE METALS.

PERMITTEE NAME/ADDRESS

NAME **PSE&G**ADDRESS **P.O. BOX 236/N21****HANCOCKS BRIDGE, NJ 08038**FACILITY **PSE&G HOPE CREEK GENERATING STATION**LOCATION **LOWER ALLOWAYS CREEK, NJ 08038**DMR NUMBER: **081994**NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

NJ0025411

PERMIT NUMBER

461A

DISCHARGE NUMBER

MONITORING PERIOD

FROM

YEAR MO DAY

94 08 01

TO

YEAR MO DAY

94 08 31

(20-21)(22-23)(24-25)

(26-27)(28-29)(30-31)

COOLING TOWER BLOWDOWN

MAJOR

SALEM

SOUTHERN REGION

PARAMETER (32-37)	SAMPLE MEASUREMENT (38-41)	(3 Card Only) QUANTITY OR LOADING (46-53)		UNITS	(4 Card Only) QUALITY OR CONCENTRATION (58-65)		UNITS	NO. EX (62-63)	FREQ. OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		*****	*****		*****	*****				
CHLORINE, TOTAL RESIDUAL 50060 1 0	SAMPLE MEASUREMENT	*****	*****		*****	< 0.1	< 0.1			CONTINUOUS
EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	****	*****	.2 MNTH AVG	.5 DLY MAX	MG/L		CONTINUOUS
HEAT (SUMMER) (PER HOUR) 81386 2 1	SAMPLE MEASUREMENT	77	144		*****	*****	*****			CONTINUALCTD UOUS
EFFLUENT NET VALUE	PERMIT REQUIREMENT	REPORT MNTH AVG	443 DLY MAX	MBTU/ HR	*****	*****	*****	**** ***		CONTINUALCTD UOUS
	SAMPLE MEASUREMENT									
	PERMIT REQUIREMENT									
	SAMPLE MEASUREMENT									
	PERMIT REQUIREMENT									
	SAMPLE MEASUREMENT									
	PERMIT REQUIREMENT									
	SAMPLE MEASUREMENT									
	PERMIT REQUIREMENT									
	SAMPLE MEASUREMENT									
	PERMIT REQUIREMENT									
	SAMPLE MEASUREMENT									
	PERMIT REQUIREMENT									

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER

**ROBERT J. HOVEY
GENERAL MANAGER
HOPE CREEK OPERATIONS**

TYPED OR PRINTED

I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN; AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE, AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 USC § 1001 AND 33 USC § 1319. (Penalties under these statutes may include fines up to \$10,000 and/or maximum imprisonment of between 6 months and 5 years.)

SIGNATURE OF PRINCIPAL
EXECUTIVE OFFICER OR
AUTHORIZED AGENT

TELEPHONE

DATE

609 339-3463

94 09 22

AREA
CODE

NUMBER

YEAR MO DAY

SAMPLING FOR CO, ZN, & CR IS REQUIRED ONLY IF MAINTENANCE CHEMICALS CONTAINING THESE METALS ARE USED. IF NOT USED, ENTER "NODI" FOR THESE METALS.

PERMITTEE NAME/ADDRESS

NAME **PSE&G**
 ADDRESS **P.O. BOX 236/N21**
HANCOCKS BRIDGE, NJ 08038

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
 DISCHARGE MONITORING REPORT (DMR)
 (2-16) (17-19)

NJ0025411			461C				
PERMIT NUMBER			DISCHARGE NUMBER				
MONITORING PERIOD							
FROM	YEAR	MO	DAY	TO	YEAR	MO	DAY
	94	08	01		94	08	31
(20-21)(22-23)(24-25)				(26-27)(28-29)(30-31)			

LOW VOLUME WW SYSTEM
 MAJOR SALEM
 SOUTHERN REGION

FACILITY **PSE&G HOPE CREEK GENERATING STATION**
 LOCATION **LOWER ALLOWAYS CREEK, NJ 08038**

DMR NUMBER: 081994

PARAMETER (32-37)	SAMPLE MEASUREMENT (40-41)	(3 Card Only) QUANTITY OR LOADING (46-53)		UNITS	(4 Card Only) QUALITY OR CONCENTRATION (38-45)		UNITS	NO. OF ANALYSIS (64-68)	FREQ. OF ANALYSIS (69-70)	SAMPLE TYPE (69-70)		
		QUANTITY OR LOADING (46-53)	UNITS		QUALITY OR CONCENTRATION (38-45)	UNITS						
TEMPERATURE, WATER DEG. CENTIGRADE 00010 1 1	SAMPLE MEASUREMENT	*****	*****		*****	23.2	24.0		0	WEEKLY GRAB		
EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	****	*****	REPORT Mnth AVG	REPORT DLY MAX	DEG.C	0	WEEKLY GRAB		
PH	SAMPLE MEASUREMENT	*****	*****		8	*****	8		0	WEEKLY GRAB		
EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	****	6	*****	9	SU	0	WEEKLY GRAB		
SOLIDS, TOTAL SUSPENDED 00530 1 0	SAMPLE MEASUREMENT	*****	*****		*****	7	8		0	TWICE/COMPOS MONTH		
EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	****	*****	30 Mnth AVG	100 DLY MAX	MG/L	0	TWICE/COMPOS MONTH		
HYDROCARBONS, IN H2O, IR, CC14 EXT. CHROMAT 00551 1 0	SAMPLE MEASUREMENT	*****	*****		*****	< 0.2	< 0.2		0	TWICE/GRAB MONTH		
EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	****	*****	10 Mnth AVG	15 DLY MAX	MG/L	0	TWICE/GRAB MONTH		
NITROGEN, AMMONIA TOTAL (AS N) 00610 1 0	SAMPLE MEASUREMENT	*****	*****		*****	1	1		0	TWICE/COMPOS MONTH		
EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	****	*****	35 Mnth AVG	REPORT DLY MAX	MG/L	0	TWICE/COMPOS MONTH		
CARBON, TOT ORGANIC (TOC) 00680 1 1	SAMPLE MEASUREMENT	*****	*****		*****	18	18		0	TWICE/COMPOS MONTH **		
EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	****	*****	REPORT Mnth AVG	50 DLY MAX	MG/L	0	TWICE/GRAB MONTH		
COPPER, TOTAL (AS CU) 01042 1 0	SAMPLE MEASUREMENT	*****	*****		*****	0.1	0.1		0	TWICE/GRAB MONTH		
EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	****	*****	REPORT Mnth AVG	.2 DLY MAX	MG/L	0	TWICE/GRAB MONTH		
NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN, AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 USC § 1001 AND 33 USC § 1319. (Penalties under these statutes may include fines up to \$10,000 and/or maximum imprisonment of between 6 months and 5 years.)							TELEPHONE		DATE		
ROBERT J. HOVEY GENERAL MANAGER HOPE CREEK OPERATIONS								609 339-3463		94 09 22		
TYPED OR PRINTED	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT							AREA CODE	NUMBER	YEAR	MO	DAY

** Please refer to the attached Transmittal sheet addenda

PERMITTEE NAME/ADDRESS

NAME **PSE&G**ADDRESS **P.O. BOX 236/N21****HANCOCKS BRIDGE, NJ 08038**FACILITY **PSE&G HOPE CREEK GENERATING STATION**LOCATION **LOWER ALLOWAYS CREEK, NJ 08038**DMR NUMBER: **081994**NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)
(2-16) (17-19)**NJ0025411**

PERMIT NUMBER

461C

DISCHARGE NUMBER

MONITORING PERIOD

FROM	YEAR	MO	DAY	TO	YEAR	MO	DAY
	94	08	01		94	08	31

(20-21)(22-23)(24-25)

(26-27)(28-29)(30-31)


LOW VOLUME WW SYSTEM

MAJOR

SALEM

SOUTHERN REGION

PARAMETER (32-37)	SAMPLE MEASUREMENT (38-40)	(3 Card Only) QUANTITY OR LOADING (46-53)		UNITS	(4 Card Only) QUALITY OR CONCENTRATION (54-61)			UNITS	NO. EX (62) (63)	FREQ. OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		(46-53)	(54-61)		(54-55)	(56-57)	(58-61)				
IRON, TOTAL (AS FE) 01045 1 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****		*****	1.40	1.52				TWICE/MONTH GRAB
	PERMIT REQUIREMENT	*****	*****	****	*****	REPORT Mnth AVG	REPORT DLY MAX	MG/L			TWICE/MONTH GRAB
FLOW, IN CONDUIT OR THRU TREATMENT PLANT 50050 1 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	0.05	0.14		*****	*****	*****				CONTINUOUS
	PERMIT REQUIREMENT	REPORT Mnth AVG	.45 DLY MAX	MGD	*****	*****	*****	****			CONTINUOUS
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER ROBERT J. HOVEY GENERAL MANAGER HOPE CREEK OPERATIONS TYPED OR PRINTED	I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN; AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 USC § 1001 AND 33 USC § 1319. (Penalties under these statutes may include fines up to \$10,000 and/or maximum imprisonment of between 6 months and 5 years.)	 SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE		DATE		
			609 339-3463	94 09 22	AREA CODE	NUMBER	YEAR

PERMITTEE NAME/ADDRESS

NAME PSE&G

ADDRESS P.O. BOX 236/N21
HANCOCKS BRIDGE, NJ 08038NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)
(2-16) (17-19)

NJ0025411

PERMIT NUMBER

462A

DISCHARGE NUMBER

MONITORING PERIOD

FACILITY PSE&G HOPE CREEK GENERATING STATION

LOCATION LOWER ALLOWAYS CREEK, NJ 08038

FROM

YEAR MO DAY

94 08 01

TO

YEAR MO DAY

94 08 31

(20-21)(22-23)(24-25)

(26-27)(28-29)(30-31)

NORTH STORM DRAIN
MAJOR
SOUTHERN REGION

SALEM

DMR NUMBER: 081994

PARAMETER (32-37)	SAMPLE MEASUREMENT (38-43)	(3 Card Only) QUANTITY OR LOADING (46-53)		UNITS	(4 Card Only) QUALITY OR CONCENTRATION (54-61)		UNITS	NO. EX. (62-63)	FREQ. OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		(46-53)	(54-61)		(54-61)	(54-61)				
PH	SAMPLE MEASUREMENT	*****	*****		7.6	*****	7.6		0 ONCE/MONTH	GRAB
00400 1 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	****	6.0 MINIMUM	*****	9.0 MAXIMUM	SU	ONCE/MONTH	GRAB
SOLIDS, TOTAL SUSPENDED	SAMPLE MEASUREMENT	*****	*****		*****		16		0 ONCE/MONTH	GRAB
00530 1 1 (ADMIN) EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	****	*****	REPORT Mnth AVG	REPORT DLY MAX	MG/L	ONCE/MONTH	GRAB
HYDROCARBONS, IN H2O, IR, CC14 EXT. CHROMAT	SAMPLE MEASUREMENT	*****	*****		*****	< 0.2	< 0.2		0 ONCE/MONTH	GRAB-3
00551 1 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	****	*****	REPORT Mnth AVG	15 DLY MAX	MG/L	ONCE/MONTH	GRAB-3
CARBON, TOT ORGANIC (TOC)	SAMPLE MEASUREMENT	*****	*****		*****	16	16		0 ONCE/MONTH	GRAB
00680 1 1 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	****	*****	REPORT Mnth AVG	50 DLY MAX	MG/L	ONCE/MONTH	GRAB
FLOW, IN CONDUIT OR THRU TREATMENT PLANT	SAMPLE MEASUREMENT	0.261	0.261		*****	*****	*****		0 ONCE/MONTH	
50050 1 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	REPORT Mnth AVG	REPORT DLY MAX	MGD	*****	*****	*****	****	ONCE/MONTH	
	SAMPLE MEASUREMENT									
	PERMIT REQUIREMENT									
	SAMPLE MEASUREMENT									
	PERMIT REQUIREMENT									

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER
ROBERT J. HOVEY
GENERAL MANAGER
HOPE CREEK OPERATIONS

TYPED OR PRINTED

I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN, AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 USC § 1001 AND 33 USC § 1319. (Penalties under these statutes may include fines up to \$10,000 and/or maximum imprisonment of between 6 months and 5 years.)

SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT

TELEPHONE
609 339-3463

DATE
94 09 22

SAMPLES TO BE TAKEN DURING A DISCHARGE EVENT, EXCEPT FOR PET HC FOR WHICH SAMPLES SHALL BE TAKEN DURING THE 1ST PRECIPITATION EVENT OF MONTH WHICH CAUSES DISCHARGE DURING WORKING HRS & IS PRECEDED BY MINIMUM DRY PERIOD OF 72 HRS.

PERMITTEE NAME/ADDRESS

NAME **PSE&G**
 ADDRESS **P.O. BOX 236/N21**
HANCOCKS BRIDGE, NJ 08038

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
 DISCHARGE MONITORING REPORT (DMR)
 (2-16) (17-19)

NJ0025411
 PERMIT NUMBER
462B
 DISCHARGE NUMBER

FACILITY **PSE&G HOPE CREEK GENERATING STATION**
 LOCATION **LOWER ALLOWAYS CREEK, NJ 08038**

DMR NUMBER: 081994

MONITORING PERIOD
 FROM YEAR MO DAY TO YEAR MO DAY
94 08 01 94 08 31
 (20-21)(22-23)(24-25) (26-27)(28-29)(30-31)

SEWAGE W.W.
MAJOR
SOUTHERN REGION

SALEM

PARAMETER (32-37)	SAMPLE MEASUREMENT	(3 Card Only) QUANTITY OR LOADING (46-53)		UNITS	(4 Card Only) QUALITY OR CONCENTRATION (38-45)		UNITS	NO. OF ANALYSIS (62-65)	FREQ. OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		REPORT Mnth Avg	REPORT Dly Max		REPORT Mnth Avg	REPORT Dly Max				
BOD, 5-DAY (20 DEG. C) 00310 G 0 RAW SEW/INFLUENT	SAMPLE MEASUREMENT	96.8	96.8	KG/DAY	*****	728.0	728.0	MG/L	0 ONCE/MONTH	GRAB
	PERMIT REQUIREMENT	REPORT Mnth Avg	REPORT Dly Max	KG/DAY	*****	REPORT Mnth Avg	REPORT Dly Max	MG/L	ONCE/MONTH	GRAB
BOD, 5-DAY (20 DEG. C) 00310 1 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	1.8	1.8	KG/DAY	*****	13.5	13.5	MG/L	0 ONCE/MONTH	GRAB
	PERMIT REQUIREMENT	REPORT Mnth Avg	REPORT Dly Max	KG/DAY	*****	REPORT Mnth Avg	REPORT Dly Max	MG/L	ONCE/MONTH	GRAB
PH	SAMPLE MEASUREMENT	*****	*****		7.1	*****	7.7		0 TWICE/WEEK	GRAB
00400 1 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	*****	6.0 MINIMUM	*****	9.0 MAXIMUM	SU	TWICE/WEEK	GRAB
SOLIDS, TOTAL SUSPENDED 00530 G 0 RAW SEW/INFLUENT	SAMPLE MEASUREMENT	*****	*****	*****	*****	278	278	MG/L	0 ONCE/MONTH	COMPOS
	PERMIT REQUIREMENT	*****	*****	*****	*****	REPORT Mnth Avg	REPORT Dly Max	MG/L	ONCE/MONTH	COMPOS
SOLIDS, TOTAL SUSPENDED 00530 1 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	*****	*****	< 1	< 1	MG/L	0 ONCE/MONTH	COMPOS
	PERMIT REQUIREMENT	*****	*****	*****	*****	30 Mnth Avg	100 Dly Max	MG/L	ONCE/MONTH	COMPOS
OIL AND GREASE FREON EXTR-GRAV METH 00556 1 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	*****	*****	< 1	< 1	MG/L	0 ONCE/MONTH	GRAB
	PERMIT REQUIREMENT	*****	*****	*****	*****	10 Mnth Avg	15 Dly Max	MG/L	ONCE/MONTH	GRAB
FLOW, IN CONDUIT OR THRU TREATMENT PLANT 50050 1 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	0.026	0.048	MGD	*****	*****	*****	*****	0 DAILY	FLOIND
	PERMIT REQUIREMENT	REPORT Mnth Avg	REPORT Dly Max	MGD	*****	*****	*****	*****	DAILY	FLOIND

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER
ROBERT J. HOVEY
GENERAL MANAGER
HOPE CREEK OPERATIONS
 TYPED OR PRINTED

I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN, AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 USC § 1001 AND 35 USC § 1370. (Penalties under these statutes may include fines up to \$10,000 and/or maximum imprisonment of between 6 months and 5 years.)

SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT

TELEPHONE
609 339-3463

DATE
94 09 22

AREA CODE NUMBER YEAR MO DAY

PERMITTEE NAME/ADDRESS

NAME **PSE&G**ADDRESS **P.O. BOX 236/N21**
HANCOCKS BRIDGE, NJ 08038FACILITY **PSE&G HOPE CREEK GENERATING STATION**LOCATION **LOWER ALLOWAYS CREEK, NJ 08038**DMR NUMBER: **081994**NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)
(2-16) (17-19)

NJ0025411

PERMIT NUMBER

462B

DISCHARGE NUMBER

MONITORING PERIOD

FROM	YEAR	MO	DAY	TO	YEAR	MO	DAY
	94	08	01		94	08	31
	(20-21)(22-23)(24-25)				(26-27)(28-29)(30-31)		


SEWAGE W.W.
MAJOR
SOUTHERN REGION

SALEM

PARAMETER (32-37)	SAMPLE MEASUREMENT	(3 Card Only) QUANTITY OR LOADING (46-53)		UNITS	(4 Card Only) QUALITY OR CONCENTRATION (38-45) (46-53) (54-61)			UNITS	NO. EX. (62-63)	FREQ. OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
COLIFORM, FECAL GENERAL 74055 1 0	SAMPLE MEASUREMENT	*****	*****		*****	< 1	< 1		0	ONCE/MONTH	GRAB
EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	****	*****	200	400	£/100		ONCE/MONTH	GRAB
BOD, 5-DAY PERCENT REMOVAL 81010 K 0	SAMPLE MEASUREMENT	*****	*****		98.1	98.1	*****		0	ONCE/MONTH	CALCTD
PERCENT REMOVAL	PERMIT REQUIREMENT	*****	*****	****	87.5	REPORT	*****	PERCE		ONCE/MONTH	CALCTD
SOLIDS, SUSPENDED PERCENT REMOVAL 81011 K 0	SAMPLE MEASUREMENT	*****	*****		100	100	*****		0	ONCE/MONTH	CALCTD
PERCENT REMOVAL	PERMIT REQUIREMENT	*****	*****	****	85	REPORT	*****	PERCE		ONCE/MONTH	CALCTD
OXYGEN DEMAND FIRST STAGE 82210 1 0	SAMPLE MEASUREMENT	2.2	2.2		*****	16.2	16.2		0	ONCE/MONTH	CALCTD
EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	8.2	REPORT	KG/DAY	*****	REPORT	REPORT	MG/L		ONCE/MONTH	CALCTD
		MNTH AVG	DLY MAX			MNTH AVG	DLY MAX				
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER
ROBERT J. HOVEY
 GENERAL MANAGER
 HOPE CREEK OPERATIONS
 TYPED OR PRINTED

I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN, AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 USC § 1001 AND 33 USC § 1319. (Penalties under these statutes may include fines up to \$10,000 and/or maximum imprisonment of between 6 months and 5 years.)

TELEPHONE
609 339-3463
 AREA CODE NUMBER
 SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT

 DATE
94 09 22
 YEAR MO DAY

PERMITTEE NAME/ADDRESS

NAME PSE&G

ADDRESS P.O. BOX 236/N21

HANCOCKS BRIDGE, NJ 08038

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)
(2-16) (17-19)

NJ0025411

PERMIT NUMBER

463A

DISCHARGE NUMBER

FACILITY PSE&G HOPE CREEK GENERATING STATION

LOCATION LOWER ALLOWAYS CREEK, NJ 08038

DMR NUMBER: 081994

MONITORING PERIOD						
FROM			TO			
YEAR	MO	DAY	YEAR	MO	DAY	
94	08	01	94	08	31	
(20-21)(22-23)(24-25)			(26-27)(28-29)(30-31)			

(20-21)(22-23)(24-25)

(26-27)(28-29)(30-31)

SOUTH STORM DRAIN
MAJOR
SOUTHERN REGION

SALEM

DMR NUMBER: 081994													
PARAMETER (32-37)	(3 Card Only) QUANTITY OR LOADING (46-53)			(4 Card Only) QUALITY OR CONCENTRATION (38-45)			(46-53) QUALITY OR CONCENTRATION (54-61)			NO. EX (62 63)	FREQ. OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
				UNITS				UNITS					
PH	SAMPLE MEASUREMENT	*****	*****		7.4	*****	7.4	SU	0	ONCE/MONTH	GRAB		
00400 1 0	PERMIT REQUIREMENT	*****	*****	****	6.0	*****	9.0		ONCE/MONTH	GRAB			
EFFLUENT GROSS VALUE				****	MINIMUM		MAXIMUM						
SOLIDS, TOTAL	SAMPLE MEASUREMENT	*****	*****		*****		86	MG/L	0	ONCE/MONTH	GRAB		
SUSPENDED	PERMIT REQUIREMENT	*****	*****	****	*****	REPORT	REPORT		ONCE/MONTH	GRAB			
00530 1 1 (ADMIN)				****		MNTH AVG	DLY MAX						
EFFLUENT GROSS VALUE				****									
HYDROCARBONS, IN H2O,	SAMPLE MEASUREMENT	*****	*****		*****		0	MG/L	0	ONCE/MONTH	GRAB-3		
IR, CC14 EXT. CHROMAT	PERMIT REQUIREMENT	*****	*****	****	*****	REPORT	15		ONCE/MONTH	GRAB-3			
00551 1 0				****		MNTH AVG	DLY MAX						
EFFLUENT GROSS VALUE				****									
CARBON, TOT ORGANIC (TOC)	SAMPLE MEASUREMENT	*****	*****		*****		17	MG/L	0	ONCE/MONTH	GRAB		
00680 1 1	PERMIT REQUIREMENT	*****	*****	****	*****	REPORT	50		ONCE/MONTH	GRAB			
EFFLUENT GROSS VALUE				****		MNTH AVG	DLY MAX						
FLOW, IN CONDUIT OR	SAMPLE MEASUREMENT	0.282	0.282		*****	*****	*****	****	0	ONCE/MONTH			
THRU TREATMENT PLANT	PERMIT REQUIREMENT	REPORT	REPORT	MGD	*****	*****	*****		ONCE/MONTH				
50050 1 0		MNTH AVG	DLY MAX					***					
EFFLUENT GROSS VALUE													
	SAMPLE MEASUREMENT												
	PERMIT REQUIREMENT												
	SAMPLE MEASUREMENT												
	PERMIT REQUIREMENT												

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER

ROBERT J. HOVEY
GENERAL MANAGER
HOPE CREEK OPERATIONS

TYPED OR PRINTED

I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN, AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 USC § 1001 AND 33 USC § 1319. (Penalties under these statutes may include fines up to \$10,000 and/or maximum imprisonment of between 6 months and 5 years.)

SIGNATURE OF PRINCIPAL
EXECUTIVE OFFICER OR
AUTHORIZED AGENT

TELEPHONE

DATE

609 339-3463

94 09 22

AREA
CODE

NUMBER

YEAR

MO

DAY

SAMPLES TO BE TAKEN DURING A DISCHARGE EVENT, EXCEPT FOR PET HC FOR WHICH SAMPLES SHALL BE TAKEN DURING THE 1ST PRECIPITATION EVENT OF MONTH WHICH CAUSES DISCHARGE DURING WORKING HRS & IS PRECEDED BY MINIMUM DRY PERIOD OF 72 HRS.

PERMITTEE NAME/ADDRESS

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)
(2-16) (17-19)

NAME PSE&G

ADDRESS P.O. BOX 236/N21

HANCOCKS BRIDGE, NJ 08038

NJ0025411

464A

PERMIT NUMBER

DISCHARGE NUMBER

MONITORING PERIOD

FROM	YEAR	MO	DAY	TO	YEAR	MO	DAY
	94	08	01		94	08	31

(20-21)(22-23)(24-25) (26-27)(28-29)(30-31)

PERIM STORM DRAIN
MAJOR
SOUTHERN REGION

SALEM

FACILITY PSE&G HOPE CREEK GENERATING STATION

LOCATION LOWER ALLOWAYS CREEK, NJ 08038

DMR NUMBER: 081994

PARAMETER (32-37)	SAMPLE MEASUREMENT (38-41)	(3 Card Only) QUANTITY OR LOADING (46-53)		UNITS	(4 Card Only) QUALITY OR CONCENTRATION (54-61)		UNITS	NO. EX. (62-63)	FREQ. OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
PH	SAMPLE MEASUREMENT	*****	*****		7.7	*****	7.7		0	ONCE/MONTH
00400 1 0	PERMIT REQUIREMENT	*****	*****	****	6.0	*****	9.0	SU		ONCE/MONTH
EFFLUENT GROSS VALUE				****	MINIMUM		MAXIMUM			GRAB
SOLIDS, TOTAL	SAMPLE MEASUREMENT	*****	*****		*****		16		0	ONCE/MONTH
SUSPENDED	PERMIT REQUIREMENT	*****	*****	****	*****		16	MG/L		ONCE/MONTH
00530 1 1 (ADMIN)				****	REPORT		REPORT			GRAB
EFFLUENT GROSS VALUE				****	MNTH AVG		DLY MAX			ONCE/MONTH
KYDROCARBONS, IN H2O,	SAMPLE MEASUREMENT	*****	*****		*****		< 0.2		0	ONCE/MONTH
IR, CC14 EXT. CHROMAT	PERMIT REQUIREMENT	*****	*****	****	*****		< 0.2			GRAB-3
00551 1 0				****	REPORT		15	MG/L		ONCE/MONTH
EFFLUENT GROSS VALUE				****	MNTH AVG		DLY MAX			GRAB-3
CARBON, TOT ORGANIC	SAMPLE MEASUREMENT	*****	*****		*****		20		0	ONCE/MONTH
(TOC)	PERMIT REQUIREMENT	*****	*****	****	*****		50	MG/L		ONCE/MONTH
00680 1 1				****	REPORT		DLY MAX			GRAB
EFFLUENT GROSS VALUE				****	MNTH AVG					ONCE/MONTH
FLOW, IN CONDUIT OR	SAMPLE MEASUREMENT	0.368	0.368		*****	*****	*****		0	ONCE/MONTH
THRU TREATMENT PLANT	PERMIT REQUIREMENT	REPORT	REPORT	MGD	*****	*****	*****	****		ONCE/MONTH
50050 1 0		MNTH AVG	DLY MAX							
EFFLUENT GROSS VALUE										
	SAMPLE MEASUREMENT									
	PERMIT REQUIREMENT									
	SAMPLE MEASUREMENT									
	PERMIT REQUIREMENT									

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER

ROBERT J. HOVEY
GENERAL MANAGER
HOPE CREEK OPERATIONS

TYPED OR PRINTED

I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN; AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 USC § 1001 AND 33 USC § 1310. (Penalties under these statutes may include fines up to \$10,000 and/or maximum imprisonment of between 6 months and 5 years.)

SIGNATURE OF PRINCIPAL
EXECUTIVE OFFICER OR
AUTHORIZED AGENT

TELEPHONE

DATE

609 339-2463 94 09 22

AREA
CODE

NUMBER

YEAR

MO

DAY

SAMPLES TO BE TAKEN DURING A DISCHARGE EVENT, EXCEPT FOR PET HC FOR WHICH SAMPLES SHALL BE TAKEN DURING THE 1ST PRECIPITATION EVENT OF MONTH WHICH CAUSES DISCHARGE DURING WORKING HRS & IS PRECEDED BY MINIMUM DRY PERIOD OF 72 HRS.

LABS: 08153 17451 77535 06431 11118

PAGE 12 OF 12