



Commonwealth Edison
LaSalle County Nuclear Station
Rural Route #1, Box 220
Marseilles, Illinois 61341
Telephone 815/357-6761

April 8, 1983

James G. Keppler
Regional Administrator
Region III
U.S. Nuclear Regulatory Commission
799 Roosevelt Road
Glen Ellyn, IL 60137

Dear Sir:

In accordance with LaSalle County Station Unit 1 Facility Operating License NPF-11, Appendix B, Section 3.2, we are submitting to you a copy of the NPDES noncompliances for LaSalle County Nuclear Generating Station Permit No. IL0048151.

G. J. Diederich
Superintendent
LaSalle County Station

GJD/FRL/JDW/rg

Enclosure

cc: DVR Report

8304150538 830408
PDR ADOCK 05000373
S PDR

APR 11 1983

IE22



Commonwealth Edison
LaSalle County Nuclear Station
Rural Route #1, Box 220
Marseilles, Illinois 61341
Telephone 815/357-6761

March 21, 1983

U.S. Environmental Protection Agency
Region V, Enforcement Division
ATTN: Chief, Compliance Unit
230 South Dearborn Street
Chicago, IL 60604

Illinois Environmental Protection Agency
Division of Water Pollution Control
Compliance Management Unit
2200 Churchill Road
Springfield, IL 62706

Dear Sir:

Subject: NPDES Noncompliances for LaSalle County Nuclear
Generating Station - Permit No. IL0048151

In accordance with Standard Condition 12, we wish to submit the following notice of noncompliances, which are listed chronologically in the attached table.

If there are any questions, please contact Joe Williams of my staff at (815) 357-6761, extension 201.

G. J. Diederich
Station Superintendent

for JDN
GJD/FRL/JDW/lrw

cc: Director of Water Quality, Environmental Affairs
Manager, Nuclear Stations Division

LASALLE COUNTY NUCLEAR GENERATING STATION
N.P.D.E.S. PERMIT NO: IL0048151
NONCOMPLIANCE REPORT

DISCHARGE NUMBER AND DESCRIPTION: 001C Low Volume Waste
Regen. Wastes Soln. Discharge Tanks

PARAMETER AND PERMIT LIMIT: Total Iron, 1.0 mg/l

NONCOMPLIANCE, DATE, AND DURATION: 8.3 mg/l, 11 March 83, 3 Hours

CAUSE OF NONCOMPLIANCE: The most probable cause of this noncompliance is wastes from Unit 2 condensate polishing system regeneration.

CORRECTIVE ACTION: The modification to provide the option for treatment of these tanks in the wastewater treatment facility has been implemented effective 21 March 83.

DATE RECOGNIZED AS A VIOLATION:

17 March 83

DATE INVESTIGATED:

21 March 83