


ENCLOSURE

FIGURE 5.6-3

FUEL BURNUP, MID/K<sub>0</sub>U



- Domain I: Fuel assemblies with initial enrichment-burnup combinations in Domain I may be placed in either Region 1, 2, or 3 storage cells.
- Domain II: Fuel assemblies with initial enrichment-burnup combinations in Domain II shall be placed only in Region 1 or 3 storage cells.
- Domain III: Fuel assemblies with initial enrichment-burnup combinations in Domain III shall be placed only in Region 1 storage cells

FIGURE 5.6-3