



Pennsylvania Power & Light Company

Two North Ninth Street • Allentown, PA 18101 • 215 / 770-5151

April 5, 1983

Mr. R.C. Haynes
Regional Administrator, Region I
U.S. Nuclear Regulatory Commission
631 Park Avenue
King of Prussia, PA 19406

SUSQUEHANNA STEAM ELECTRIC STATION
LICENSEE EVENT REPORT 83-043/01T-0
ER 100450 FILE 841-23
PLA 1605

Docket No. 50-387
License No. NPF-14

Dear Mr. Haynes:

Attached please find a copy of Licensee Event Report No. 83-043/01T-0. This event was determined to be reportable per Technical Specification 6.9.1.8.a, in that the reactor mode switch when turned to the shutdown position did not initiate a full SCRAM. The reactor was in a shutdown condition prior to and during this event.

H.W. Keiser
Superintendent of Plant-Susquehanna

JTT/pjg

attachment

cc: Director of Nuclear Reactor Regulation
Attention: Mr. A. Schwencer, Chief
Licensing Branch No. 2
Division of Licensing
U.S. Nuclear Regulatory Commission
Washington, DC 20555

G.G. Rhoads
Resident Inspector
U.S. Nuclear Regulatory Commission
P.O. Box 52
Shickshinny, PA 18655

8304180218 830405
PDR ADOCK 05000387
S PDR

IE22