



Pennsylvania Power & Light Company

Two North Ninth Street • Allentown, PA 18101 • 215 / 770-5151

April 5, 1983

Mr. R.C. Haynes
Regional Administrator, Region I
U.S. Nuclear Regulatory Commission
631 Park Avenue
King of Prussia, PA 19406

SUSQUEHANNA STEAM ELECTRIC STATION
LICENSEE EVENT REPORT 83-044/03L-0
ER 100450 FILE 841-23
PLA 1606

Docket No. 50-387
License No. NPE-14

Dear Mr. Haynes:

Attached please find a copy of Licensee Event Report No. 83-044/03L-0. This event was determined to be reportable per Technical Specification 6.9.1.9.b, in that the High Pressure Coolant Injection system was isolated while the steam dome pressure was greater than 150psig.

H.W. Keiser
Superintendent of Plant-Susquehanna

JTT/pjg

cc: Director of Nuclear Reactor Regulation
Attention: Mr. A. Schwencer, Chief
Licensing Branch No. 2
Division of Licensing
U.S. Nuclear Regulatory Commission
Washington, DC 20555

G.G. Rhoads
Resident Inspector
U.S. Nuclear Regulatory Commission
P.O. Box 52
Shickshinny, PA 18655

IE22