

UNITED STATES OF AMERICA
NUCLEAR REGULATORY COMMISSION
BEFORE THE ATOMIC SAFETY AND LICENSING BOARD

'83 APR 13 11:15

In the Matter of)

PUBLIC SERVICE COMPANY OF)
NEW HAMPSHIRE, et al.)


(Seabrook Station, Units 1)
and 2))


Docket Nos. 50-443
50-444

NECNP REWODED CONTENTION I.D.2, TESTING AT
POWER OF MANUAL REACTOR TRIP ACTIATION FUNCTION

The Applicants do not comply with Reg. Guide 1.22 by
virture of their failure to provide for the testing of the
manual reactor trip actuation function at full power, justify
that omission, or provide for other reliable means of testing
it. Therefore Applicants violate GDC 21.

Respectfully submitted,


William S. Jordan, III


Diane Curran
HARMON & WEISS
1725 I Street, N.W.
Suite 506
Washington, D.C. 20006
(202) 833-9070

April 13, 1983

DS03