

CONTROL BLOCK:

--	--	--	--	--	--

1

0	1	N	J	S	G	S	1	2	0	0	-	0	0	0	0	0	-	0	0	3	4	1	1	1	1	4			5	
7	8	LICENSEE CODE						14	LICENSE NUMBER												25	LICENSE TYPE					30	CAT		58

0	1	REPORT SOURCE																DOCKET NUMBER																EVENT DATE																REPORT DATE															
7	8	60 61 62 63 64 65 66 67 68 69 70 71 72 73 74 75 76 77 78 79 80																																																															

0 2 Pressurizer Code Safety Valves 1PR3, 1PR4, and 1PR5 were tested for lift set pressure

0 3 and seat leakage by Wyle Laboratories during the period of November 2-13, 1982. All

0 4 valves lifted in excess of the 2485 psig \pm 1% pressure range specified in Technical

0 5 Specification 3.4.2.2. Also, all valves exhibited heavy seat leakage. The actual lift

0 6 pressures were: 1PR3 - 2564 psig (54 psig over), 1PR4 - 2532 psig (22 psig over),

0 7 1PR5 - 2546 psig (36 psig over).

0	9		C	B	11	E	12	B	13	V	A	L	V	E	X	14	J	15	B	16			
7	8		9	10		11		12		13					18		19		20				
LER RO REPORT NUMBER		EVENT YEAR				SEQUENTIAL REPORT NO.				OCCURRENCE CODE				REPORT TYPE				REVISION NO.					
17		8	3				0	0	8			0	3		L			0					
21	22	23		24	26	27		28	29	30		31		32									
ACTION TAKEN		FUTURE ACTION		EFFECT ON PLANT		SHUTDOWN METHOD		HOURS		ATTACHMENT SUBMITTED		NPRD-4 FORM SUB		PRIME COMP. SUPPLIER		COMPONENT MANUFACTURER							
D	18	Z	19	Z	20	Z	21	0	0	0	0	22	Y	23	Y	24	N	25	C	7	1	0	26
33	34	35		36		37		38	39	40		41		42		43		44	45	46	47		

1 0 All three valves were repaired and retested satisfactorily, then reinstalled. In
1 1 order to assess the actual impact of the safety valve test failures on plant performance
1 2 during the analyzed transient, an engineering evaluation of the occurrence has been
1 3 requested. A Supplemental Report will be submitted upon completion of the
1 4 evaluation.

FACILITY STATUS		% POWER			OTHER STATUS		METHOD OF DISCOVERY		DISCOVERY DESCRIPTION				
1	5	H	28	0	0	0	29	N/A	30	C	31	Pressure Lift Test	32
7	8	9	10	11	12	13	14	15	16	17	18	19	20

ACTIVITY CONTENT
RELEASED OF RELEASE

1 6 33 34

7 8 9 10 11

AMOUNT OF ACTIVITY (35)

N/A

44

LOCATION OF RELEASE (36)

N/A

45 80

PERSONNEL EXPOSURES									
NUMBER			TYPE	DESCRIPTION	(39)				
1	7	0	0	0	(37)	Z	(38)	N/A	

PERSONNEL INJURIES	80
NUMBER	DESCRIPTION
41	

7 8 9 10 11 12 N/A

LOSS OF OR DAMAGE TO FACILITY (43)

TYPE		DESCRIPTION	
1	9	Z	42
N/A			

PUBLICITY
 ISSUED DESCRIPTION (45)
 2 0 [N] (44) N/A
 8304180484 830406
 PDR ADOCK 05000272
 S PDR
 NRC USE ONLY

NAME OF PREPARER F. Dickey

PHONE: (609) 935-6000 Ext. 3229