



TU ELECTRIC

Log # TXX-91167  
File # 10110  
10010  
910.3  
Ref. # 10CFR50.55(e)

May 1, 1991

William J. Cahill, Jr.  
Executive Vice President

U. S. Nuclear Regulatory Commission  
Attn: Document Control Desk  
Washington, DC 20555

SUBJECT: COMANCHE PEAK STEAM ELECTRIC STATION (CPSES) - UNIT 2  
DOCKET NO. 50-446  
MOTOR OPERATORS FOR MANUAL VALVES  
SDAR CP-86-35: FINAL REPORT

REF: 1) TXX-4840 dated June 2, 1986  
2) TXX-89874 dated January 2, 1990  
3) TXX-6446 dated May 15, 1987

Gentlemen:

On June 2, 1986, TU Electric notified you via Reference 1 of a reportable item involving the motor operators for several valves in the main steam system. Reference 2 stated that Unit 2 activities for this item were not scheduled, but would be discussed in a report prior to fuel load. This report describes the corrective action to be completed on Unit 2.

The corrective action for Unit 2 will be identical to that for Unit 1 as described in Reference 3. That is, design changes are being implemented to restore the modified manually operated valves to their original condition and to install additional air-operated valves to provide for the double HELB isolation capabilities described in FSAR Section 7.6.12.2. These modifications will be completed prior to fuel load.

Sincerely,

William J. Cahill, Jr.

JTC/bm

c - Mr. R. D. Martin, Region IV  
Resident Inspectors, CPSES (2)  
Mr. M. L. Fields, NRR

9105070100 910501  
PDR ADOCK 05000446  
S PDR

060067

400 North Olive Street L.B. 81 Dallas, Texas 75201

IE27  
110