



MISSISSIPPI POWER & LIGHT COMPANY

Helping Build Mississippi

P. O. BOX 340, JACKSON, MISSISSIPPI 39205

April 13, 1983

JAMES P. McGAUGHY, JR.
VICE PRESIDENT

Office of Inspection & Enforcement
U. S. Nuclear Regulatory Commission
Region II
101 Marietta St., N.W., Suite 2900
Atlanta, Georgia 30303

Attention: Mr. J. P. O'Reilly, Regional Administrator

Dear Mr. O'Reilly:

SUBJECT: Grand Gulf Nuclear Station
Unit 1
Docket No. 50-416
License No. NPF-13
File: 0260/L-835.0
Special Report 83-018/0 - Fire Rated
Doors Blocked Open to Support Planned
Work
AECM-83/0237

On March 7, 1983, fire rated doors OC202, OC105, and OC106 were blocked open to support work performed under Design Change Package (DCP) 82/5004. The doors open to the stairway and corridors on elevations 93 and 111 feet of the Control Building. The work package was performed to install a power supply to the Emergency Response Facility Information System (ERFIS) computer and its peripherals.

The doors were restored to operability on April 5, 1983. An hourly fire watch was maintained during the Limiting Condition for Operation (LCO) in accordance with Technical Specification 3.7.7. Since the seven day time limit of the LCO was exceeded, this is submitted as a Special Report pursuant to Technical Specification 6.9.2

Yours truly,

J. P. McGaughy, Jr.
FOR J. P. McGaughy, Jr.

JPM:rg

cc: See next page

8304190221 830413
PDR ADOCK 05000416
S PDR

OFFICIAL COPY

TE 22

83 APR 15 4:29

MISSISSIPPI POWER & LIGHT COMPANY

AECM-83/0237

Page 2

cc: Mr. J. B. Richard
Mr. R. B. McGehee
Mr. T. B. Conner
Mr. G. B. Taylor

Mr. Richard C. DeYoung, Director
Office of Inspection & Enforcement
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Document Control Desk
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555