

LICENSEE EVENT REPORT

CONTROL BLOCK / / / / / / (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

/0/1/ /V/A/N/A/S/1/ (2) /0/0/-/0/0/0/0/0/-/0/0/ (3) /4/1/1/1/1/ (4) / / / (5)
 LICENSEE CODE LICENSE NUMBER LICENSE TYPE CAT

/0/1/ REPORT /L/ (6) /0/5/0/0/0/3/3/8/ (7) /0/3/1/3/8/3/ (8) /0/4/0/7/8/3/ (9)
 SOURCE DOCKET NUMBER EVENT DATE REPORT DATE

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

/0/2/ / On March 13, 1983, with the Unit in Mode 3, Individual Rod Position Indication /
 /0/3/ / (IRPI) for Rod G-13 in Shutdown Bank "A" deviated from the group demand position /
 /0/4/ / by greater than 12 steps. The reactor trip breakers were immediately opened as /
 /0/5/ / required by the Action Statement, thus the health and safety of the general /
 /0/6/ / public were not affected. This event is contrary to T.S. 3.1.3.3 and reportable /
 /0/7/ / pursuant to T.S. 6.9.1.9.b. /
 /0/8/ /

SYSTEM CAUSE CAUSE COMP. VALVE
 CODE CODE SUBCODE COMPONENT CODE SUBCODE SUBCODE

/0/9/ /I/D/ (11) /E/ (12) /E/ (13) /I/N/S/T/R/U/ /I/ /Z/
 LER/RO EVENT YEAR SEQUENTIAL OCCURRENCE REPORT REVISION
 (17) REPORT NO. TYPE NO.
 NUMBER /8/3/ /-/ /0/0/5/ / / /0/3/ /L/ /-/ /0/

ACTION FUTURE EFFECT SHUTDOWN ATTACHMENT NPRD-4 PRIME COMP. COMPONENT
 TAKEN ACTION ON PLANT METHOD HOURS SUBMITTED FORM SUB. SUPPLIER MANUFACTURER

/E/ (18) /Z/ (19) /Z/ (20) /Z/ (21) /0/0/0/0/ (22) /N/ (23) /N/ (24) /N/ (25) /W/1/2/0/
 (26)

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

/1/0/ / The cause of the indicator disagreement was instrument drift. This is a recurr- /
 /1/1/ / ing problem and is generic to Westinghouse Analog Position Indication Systems. /
 /1/2/ / The Rod Position Indicator Channel for Rod G-13 was properly recalibrated and /
 /1/3/ / returned to service. /
 /1/4/ /

FACILITY METHOD OF
 STATUS %POWER OTHER STATUS DISCOVERY DISCOVERY DESCRIPTION (32)
 /1/5/ /G/ (28) /0/0/0/ (29) / NA / (30) /A/ (31) / Operator Observation /

ACTIVITY CONTENT
 RELEASED OF RELEASE AMOUNT OF ACTIVITY (35) LOCATION OF RELEASE (36)
 /1/6/ /Z/ (33) /Z/ (34) / NA / / NA /

PERSONNEL EXPOSURES
 NUMBER TYPE DESCRIPTION (39)
 /1/7/ /0/0/0/ (37) /Z/ (38) / NA /

PERSONNEL INJURIES
 NUMBER DESCRIPTION (41)
 /1/8/ /0/0/0/ (40) / NA /

LOSS OF OR DAMAGE TO FACILITY (43)
 TYPE DESCRIPTION
 /1/9/ /Z/ (42) / NA /

PUBLICITY
 ISSUED DESCRIPTION (45)
 /2/0/ /N/ (44) / NA /

NRC USE ONLY

NAME OF PREPARER E. WAYNE HARRELL PHONE (703) 894-5151