

CONTROL BLOCK:

						(1)
--	--	--	--	--	--	-----

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0	1	N	C	B	E	P	1	2	0	0	-	0	0	0	0	0	-	0	0	3	4	1	1	1	1	4			5	
7	8	LICENSEE CODE							14	LICENSE NUMBER										25	26	LICENSE TYPE					30	57	CAT	58

CON'T

0 1 7 8

REPORT SOURCE L 6 0 5 0 - 0 3 2 5 7 0 3 1 3 8 3 8 0 4 1 2 8 3 9

60 61 DOCKET NUMBER 68 69 EVENT DATE 74 75 REPORT DATE 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 | During the ongoing unit refueling outage, while replacing selected LPRM inputs with

0 3 | APRM B manually bypassed, APRMs B and F were rendered inoperable due to too few LPRM

0 4 | inputs. Later that same day with APRM D manually bypassed, APRM B was rendered in-

0 5 | operable due to too few LPRM inputs. In each case, a trip signal was then manually

0 6 | inserted on the affected B RPS channel in accordance with technical specifications.

0 7 | These events did not affect the health and safety of the public.

Technical Specifications 3.3.1, 6.9.1.9b

Technical Specifications 3.3.1, 6.9.1.9b

7 8 9

0 8

SYSTEM CODE I B (11)

CAUSE CODE E (12)

CAUSE SUBCODE E (13)

COMPONENT CODE I N S T R U (14)

COMP. SUBCODE E (15)

VALVE SUBCODE Z (16)

7 8

0 9

LER/RO REPORT NUMBER (17)

EVENT YEAR 8 3 (21)

SEQUENTIAL REPORT NO. 0 1 3 (24)

OCCURRENCE CODE 0 3 (28)

REPORT TYPE L (30)

REVISION NO. 0 (32)

ACTION TAKEN D (18)

FUTURE ACTION Z (19)

EFFECT ON PLANT Z (20)

SHUTDOWN METHOD Z (21)

HOURS 0 0 0 0 (22)

ATTACHMENT SUBMITTED N (23)

NPFD-4 FORM SUB. Y (24)

PRIME COMP. SUPPLIER N (25)

COMPONENT MANUFACTURER G 0 8 0 (26)

7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 LPRMs 20-29D and 83-174A had failed causing APRMs B and F to become inoperable and

1 1 LPRM 28-37C had failed causing APRM B to become inoperable. A sufficient number of

1 2 LPRMs, Model No. NA-200, were repaired to return APRMs B, D, and F to service. No

1 2 further action regarding these events is planned.

1 4 7 8 9

FACILITY STATUS (28) 1 5 H
 % POWER 0 0 0 (29) 10 12
 OTHER STATUS (30) NA 44
 METHOD OF DISCOVERY (31) A
 DISCOVERY DESCRIPTION (32) Operational Event 80

ACTIVITY CONTENT
RELEASED OF RELEASE AMOUNT OF ACTIVITY (35) NA LOCATION OF RELEASE (36)

PERSONNEL EXPOSURES											
NUMBER			TYPE	DESCRIPTION							
1	7	0	0	(37) Z	(38) NA						

PERSONNEL INJURIES
NUMBER DESCRIPTION (41)
1 8 0 0 0 (40) NA
S PDR

1 9		Z		42		43	
TYPE		DESCRIPTION					
				NA			

2 0 N 44 NA

NRC USE ONLY

NAME OF PREPARER M. J. Pastva, Jr.

PHONE: 919-457-9521