

LICENSEE EVENT REPORT

CONTROL BLOCK:

1	2	3	4	5	6
---	---	---	---	---	---

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0	1	N	C	B	E	P	1	2	0	0	-	0	0	0	0	-	0	0	3	4	1	1	1	1	4		5
---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	--	---

7 8 9 14 15 25 26 30 57 CAT 58

CON'T

0	1	L	6	0	5	0	-	0	3	2	5	7	0	3	1	2	8	3	8	0	4	1	1	8	3	9
---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---

7 8 60 61 68 69 74 75 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 | Routine Surveillance during unit refueling operations revealed "00" and "full-in"

0 3 | position indication for control rod 30-15 was inoperable. On 3-17-83, "full-in"

0 4 | position indication for control rod 10-31 and "00" position indication for control

0 5 | rod 26-07 were inoperable. These events did not affect the health and safety of the

0 6 | public.

0 7 |

0 8 | Technical Specifications 3.1.3.7, 6.9.1.9b

7 8 9 80

0	9	I	D	11	A	12	X	13	X	X	X	X	X	X	14	Z	15	Z	16
---	---	---	---	----	---	----	---	----	---	---	---	---	---	---	----	---	----	---	----

7 8 9 10 11 12 13 18 19 20

17	8	3		0	1	2		0	3	L		0
----	---	---	--	---	---	---	--	---	---	---	--	---

21 22 23 24 26 27 28 29 30 31 32
ACTION TAKEN FUTURE ACTION EFFECT ON PLANT SHUTDOWN METHOD HOURS ATTACHMENT SUBMITTED NPRD-4 FORM SUB. PRIME COMP. SUPPLIER COMPONENT MANUFACTURER
X 18 Z 19 Z 20 Z 21 0 0 0 0 N 23 Y 24 N 25 G 0 8 0 26
33 34 35 36 37 40 41 42 43 44 47

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 | Both problems, bent pins in the PIP connector to rod 30-15 and a loose PIP connector

1 1 | to rod 10-31, are attributed to accidental bumping during undervessel work. No

1 2 | detectable problem was found with rod 26-07. The PIP connectors to 30-15 and 26-07

1 3 | (Model No. 798D227G003) were replaced, the PIP connector to 10-31 was reconnected,

1 4 | and position indications of the subject rods were reestablished.

7 8 9 80

1	5	H	28	0	0	0	29	NA	A	31	Operator Surveillance	32
---	---	---	----	---	---	---	----	----	---	----	-----------------------	----

7 8 9 10 12 13 44 45 46 80

1	6	Z	33	Z	34	NA	NA	36
---	---	---	----	---	----	----	----	----

7 8 9 10 11 44 45 80

1	7	0	0	0	37	Z	38	NA	39
---	---	---	---	---	----	---	----	----	----

7 8 9 10 11 12 13 80

1	8	0	0	0	40	NA	41
---	---	---	---	---	----	----	----

7 8 9 10 11 12 80

1	9	Z	42	NA	43
---	---	---	----	----	----

7 8 9 10 80

2	0	N	44	NA	45
---	---	---	----	----	----

7 8 9 10 80
ISSUED DESCRIPTION
N
PDR ADOCK 830411 830411 05000325 PDR
S
NRC USE ONLY
68 69 80

NAME OF PREPARER M.J. Pastva, Jr.

PHONE (919) 457-9521