



Carolina Power & Light Company

Brunswick Steam Electric Plant
P. O. Box 10429
Southport, NC 28461-0429

April 8, 1983

FILE: B09-13510C
SERIAL: BSEP/83-1151

Mr. James P. O'Reilly, Director
U. S. Nuclear Regulatory Commission
Region II, Suite 3100
101 Marietta Street NW
Atlanta, GA 30303

BRUNSWICK STEAM ELECTRIC PLANT, UNIT NO. 2
DOCKET NO. 50-324
LICENSE NO. DPR-62
SPECIAL REPORT PER TECHNICAL SPECIFICATION 3.7.8

Dear Mr. O'Reilly:

During Unit No. 2 power operation on March 2, 1983, four fire barrier LCOs were generated to permit work in the Service Water Building required for the installation of a plant modification. Due to the complexity of the work involved with this modification, the seven-day specified time frame of the subject LCOs was exceeded. On April 4, 1983, the involved plant modification was completed, and the four affected fire barriers were returned to service. This report is submitted pursuant to Technical Specification 6.9.2.

Very truly yours,

C. R. Dietz, General Manager
Brunswick Steam Electric Plant

RMP/shb/LETSB1

Enclosure

cc: Mr. R. C. DeYoung
NRC Document Control Desk

OFFICIAL COPY

TE 22

8304190403 830408
PDR ADOCK 05000324
S PDR