



DUKE POWER

September 29, 1994

U.S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, D.C. 20555

Subject: Catawba Nuclear Station, Units 1 and 2
Docket Nos. 50-413 and 50-414
Generic Letter 89-13, "Service Water System Problems Affecting Safety Related Equipment"

By letters dated January 26, 1990, September 12, 1990 and October 20, 1993, Duke Power provided updates to the status and schedule for implementation of outstanding activities associated with the subject Generic Letter.

These letters, collectively, constitutes consideration of all actions identified and required by Generic Letter 89-13. Preventative/corrective measures were initiated to meet compliance with the requirements of Generic Letter 89-13, however, during a recent Service Water Inspection performed here at Catawba by Region II, areas of concern were identified, with respect to full compliance to Generic Letter 89-13, for which additional preventative/corrective measures are planned:

- The Service Water System Assured Make-up lines to the Component Cooling System Surge Tanks were identified as stagnant service water lines, not all of which were flushed or flow tested on a periodic basis. These lines were subsequently flushed or radiographed to verify adequate flow. Procedures to flush these lines periodically, initially on a quarterly frequency, are currently being developed for implementation by December 1, 1994.
- The Service Water System Assured Supply to the Auxiliary Shutdown Panel Supply Units were identified as stagnant service water lines that are not currently flushed at design flow. Measures to periodically flush these normally stagnant lines at design flow rates will be implemented by January 1, 1995.


9410070124 940929
PDR ADOCK 05000413
PDR

AD65/10

U.S. Nuclear Regulatory Commission
September 29, 1994
Page 2

Accordingly, following implementation of these additional measures, by January 1, 1995, Catawba compliance to Generic Letter 89-13 will be fully implemented and considered closed.

If there are any further questions regarding Generic Letter 89-13, please contact Jeff Lowery at (803) 831-3414.

Handwritten signature of Mark E. Patrick in cursive script.

D.L. Rehn, Site Vice-President
Catawba Nuclear Station

/JLL

cc: S.D. Ebnetter
Regional Administrator, Region II

R.E. Martin, ONRR

R.J. Freudenberger
Senior Resident Inspector