

CP&L

Carolina Power & Light Company

Brunswick Steam Electric Plant
P. O. Box 10429
Southport, NC 28461-0429

April 8, 1983

FILE: B09-13510C
SERIAL: BSEP/83-1150


Mr. James P. O'Reilly, Director
U. S. Nuclear Regulatory Commission
Region II, Suite 3100
101 Marietta Street NW
Atlanta, GA 30303

BRUNSWICK STEAM ELECTRIC PLANT, UNIT NO. 1
DOCKET NO. 50-325
LICENSE NO. DPR-71
SPECIAL REPORT PER TECHNICAL SPECIFICATION 3.7.8

Dear Mr. O'Reilly:

During a Unit No. 1 refueling outage, four fire barrier LCOs (one with an issuance date of March 2, 1983, and three with issuance dates of March 11, 1983) were generated to permit work in the Augmented Off-Gas and Control Buildings required for the installation of two plant modifications. Due to the complexity of the work required with these modifications, the seven-day specified time frame of these LCOs has been exceeded. Until completion of the involved modification work and cancellation of the subject LCOs, appropriate stationed fire watches will remain in effect. This report is submitted pursuant to Technical Specification 6.9.2.

Very truly yours,



C. R. Dietz, General Manager
Brunswick Steam Electric Plant

RMP/shb/LETSB1

Enclosure

cc: Mr. R. C. DeYoung
NRC Document Control Desk

8304190410 830408
PDR ADOCK 05000325
S PDR

OFFICIAL COPY

IE 22

83 APR 14 4 9: 26
USNRC REGION II
ATLANTA, GEORGIA