

ATTACHMENT 2

TECHNICAL SPECIFICATION PAGES WITH PEN AND INK CHANGES

LICENSE AMENDMENT APPLICATION

REVISION OF SRM AND IRM CHANNEL CALIBRATION FREQUENCIES

FACILITY OPERATING LICENSE NPF-57

HOPE CREEK GENERATING STATION

DOCKET NO. 50-354

NLR-N94125

LCR 94-21

The following Technical Specifications for Facility Operating License No. NPF-57 are affected by this License Amendment Request:

Technical Specification

Page

Table 4.3.6-1

3/4 3-60

TABLE 4.3.6-1

CONTROL ROD BLOCK INSTRUMENTATION SURVEILLANCE REQUIREMENTS

<u>TRIP FUNCTION</u>	<u>CHANNEL CHECK</u>	<u>CHANNEL FUNCTIONAL TEST</u>	<u>CHANNEL CALIBRATION</u> ^(a)	<u>OPERATIONAL CONDITIONS FOR WHICH SURVEILLANCE REQUIRED</u>
1. <u>ROD BLOCK MONITOR</u>				
a. Upscale	NA	Z ^{(c)(d)} , Q ^(c)	SA	1*
b. Inoperative	NA	Z ^{(c)(d)} , Q ^(c)	NA	1*
c. Downscale	NA	Z ^{(c)(d)} , Q ^(c)	SA	1*
2. <u>APRM</u>				
a. Flow Biased Neutron Flux - Upscale	NA	S/U ^(b) , Q	SA	1
b. Inoperative	NA	S/U ^(b) , Q	NA	1, 2, 5
c. Downscale	NA	S/U ^(b) , Q	SA	1
d. Neutron Flux - Upscale, Startup	NA	S/U ^(b) , Q	SA	2, 5
3. <u>SOURCE RANGE MONITORS</u>				
a. Detector not full in	NA	S/U ^(b) , W	NA R	2, 5
b. Upscale	NA	S/U ^(b) , W	SA R	2, 5
c. Inoperative	NA	S/U ^(b) , W	NA R	2, 5
d. Downscale	NA	S/U ^(b) , W	SA R	2, 5
4. <u>INTERMEDIATE RANGE MONITORS</u>				
a. Detector not full in	NA	S/U ^(b) , W	NA R	2, 5
b. Upscale	NA	S/U ^(b) , W	SA R	2, 5
c. Inoperative	NA	S/U ^(b) , W	NA R	2, 5
d. Downscale	NA	S/U ^(b) , W	SA R	2, 5
5. <u>SCRAM DISCHARGE VOLUME</u>				
a. Water Level-High (Float Switch)	NA	Q	R	1, 2, 5**
6. <u>REACTOR COOLANT SYSTEM RECIRCULATION FLOW</u>				
a. Upscale	NA	S/U ^(b) , Q	SA	1
b. Inoperative	NA	S/U ^(b) , Q	NA	1
c. Comparator	NA	S/U ^(b) , Q	SA	1
7. <u>REACTOR MODE SWITCH SHUTDOWN POSITION</u>	NA	R	NA	3, 4