

3150-0011
EXPIRES 4-30-82

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

7 8 9
REPORT SOURCE L 6 0 5 0 0 0 3 9 5 7 0 3 1 8 8 3 8 0 4 1 2 8 3 9
60 61 DOCKET NUMBER 68 69 EVENT DATE 74 75 REPORT DATE 80

0	2	On March 18, 1985, with the Plant in Mode 3, one of the Reactor Building Cooling
0	3	Unit Service Water Flow Indicators failed low. Accident Monitoring
0	4	Instrumentation Channel 4496 was subsequently declared inoperable at 1135 hours in
0	5	accordance with Action Statement (a) of Technical Specification 3.3.3.6. There
0	6	were no adverse consequences from this event since redundant flow and pressure
0	7	indications were available for monitoring system performance.
0	8	

SYSTEM CODE		CAUSE CODE		CAUSE SUBCODE		COMPONENT CODE				COMP. SUBCODE		VALVE SUBCODE					
0	9	I	D	E	E	I	N	S	T	R	U	I	Z				
7	8	9	10	11	12	13	14	15	16	17	18	19	20				
(17) LER/RO REPORT NUMBER		EVENT YEAR		SEQUENTIAL REPORT NO.		OCCURRENCE CODE		REPORT TYPE		REVISION NO.							
8 3		18 3		0 2 6		0 3		L		0							
21		22		23		24		25		26							
ACTION TAKEN		FUTURE ACTION		EFFECT ON PLANT		SHUTDOWN METHOD		HOURS		ATTACHMENT SUBMITTED		NPRD-4 FORM SUB.		PRIME COMP. SUPPLIER		COMPONENT MANUFACTURER	
C	Z	Z	Z	Z	Z	0	0	0	0	N	N	N	A	I	1	3	0
33	34	35	36	37	38	39	40	41	42	43	44	45	46	47	48	49	50

1 0 The cause of the low flow indication is attributed to an internal failure of
1 1 indicator FI-4496. The indicator would not respond above half scale. The
1 2 indicator was replaced and returned to operable status on March 23, 1983, upon
1 3 completion of a satisfactory channel calibration. The licensee plans no
1 4 additional action in regards to this event.

FACILITY STATUS (28) 1 5 D 0 0 0 29 N/A 30
 % POWER 10 12 13
 OTHER STATUS 30
 METHOD OF DISCOVERY 44 45 46 A 31
 DISCOVERY DESCRIPTION 32 Operator Observation 80
 ACTIVITY CONTENT 7 8 9 10 11 12 13
 RELEASED OF RELEASE 1 6 Z 33
 AMOUNT OF ACTIVITY 35 Z 34 N/A 42
 LOCATION OF RELEASE 36 N/A 60

		PERSONNEL EXPOSURES			
		NUMBER	TYPE	DESCRIPTION	
1	7	000	(37) Z	(38)	N/A

PERSONNEL INJURIES		DESCRIPTION		(41)
NUMBER				
1	8	0	0	0
				(40)
				N/A

7 8 9 10 11 12

LOSS OF OR DAMAGE TO FACILITY
TYPE DESCRIPTION (43)

(1) (9) | Z(42) | N/A

8304190447 830412
PDR ADOCK 05000395
S PDR

7 8 9 10 80
 PUBLICITY ISSUED DESCRIPTION (45) NRC USE ONLY

C. J. McKinney

PHONE

(803) 345-5209