

Georgia Power Company  
40 Inverness Center Parkway  
Post Office Box 1295  
Birmingham, Alabama 35201  
Telephone 205 877-7122

C. K. McCoy  
Vice President, Nuclear  
Vogtle Project

October 6, 1994



Docket No. 50-424

U. S. Nuclear Regulatory Commission  
ATTN: Document Control Desk  
Washington, D. C. 20555

Ladies and Gentlemen:

VOGTLE ELECTRIC GENERATING PLANT  
TECHNICAL SPECIFICATIONS SPECIAL REPORT- UNIT 1  
NUMBER OF STEAM GENERATOR TUBES PLUGGED DURING 1R5

In accordance with the requirements of Vogtle Electric Generating Plant Technical Specifications (TS) sections 4.4.5.5.a and 6.8.2, Georgia Power Company (GPC) submits the enclosed special report containing the number of steam generator tubes plugged during the Unit 1 fifth refueling outage (1R5).

As a result of the inservice inspection completed on October 1, 1994, a total of twelve (12) tubes were plugged in steam generators 2, 3, and 4. Only five (5) of these tubes met or exceeded the TS limit for wall thinning (40 percent). The remainder were plugged as a precautionary measure. Complete inspection results will be submitted within 12 months per the requirement of TS 4.4.5.5.b.

Sincerely,

*C. K. McCoy*  
C. K. McCoy

CKM/TEW/AFS

cc: Georgia Power Company  
Mr. J. B. Beasley, Jr.  
Mr. M. Sheibani  
NORMS

120017

U. S. Nuclear Regulatory Commission  
Mr. S. D. Ebnetter, Regional Administrator  
Mr. D. S. Hood, Licensing Project Manager, NRR  
Mr. B. R. Bonser, Senior Resident Inspector, Vogtle

9410120113 941006  
PDR ADDCK 05000424  
P PDR

ADD 1/0