



Entergy
Operations

Entergy Operations, Inc.

Regulatory Affairs

Washington, DC 20004

Telephone (202) 462-1111

May 8, 1991

1CAN059104

U. S. Nuclear Regulatory Commission
Document Control Desk
Mail Station P1-137
Washington, DC 20555

SUBJECT: Arkansas Nuclear One - Unit 1
Docket No. 50-313
License No. DPR-51
Inservice Inspection Outage
Summary Report

Gentlemen:

Article IWA-6230, Section XI of the ASME Code requires the Owner to submit a inservice inspection (ISI) summary report. This report is due within 90 days of the completion of the ISI conducted during a refueling outage. The scope of the report is for Class 1 and 2 pressure retaining components and their supports. The purpose of this submittal is to provide the required summary report.

Attachment 1 provides the summary report of the ISI performed during the ninth refueling outage (1R9) for Arkansas Nuclear One, Unit 1 (ANO-1). This summary report was prepared in accordance with Section XI of the Code. The outage was completed on January 7, 1991. The delay in this submittal, which was discussed with the NRC NRR Project Manager, is due to personnel changes and upgrades in the ANO-1 ISI program.

Attachment 2 provides a summary of the reportable indications found during the ISI and the resolution of these indications. The forms NIS-2 "Owner's Report for Repairs or Replacements" are provided in Attachment 3.

Should you have any questions regarding this issue, please contact me.

Very truly yours,

Rich J. King for JJJ
James J. Fisicaro
Director, Licensing

JJF/RWC/kdr
Attachments

9105140074 910508
PDR ADOCK 05000313
Q PDR

A047
11

cc: Mr. Robert Martin
Regional Administrator
U. S. Nuclear Regulatory Commission
Region IV
611 Ryan Plaza Drive, Suite 1000
Arlington, TX 76011

NRC Senior Resident Inspector
Arkansas Nuclear One - ANO-1 & 2
Number 1, Nuclear Plant Road
Russellville, AR 72801

Mr. Thomas W. Alexion
NRR Project Manager, Region IV/ANO-1
U. S. Nuclear Regulatory Commission
NRR Mail Stop 11-D-23
One White Flint North
11555 Rockville Pike
Rockville, Maryland 20852

Ms. Sheri Peterson
NRR Project Manager, Region IV/ANO-2
NRR Mail Stop 11-D-23
One White Flint North
11555 Rockville Pike
Rockville Maryland 20852

ATTACHMENT 1

INSERVICE INSPECTION

SUMMARY REPORT FOR AND-1