

UNITED STATES NUCLEAR REGULATORY COMMISSION

In the Matter of)	
)	
NIAGARA MOHAWK POWER CORPORATION)	Docket No. 50-410
)	
Nine Mile Point Nuclear Station Unit 2)	

APPLICATION FOR AMENDMENT TO OPERATING LICENSE

Pursuant to Section 50.90 of the Regulations of the Nuclear Regulatory Commission, Niagara Mohawk Power Corporation, holder of Facility Operating License No. NPF-69, hereby requests that action statements b and b.1 and the applicability of LCO 3.7.3, "Control Room Outdoor Air Special Filter Train System," and the tables 3.3.7.1-1 and 4.3.7.1-1 of LCO 3.3.7.1 "Radiation Monitoring Instruemtnation" of the Technical Specifications as set forth in Appendix A to that License be amended. The proposed changes have been reviewed in accordance with Section 6.5 of the Technical Specifications.

The proposed Technical Specification changes contained herein represent revisions to the applicability, action statement b and action statement b.1 of Limiting Condition for Operation (LCO) 3.7.3, "Control Room Outdoor Air Special Filter Train System," and to Tables 3.3.7.1-1, "Radiation Monitoring Instrumentation," and 4.3.7.1-1, "Radiation Monitoring Instrumentation Surveillance Requirements," of LCO 3.3.7.1, "Radiation Monitoring Instrumentation." LCO 3.7.3 is presently applicable in all operational conditions including when irradiated fuel is being handled in the reactor building and during core alterations and operations with a potential for draining the reactor vessel and uncovering irradiated fuel.

Specifically, the proposed change to the applicability of LCO 3.7.3 would make this LCO applicable during operational conditions 1, 2, 3 and when irradiated fuel is being handled in the reactor building and during core alterations and operations with a potential for draining the reactor vessel and uncovering irradiated fuel. Additionally, to be consistent with the above proposed change, a revision is proposed to action statement b of LCO 3.7.3.

The change to action statement b.1 of LCO 3.7.3 would exclude this action statement from the requirements of LCO 3.0.4. The changes to Tables 3.3.7.1-1 and 4.3.7.1-1 of LCO 3.3.7.1 are made to be consistent with the change to the applicability of LCO 3.7.3.

The proposed changes will not authorize any change in the types of effluents or in the authorized power level of the facility in conjunction with this Application for License Amendment. Supporting information and analysis which demonstrate that the proposed changes do not involve a significant hazards consideration, pursuant to 10 CFR 50.92, are included as Attachment B.

Wherefore, the Applicant respectfully requests that Appendix A to Facility Operating License No. NPF-69 be amended in the form attached hereto as Attachment A.


NIAGARA MOHAWK POWER CORPORATION

By



B. Ralph Sylvia
Executive Vice President - Nuclear

Subscribed and sworn to before me
on this 4th day of Oct 1994.



NOTARY PUBLIC

BEVERLY W. RIPKA
Notary Public State of New York
in Oswego Co. No. 4644879
Commission Exp. Mar. 30, 1996

4/27/96