

SEISMIC QUALIFICATION
OF THE
REACTOR CORE COOLING BENCH BOARD
EQUIPMENT NO.1H13-P601

PREPARED BY SARGENT & LUNDY



SEISMIC ANALYSIS OF MAIN	
Calcs. For	
CONTROL BOARD FOR ZIMMER	
NUCLEAR PLANT	
<input checked="" type="checkbox"/> Safety-Related	<input type="checkbox"/> Non-Safety-Related

CALC. NO: CQD-002323
REV: 00 DATE: 06/03/82
PROJECT NUMBER: 4130-15

PAGE 1 OF 67

Client	CG&E Co.
Project	ZIMMER -1
Proj. No.	4130-15
Equip. No.	1H13-P601

Prepared by	<i>Harish Kumar</i>	Date	06-03-82
Reviewed by	<i>Talat Kumar</i>	Date	06-04-82
Approved by	<i>y. A. Patel</i>	Date	06/04/82

Purpose

To requalify panel 1H13-P601 per the latest instrument list.

Data and Assumptions

Structural details were obtained from drawings Nos. E24068 & E2407. The finite element model as well as member structural properties were based on the original qualification reports; EMD File No. 021333



Calcs. For

CALC. NO: CDD-002323
REV: 00 DATE: 06/03/82
PROJECT NUMBER: 4130-15

Safety-Related

Non-Safety-Related

PAGE 2 OF 67

Client	Prepared by	Date
Project	Reviewed by	Date
Proj. No.	Approved by	Date
Equip. No.		

References

1. Sargent & Lundy drawing Nos. E 2406, Sheet 1. Rev. F, E 2406 Sheet 3, Rev. F, E 2407, Sheet 2, Rev. S
2. Seismic Qualification Report for Panel 1H13-PG01 EMD File No. 021333, Rev. 00 Feb. 8, 1980
3. Response Spectra For Zimner Elevation 546'-0"
SDD-EMD-30 Rev. 1 8-16-76 pp. 26 thru 29, 31, 32.

Client	Prepared by	Date
Project	Reviewed by	Date
Proj. No.	Approved by	Date
Equip. No.		

Conclusion

A dynamic finite element analysis was performed to requalify panel IH13-P601. Results of this analysis indicate that panel IH13-P601 is seismically qualified. Pertinent details of the evaluation are summarized below.

Panel IH13-P601 was qualified earlier (EMD File No. 021333). The requalification was required due to changes in both the location and weight of the instruments.

A Finite element model of the panel was constructed based on the original qualification report. The model constructed has 121 nodes, 90 plate elements and 152 beam elements. The static analysis based on the revised loads yielded negligibly small element stresses as well as small nodal displacements. The dynamic analysis consisted of (i) an eigenfrequency analysis and (ii) a response spectra analysis.

In the eigenfrequency analysis a total of 16 modes were determined. The fundamental frequency is 5.57 Hz., the predominant vibratory response for the first 3 modes is along the shorter horizontal axis of the panel. The factored global matrices as well as modal participation factors have been saved on permanent file for later use.



Calcs. For

CALC. NO: CQD-002323
REV: 00 DATE: 06/03/82
PROJECT NUMBER: 413C-15

Safety-Related

Non-Safety-Related

PAGE 4 OF 67

Client	Prepared by	Date
Project	Reviewed by	Date
Proj. No.	Approved by	Date
Equip. No.		

A response spectra analysis based on the factored global matrices saved on permanent file during the eigen-frequency analysis was performed. The response spectra used are the Required Response Spectra for Zimmer, Auxiliary Building Elevation 546'-0". Damping ratios of 1% for OBE and 2% for SSE were used in the response spectra analysis. The maximum plate stress is 3940 psi. The beam stresses are low and well within allowable value of 18 ksi. The maximum acceleration is 2.2g along the vertical axis occurring at a top panel location.

Client	Prepared by	Date
Project	Reviewed by	Date
Proj. No.	Approved by	Date
Equip. No.		

Analysis

A three dimensional finite element model was used in the analysis. The model consisted of 121 nodes, 90 plate elements and 152 beam elements. The input to the response spectra analysis consist of acceleration-spectra - "Envelope of Soil-Structure Interaction Response Spectra for Aux. Bldg. Elev. 546-0" (ERS)

An eigen-frequency analysis was performed and a response spectra analysis based on the eigen analysis was performed.

Bounding stresses for both plate and beam elements were computed. The stresses were very small. The Maximum acceleration value of 2.2g in the vertical direction.

The finite element model and nodal co-ordinates as well as all information required to generate the model are described.



Appendix A contains all the input data - nodal coordinates, beam and plate data.

Appendix B contains beam property data

Appendix C contains stress calculation. This appendix verifies that the structural integrity of the panel.

Appendix D contains the Required response spectra

Appendix E Instrument Weights/Masses



DYNAMIC ANALYSIS OF MAIN CONTROL BOARDS FOR ZIMMER.
 SCALE: 1./9.840

FINITE ELEMENT MODEL GE PANEL 1113-P601

Client	Prepared by	Date
Project	Reviewed by	Date
Proj. No.	Approved by	Date
Equip. No.		

Nodal Masses & Moments of Inertia

Revised nodal masses and moments of Inertia corresponding to the new instrument location as well as new instruments are incorporated in the model. A list of instruments including weight and size are stated in Appendix E. The changed nodal masses as well as mass-locations necessitated this requalification.

Eigen-frequency Analysis

A total of 16 frequencies were determined ranging from 5.75 Hz to 35.04 Hz.

Mode Number Frequency (Hz.)

1	5.57
2	7.27
3	9.86
4	13.25
5	16.55
6	18.20
7	19.56
8	19.68
9	25.75
10	26.76
11	26.92
12	28.73
13	29.20
14	30.22
15	31.3
16	35.04

Client	Prepared by	Date
Project	Reviewed by	Date
Proj. No.	Approved by	Date
Equip. No.		

Modal Participation Factors are:

MODAL PARTICIPATION FACTORS SAVED ON UNIT 32

MODE	X-DIRECTION	Y-DIRECTION	Z-DIRECTION
1	-.94823-04	-.90543-03	.74022+00
2	.31725-03	-.50837-03	.29363+00
3	-.98245-03	-.29933-03	.22507+00
4	.15963-02	-.22376-03	-.12644-01
5	-.34777-02	-.53128-03	.75019-01
6	.81082-03	-.46108-03	.14566-01
7	-.31188-03	-.15199-03	.10819-02
8	.31566-02	-.16561-02	.14429+00
9	-.43097-02	.18019-03	-.25041-02
10	.14840-04	-.54360-03	.64574-01

3306

76

11	.10866-01	.12614-01	-.11036+01
12	-.12516-02	-.77451-04	.11284-02
13	.32869-01	.12339-02	-.15923+00
14	.24077-02	-.19632-03	.57147-02
15	.46922-02	.48123-03	-.19578-02
16	.14726+00	-.32935-02	.30068-01

The maximum acceleration occurs at node L+; 2.2g
in the vertical direction.

Client	Prepared by	Date
Project	Reviewed by	Date
Proj. No.	Approved by	Date
Equip. No.		

Response Spectra Analysis

Applicable Response Spectra are shown in Appendix B.
Appendix C contains the stress calculations.

2% SSE Response Spectra curves

En 1% OBE Response Spectra curves

at elevation 546'-0" are used.

Upper bound plate stress is 3940 psi
Beam stresses are all well below the 18,000
psi allowable value.



Calcs. For	
Safety-Related	Non-Safety-Related

Client	Prepared by	Date
Project	Reviewed by	Date
Proj. No.	Approved by	Date
Equip. No.		

APPENDIX - A -

INPUT DATA

DYNAMIC ANALYSIS OF MAIN CONTROL BOARDS FOR ZIMMER.

CONTROL INFORMATION

NUMBER OF NODAL POINTS = 121
 NUMBER OF ELEMENT TYPES = 2
 NUMBER OF LOAD CASES = 0
 NUMBER OF FREQUENCIES = 36
 ANALYSIS CODE (NDYN) = 1
 EQ.0, STATIC
 EQ.1, MODAL EXTRACTION
 EQ.2, FORCED RESPONSE
 EQ.3, RESPONSE SPECTRUM
 EQ.4, DIRECT INTEGRATION
 SOLUTION MODE (MODEX) = 0
 EQ.0, EXECUTION
 EQ.1, DATA CHECK
 NUMBER OF SUBSPACE
 ITERATION VECTORS (NAD) = 0
 EQUATIONS PER BLOCK = 0
 SAVE FLAG (NDYN.EQ.4)
 (NSVD,NSVV,NSVA,NSVS) = 0
 RESOLUTION MODE = 0
 EQ.0, NO SAVING
 EQ.1, SAVING
 EQ.2, USING INFO. SAVED

ALLOWABLE CORE STORAGE = 65000

OPTION FOR RETAINING GEOMETRIC DATA, (0=NO, 1=YES) = 1
 OPTION TO SAVE FILE-32 OF MODE SHAPE + FREQ (0=NO, 1=YES) = 1
 SAVING FILE-14 FOR STATIC OR RESP SPEC (0=NO, 1=YES) = 0
 OPTION FOR PERFORMING EQUILIBRIUM CHECK, (0=YES, 1=NO) = 0
 OPTION FOR PRINTING OUT FINAL LOAD VECTOR, (0=NO, 1=YES) = 0
 PRINTING OUT RESIDUAL FORCE AT EACH NODE, (0=NO, 1=YES) = 0
 TOLERANCE OF RESIDUAL FORCE/MAX. NODAL FORCE OR MOMENT = .00000
 NUMBER OF ITERATIONS FOR NON-LINEAR BOUNDARY ELEMENT = 100
 TOLERANCE FOR NON-LINEAR BOUNDARY ELEMENTS CONVERGENCY = .00100

NODAL POINT INPUT DATA

NODE NUMBER	BOUNDARY CONDITION CODES						NODAL POINT COORDINATES			T	
	X	Y	Z	XX	YY	ZZ	X	Y	Z		
1	0	0	0	0	0	0	.000	132.000	36.000	0	.000
2	0	0	0	0	0	0	.000	114.000	36.000	0	.000
3	0	0	0	0	0	0	.000	90.000	36.000	0	.000
4	0	0	0	0	0	0	.000	72.000	36.000	0	.000
5	0	0	0	0	0	0	.000	56.000	36.000	0	.000
6	0	0	0	0	0	0	.000	47.000	36.000	0	.000
7	0	0	0	0	0	0	.000	32.000	36.000	0	.000
8	0	0	0	0	0	0	.000	29.000	50.700	0	.000
9	0	0	0	0	0	0	.000	26.000	65.400	0	.000
10	0	0	0	0	0	0	.000	8.000	61.660	0	.000
11	1	1	1	1	1	1	.000	.000	60.000	0	.000

PAGE 11 OF 67

CALC. NO: CDD-002323
 REV: 00 DATE: 06/03/82
 PROJECT NUMBER: 4130-15

SARGER LUNDY

ENGINEER

SARGENT & LUNDY

ANNOUNCEMENT

15

SARGE LUNDY

[illegible]

GENERATED NODAL DATA

NODE NUMBER	BOUNDARY X	BOUNDARY Y	BOUNDARY Z	CONDITION XX	CONDITION YY	CONDITION ZZ
----------------	---------------	---------------	---------------	-----------------	-----------------	-----------------

NODAL POINT COORDINATES

1

1	132.000	36.000	.000
2	114.000	36.000	.000
3	90.000	36.000	.000
4	72.000	36.000	.000
5	56.000	36.000	.000
6	47.000	36.000	.000
7	32.000	36.000	.000
8	29.000	50.700	.000
9	26.000	65.400	.000
10	8.000	61.660	.000
11	.000	60.000	.000
12	.000	36.000	.000
13	8.000	36.000	.000
14	.000	.000	.000
15	8.000	.000	.000
16	47.000	.000	.000
17	56.000	.000	.000
18	90.000	.000	.000
19	132.000	36.000	.000
20	114.000	36.000	.000
21	90.000	36.000	.000
22	72.000	36.000	.000
23	56.000	36.000	.000
24	47.000	36.000	.000
25	32.000	36.000	.000
26	29.000	50.700	.000
27	26.000	65.400	.000
28	8.000	60.000	.000
29	.000	36.000	.000
30	8.000	.000	.000
31	47.000	.000	.000
32	56.000	.000	.000
33	90.000	.000	.000
34	132.000	36.000	.000
35	114.000	36.000	.000
36	90.000	36.000	.000
37	72.000	36.000	.000
38	56.000	36.000	.000
39	47.000	36.000	.000
40	32.000	36.000	.000
41	29.000	50.700	.000
42	26.000	65.400	.000
43	8.000	60.000	.000
44	.000	36.000	.000
45	8.000	.000	.000
46	47.000	.000	.000
47	56.000	.000	.000
48	90.000	.000	.000
49	132.000	36.000	.000
50	114.000	36.000	.000
51	90.000	36.000	.000
52	72.000	36.000	.000
53	56.000	36.000	.000
54	47.000	36.000	.000
55	32.000	36.000	.000
56	29.000	50.700	.000
57	26.000	65.400	.000
58	8.000	61.660	.000
	.000	60.000	.000
	.000	.000	.000
	8.000	.000	.000
	47.000	.000	.000
	90.000	.000	.000

SARGEI LUNDY

SARGEI LUNDY

SARGEI LUNDY

EQUATION NUMBERS

* INDICATES SPECIAL BOUND. COND., READ NODAL INPUT DATA FOR MORE INFORMATIONS.

EQUATION NUMBERS

N	-X	Y	Z	XX	YY	ZZ
1	1	2	3	4	5	6
2	7	8	9	10	11	12
3	13	14	15	16	17	18
4	19	20	21	22	23	24
5	25	26	27	28	29	30
6	31	32	33	34	35	36
7	37	38	39	40	41	42
8	43	44	45	46	47	48
9	49	50	51	52	53	54
10	55	56	57	58	59	60
11	0	0	0	0	0	0
12	0	0	0	0	0	0
13	61	62	63	64	65	66
14	0	0	0	0	0	0
15	67	68	69	70	71	72
16	73	74	75	76	77	78
17	79	80	81	82	83	84
18	85	86	87	88	89	90
19	91	92	93	94	95	96
20	97	98	99	100	101	0
21	102	103	104	105	106	107
22	108	109	110	111	112	113
23	114	115	116	117	118	119
24	120	121	122	123	124	125
25	126	127	128	129	130	131
26	132	133	134	135	136	137
27	138	139	140	141	142	143
28	144	145	146	147	148	149
29	150	151	152	153	154	155
30	156	157	158	159	160	161
31	162	163	164	165	166	167
32	168	169	170	171	172	173
33	174	175	176	177	178	179
34	180	181	182	183	184	185
35	186	187	188	189	190	191
36	192	193	194	195	196	197
37	198	199	200	201	202	203
38	0	0	0	0	0	0
39	0	0	0	0	0	0
40	0	0	0	0	0	0
41	204	205	206	207	208	209
42	210	211	212	213	214	215
43	216	217	218	219	220	221
44	222	223	224	225	226	227
45	228	229	230	231	232	0
46	232	233	234	235	236	237
47	239	240	241	242	243	244
48	245	246	247	248	249	250

49	251	252	253	254	255	256
50	257	258	259	260	261	262
51	263	264	265	266	267	268
52	269	270	271	272	273	274
53	275	276	277	278	279	280
54	0	0	0	0	0	0
55	0	0	0	0	0	0
56	281	282	283	284	285	286
57	287	288	289	290	291	292
58	293	294	295	296	297	298
59	299	300	301	302	303	304
60	305	306	307	308	309	310
61	311	312	313	314	315	316
62	317	318	319	320	321	322
63	323	324	325	326	327	328
64	329	330	331	332	333	334
65	335	336	337	338	339	340
66	341	342	343	344	345	346
67	347	348	349	350	351	352
68	0	0	0	0	0	0
69	0	0	0	0	0	0
70	0	0	0	0	0	0
71	353	354	355	356	357	358
72	359	360	361	362	363	364
73	365	366	367	368	369	370
74	371	372	373	374	375	376
75	377	378	379	380	381	382
76	383	384	385	386	387	388
77	389	390	391	392	393	394
78	395	396	397	398	399	400
79	401	402	403	404	405	406
80	407	408	409	410	411	412
81	413	414	415	416	417	418
82	419	420	421	422	423	424
83	425	426	427	428	429	430
84	0	0	0	0	0	0
85	0	0	0	0	0	0
86	431	432	433	434	435	436
87	437	438	439	440	441	442
88	443	444	445	446	447	448
89	449	450	451	452	453	454
90	455	456	457	458	459	460
91	461	462	463	464	465	466
92	467	468	469	470	471	472
93	473	474	475	476	477	478
94	479	480	481	482	483	484
95	485	486	487	488	489	490
96	491	492	493	494	495	496
97	497	498	499	500	501	502
98	503	504	505	506	507	508
99	0	0	0	0	0	0
100	0	0	0	0	0	0
101	509	510	511	512	513	514
102	515	516	517	518	519	520
103	521	522	523	524	525	526
104	527	528	529	530	531	532
105	533	534	535	536	537	538
106	539	540	541	542	543	544

107	545	546	547	548	549	550
108	551	552	553	554	555	556
109	557	558	559	560	561	562
110	563	564	565	566	567	568
111	569	570	571	572	573	574
112	575	576	577	578	579	580
113	581	582	583	584	585	586
114	0	0	0	0	0	0
115	0	0	0	0	0	0
116	587	588	589	590	591	592
117	0	0	0	0	0	0
118	593	594	595	596	597	598
119	599	600	601	602	603	604
120	605	606	607	608	609	610
121	611	612	613	614	615	616

CALC. NO: CQD-C02323
 REV: 00 DATE: 06/03/82
 PROJECT NUMBER: 4130-15

PAGE 18 OF 67

3 / D BEAM ELEMENTS

NUMBER OF BEAMS	■	152
NUMBER OF GEOMETRIC PROPERTY SETS	■	26
NUMBER OF FIXED END FORCE SETS	■	0
NUMBER OF MATERIALS	■	1
NUMBER OF UNIFORM LOADS	■	0
NUMBER OF DAMPING PROPERTY SETS	■	0

CALC. NO: C00-002323
REV: 00 DATE: 06/03/82
PROJECT NUMBER: 4130-15
PAGE 19 OF 67

SARGEN LUNDY
ENGINEERS

MATERIAL 1 YOUNG'S MODULUS 29000000. POISSON'S RATIO .30000 WEIGHT DENSITY .28300 MASS DENSITY .00073 THERMAL COEFFICIENT .000000000

BEAM GEOMETRIC PROPERTIES

SECTION NUMBER	AXIAL AREA A(1)	SHEAR AREA A(2)	SHEAR AREA A(3)	TORSION J(1)	INERTIA I(2)	INERTIA I(3)	ECCENTRICITY	LENGTH FACTOR
1	.1000+01	.0000	.0000	.2000-01	.1333+01	.5200-02	.0000	.0000
2	.1500+01	.0000	.0000	.3125-01	.4500+01	.7800-02	.0000	.0000
3	.2250+01	.0000	.0000	.2637-01	.2700+02	.6590-02	.0000	.0000
4	.2300+00	.0000	.0000	.2320-03	.2200-01	.8500-01	.0000	.0000
5	.1080+01	.0000	.0000	.1336-01	.1830+00	.3140+00	.0000	.0000
6	.6200+00	.0000	.0000	.1290-01	.1300-01	.2700+00	.0000	.0000
7	.1190+01	.0000	.0000	.2480-01	.1090+01	.3920+00	.0000	.0000
8	.6880+00	.0000	.0000	.1433-01	.1390+00	.1390+00	.0000	.0000
9	.1360+01	.0000	.0000	.1450-01	.5809+01	.7700-01	.0000	.0000
10	.6840+00	.0000	.0000	.7300-02	.4320-01	.6146+00	.0000	.0000
11	.2300+01	.0000	.0000	.2230-01	.2872+02	.1200+00	.0000	.0000
12	.1576+01	.0000	.0000	.1460-01	.7159+01	.1130+00	.0000	.0000
13	.4600+00	.0000	.0000	.4640-03	.4400-01	.1700+00	.0000	.0000
14	.9200+00	.0000	.0000	.9280-03	.8800-01	.3400+00	.0000	.0000
15	.2138+01	.0000	.0000	.4100-01	.1239+01	.1511+01	.0000	.0000
16	.1000+01	.0000	.0000	.2000-01	.5200-02	.1333+01	.0000	.0000
17	.7500+00	.0000	.0000	.1563-01	.5625+00	.3900-02	.0000	.0000
18	.3250+01	.0000	.0000	.4637-01	.2833+02	.1179-01	.0000	.0000
19	.2720+01	.0000	.0000	.2900-01	.1162+02	.1540+00	.0000	.0000
20	.1368+01	.0000	.0000	.1460-01	.8640-01	.1229+01	.0000	.0000
21	.2500+01	.0000	.0000	.5125-01	.5833+01	.1300-01	.0000	.0000
22	.9380+00	.0000	.0000	.1954-01	.3480+00	.3480+00	.0000	.0000
23	.1240+01	.0000	.0000	.2580-01	.2600-01	.5400+00	.0000	.0000
24	.1700+01	.0000	.0000	.1465+00	.1960+00	.5840+00	.0000	.0000
25	.4600+00	.0000	.0000	.4640-03	.1080+00	.1700+00	.0000	.0000
26	.1876+01	.0000	.0000	.3908-01	.6960+00	.6960+00	.0000	.0000

ELEMENT LOAD MULTIPLIERS

	A	B	C	D
X-DIR	.000000	.000000	.000000	.000000
Y-DIR	.000000	.000000	.000000	.000000
Z-DIR	.000000	.000000	.000000	.000000
TEMP	.000000	.000000	.000000	.000000

[illegible]

SARGER LUNDY

111	54	53	50
112	53	52	50
113	68	67	65
114	84	83	80
115	83	82	80
116	99	98	95
117	98	97	95
118	114	113	110
119	113	112	110
120	15	13	14
121	13	10	14
122	16	6	14
123	18	3	14
124	28	21	18
125	43	31	18
126	56	53	55
127	57	49	55
128	58	46	18
129	73	61	18
130	86	83	85
131	87	79	85
132	88	76	18
133	101	98	100
134	102	94	100
135	103	91	18
136	118	116	117
137	118	113	117
138	119	109	117
139	121	106	117
140	7	8	11
141	8	9	11
142	25	26	7
143	26	27	7
144	50	51	7
145	51	52	7
146	80	81	7
147	81	82	7
148	95	96	7
149	96	97	7
150	110	111	117
151	111	112	117
152	102	103	99

THIN PLATE/SHELL ELEMENTS

ELEMENT TYPE = 6
 NUMBER OF ELEMENTS = 90
 NUMBER OF MATERIALS = 1
 NUMBER OF CAMPINGS = 0

MATERIAL PROPERTY TABLE

MATL. NO.	MASS DENSITY	THERMAL EXP. COEFF.			ELASTIC CONSTANTS				C(YS)	G(XY)	E	POISSON RATIO
		X	Y	Z	C(XX)	C(XY)	C(XS)	C(YZ)				
1	.001	.00	.00	.0	31868131.25	9560439.37		.0031868131.25		.0011153846.1229000000.00		.300

CALC. NO: CND-002323
 REV: 00 DATE: 06/03/82
 PROJECT NUMBER: 4130-15

PAGE 24 OF 67

SARGEI LUNDY

ELEMENT LOAD CASE MULTIPLIERS					
ELEMENT LOAD CASE NUMBER	PRESSURE	THERMAL EFFECTS	X-ACCELERATION	Y-ACCELERATION	Z-ACCELERATION
1	.000	.000	.000	.000	.000
2	.000	.000	.000	.000	.000
3	.000	.000	.000	.000	.000
4	.000	.000	.000	.000	.000

THIN PLATE/SHELL ELEMENT DATA											MATERIAL NUMBER	AVERAGE THICKNESS	NORMAL PRESSURE	TEMPERATURE DIFFERENCE	THERMAL GRADIENT	DAMPING	BAND
ELEMENT NUMBER	NODE-I	NODE-J	NODE-K	NODE-L	NODE-O												
1	1	2	20	19	0	1	.1250	.0	.00	.000	0	101					
2	2	3	21	20	0	1	.1250	.0	.00	.000	0	101					
3	3	4	22	21	0	1	.1790	.0	.00	.000	0	101					
4	4	5	23	22	0	1	.1790	.0	.00	.000	0	101					
5	5	6	24	23	0	1	.1790	.0	.00	.000	0	101					
6	6	7	25	24	0	1	.1790	.0	.00	.000	0	101					
7	7	8	26	25	0	1	.1790	.0	.00	.000	0	101					
8	8	9	27	26	0	1	.1790	.0	.00	.000	0	101					
9	19	20	30	29	0	1	.1250	.0	.00	.000	0	71					
10	20	21	31	30	0	1	.1250	.0	.00	.000	0	71					
11	21	22	32	31	0	1	.1790	.0	.00	.000	0	72					
12	22	23	33	32	0	1	.1790	.0	.00	.000	0	72					
13	23	24	34	33	0	1	.1790	.0	.00	.000	0	72					
14	24	25	35	34	0	1	.1790	.0	.00	.000	0	72					
15	25	26	36	35	0	1	.1790	.0	.00	.000	0	72					
16	26	27	37	36	0	1	.1790	.0	.00	.000	0	72					
17	29	30	45	44	0	1	.1250	.0	.00	.000	0	83					
18	30	31	46	45	0	1	.1250	.0	.00	.000	0	83					
19	31	32	47	46	0	1	.1790	.0	.00	.000	0	83					
20	32	33	48	47	0	1	.1790	.0	.00	.000	0	83					
21	33	34	49	48	0	1	.1790	.0	.00	.000	0	83					
22	34	35	50	49	0	1	.1790	.0	.00	.000	0	83					
23	35	36	51	50	0	1	.1790	.0	.00	.000	0	83					
24	36	37	52	51	0	1	.1790	.0	.00	.000	0	83					
25	44	45	60	59	0	1	.1250	.0	.00	.000	0	89					
26	45	46	61	60	0	1	.1250	.0	.00	.000	0	89					
27	46	47	62	61	0	1	.1790	.0	.00	.000	0	90					
28	47	48	63	62	0	1	.1790	.0	.00	.000	0	90					
29	48	49	64	63	0	1	.1790	.0	.00	.000	0	90					
30	49	50	65	64	0	1	.1790	.0	.00	.000	0	90					
31	50	51	66	65	0	1	.1790	.0	.00	.000	0	90					
32	51	52	67	66	0	1	.1790	.0	.00	.000	0	90					
33	59	60	75	74	0	1	.1250	.0	.00	.000	0	84					
34	60	61	76	75	0	1	.1250	.0	.00	.000	0	84					
35	61	62	77	76	0	1	.1790	.0	.00	.000	0	84					
36	62	63	78	77	0	1	.1790	.0	.00	.000	0	84					
37	63	64	79	78	0	1	.1790	.0	.00	.000	0	84					
38	64	65	80	79	0	1	.1790	.0	.00	.000	0	84					
39	65	66	81	80	0	1	.1790	.0	.00	.000	0	84					
40	66	67	82	81	0	1	.1790	.0	.00	.000	0	84					
41	74	75	90	89	0	1	.1250	.0	.00	.000	0	90					
42	75	76	91	90	0	1	.1250	.0	.00	.000	0	90					
43	76	77	92	91	0	1	.1790	.0	.00	.000	0	90					
44	77	78	93	92	0	1	.1790	.0	.00	.000	0	90					
45	78	79	94	93	0	1	.1790	.0	.00	.000	0	90					
46	79	80	95	94	0	1	.1790	.0	.00	.000	0	90					
47	80	81	96	95	0	1	.1790	.0	.00	.000	0	90					
48	81	82	97	96	0	1	.1790	.0	.00	.000	0	90					
49	89	90	105	104	0	1	.1250	.0	.00	.000	0	90					
50	90	91	106	105	0	1	.1250	.0	.00	.000	0	90					
51	91	92	107	106	0	1	.1790	.0	.00	.000	0	90					
52	92	93	108	107	0	1	.1790	.0	.00	.000	0	90					
53	93	94	109	108	0	1	.1790	.0	.00	.000	0	90					



Calcs. For		CALC. NO: CQD-002323
		REV: 00 DATE: 06/03/82
		PROJECT NUMBER: 4130-15
Safety-Related	Non-Safety-Related	

PAGE 28 OF 67

Client	Prepared by	Date
Project	Reviewed by	Date
Proj. No.	Approved by	Date
Equip. No.		

APPENDIX - B


BEAM PROPERTIES

(6)

Client	Prepared by	Date
Project	Reviewed by	Date
Proj. No.	Approved by	Date
Equip. No.		

Beam Type 1

$\frac{1}{4}" \times 4"$ Flat Stiffener




$$A = 1.04 \text{ in}^2$$

$$J_1 = 0.02 \text{ in}^4$$

$$I_2 = 1.33 \text{ in}^4$$

$$I_3 = 0.0052 \text{ in}^4$$

Beam Type 2



$$A = 1.5 \text{ in}^2$$


$$J_1 = 0.03125 \text{ in}^4$$

$$I_2 = 4.5 \text{ in}^4$$

$$I_3 = 0.0078 \text{ in}^4$$

$\frac{1}{4}" \times 6"$ Stiffener

Beam Type 3



$$A = 2.25 \text{ in}^2$$

$$J_1 = 0.02637 \text{ in}^4$$

$$I_2 = 27 \text{ in}^4$$

$$I_3 = 0.00659 \text{ in}^4$$

Client	Prepared by	Date
Project	Reviewed by	Date
Proj. No.	Approved by	Date
Equip. No.		

Beam Type ④

P - 4000 Channel-Unistrut (.81" x 1.62")

$$A = .23 \text{ in}^2$$

$$J = 0.000232 \text{ in}^4$$

$$I_2 = 0.022 \text{ in}^4$$

$$I_3 = 0.085 \text{ in}^4$$

Beam Type ⑤

Linear Combination of two type ④ & one type ⑥ Brs.

$$A = (2(.23) + .62) = 1.08 \text{ in}^2$$


$$I_2 = 2I_{3 \text{ TYP 4}} + I_{2 \text{ TYP 6}} = [0.013 + 2(0.085)] = 0.183 \text{ in}^4$$

$$I_3 = I_{3 \text{ TYP 6}} + 2I_{2 \text{ TYP 4}} = [0.27 + 2(0.022)] = 0.314 \text{ in}^4$$

$$J_1 = J_{1 \text{ TYP 6}} + 2J_{1 \text{ TYP 4}} = [0.0129 + 2(0.000232)] = 0.013364 \text{ in}^4$$

Beam Type ⑥

AISI M1020 Channel 2" x .62" x .25"



$$A = 0.62 \text{ in}^2$$


$$I_2 = 0.031 \text{ in}^4$$

$$I_3 = 0.27 \text{ in}^4$$

$$J_1 = 0.0129 \text{ in}^4$$

Beam Type ⑦

1/4" x 2" x 3"



$$A = 1.19 \text{ in}^2$$

$$I_2 = 1.09 \text{ in}^4$$


$$I_3 = 0.392 \text{ in}^4$$

$$J_1 = 0.0248 \text{ in}^4$$

Client	Prepared by	Date
Project	Reviewed by	Date
Proj. No.	Approved by	Date
Equip. No.		

Beam Type (8)

$\frac{1}{4}" \times 2" \times 2"$




$$A = .938 \text{ in}^2$$

$$J_1 = 0.0195 \text{ in}^4$$

$$I_3 = I_2 = 0.348 \text{ in}^4$$

Beam Type (9)

Channel $6" \times 1" \times .179"$



$$A = 1.36 \text{ in}^2$$


$$I_2 = 5.809 \text{ in}^4$$

$$I_3 = 0.077 \text{ in}^4$$

$$J_1 = 0.0145 \text{ in}^4$$

Beam Type (10)

$3" \times 1" \times .179"$ \angle 1c



$$A = .684 \text{ in}^2$$


$$I_2 = 0.432 \text{ in}^4$$

$$I_3 = 0.614 \text{ in}^4$$

$$J_1 = 0.0073 \text{ in}^4$$

Beam Type (12)

Two P-6000 Unistruts
attached to a $6" \times 1" \times .179"$ channel.



$$A = 1.576 \text{ in}^2$$

$$I_2 = 7.159 \text{ in}^4$$

$$I_3 = 0.113 \text{ in}^4$$

$$J_1 = 0.0146 \text{ in}^4$$

Client

Prepared by

Date

Project

Reviewed by

Date


Proj. No.

Equip. No.

Approved by

Date

Beam Type (II)

2 P-6000 unistruts attached to
a 10.5' x 1" x 0.179" channel.

$$A = 2.31 \text{ in}^2$$

$$J_1 = 0.0223 \text{ in}^4$$

$$I_2 = 28.724 \text{ in}^4$$

$$I_3 = 0.12 \text{ in}^4$$

Beam Type (III)

2 P-4000 channel unistruts.

$$A = 0.46 \text{ in}^2$$

$$J_1 = 0.000464 \text{ in}^4$$

$$I_2 = 0.044 \text{ in}^4$$

$$I_3 = 0.17 \text{ in}^4$$

Beam Type (IV)

4 P-4000 channel unistruts.


$$A = 0.92 \text{ in}^2$$

$$J_1 = 0.000928 \text{ in}^4$$

$$I_2 = 0.088 \text{ in}^4$$

$$I_3 = 0.34 \text{ in}^4$$

Beam Type (V) Combination of one 2" x 2" x 1/4"

on one 3" x 2" x 1/4" plate
with a 2" x 0.179" thick
cover plate

$$A = 2.483 \text{ in}^2$$


$$I_2 = 1.539 \text{ in}^4$$

$$I_3 = 1.811 \text{ in}^4$$

$$J_1 = 0.04818 \text{ in}^4$$

Client	Prepared by	Date
Project	Reviewed by	Date
Proj. No.	Approved by	Date
Equip. No.		

Beam Type (16)

 $\frac{1}{4}" \times 4"$ Flat stiffener


$$A = 1.0 \text{ in}^2$$

$$J_1 = 0.02 \text{ in}^4$$

$$I_2 = 0.0052 \text{ in}^4$$

$$I_3 = 1.333 \text{ in}^4$$

Beam Type (17)

 $\frac{1}{4}" \times 3"$ Flat stiffener

$$A = 0.75 \text{ in}^2$$

$$J_1 = 0.015625 \text{ in}^4$$

$$I_2 = 0.5625 \text{ in}^4$$

$$I_3 = 0.0039 \text{ in}^4$$

Beam Type (18)

Linear combination of (1) beam type
En (3) beam type

$$A = 3.25 \text{ in}^2$$

$$J_1 = 0.04637 \text{ in}^4$$

$$I_2 = 28.33 \text{ in}^4$$

$$I_3 = 0.01179 \text{ in}^4$$

SARGENT LUNDY

ENGINEERS
CHICAGO

Calcs. For

CALC. NO: CQD-002323
REV: 00 DATE: 06/03/82
PROJECT NUMBER: 4130-15

Safety-Related

Non-Safety-Related

PAGE 34 OF 67

Client	Prepared by	Date
Project	Reviewed by	Date
Proj. No.	Approved by	Date
Equip. No.		

Beam Type (19)

Linear combination of 2 type 9 beams

$$A = 2.72 \text{ in}^2$$

$$I_1 = 0.009 \text{ in}^4$$

$$I_2 = 11.62 \text{ in}^4$$

$$I_3 = 0.154 \text{ in}^4$$

Beam Type (20)

Linear Combination of 2 type 11 beams

$$A = 1.386 \text{ in}^2$$

$$I_1 = 0.0146 \text{ in}^4$$

$$I_2 = 0.0864 \text{ in}^4$$

$$I_3 = 1.229 \text{ in}^4$$

Beam Type (21)

Linear combination of 1-type ①
and 2-type ② beams

$$A = 2.5 \text{ in}^2$$

$$I_1 = 0.05125 \text{ in}^4$$

$$I_2 = 5.833 \text{ in}^4$$

$$I_3 = 0.013 \text{ in}^4$$

Beam Type (22)

2" x 2" x 1/4" L

$$A = .938 \text{ in}^2$$

$$I_1 = 0.01934 \text{ in}^4$$

$$I_2 = I_3 = 0.342 \text{ in}^4$$



Calcs. For		CALC. NO: CQD-002323
		REV: 00 DATE: 06/03/82
		PROJECT NUMBER: 4130-15
Safety-Related	Non-Safety-Relat	

PAGE 36 OF 67

Client	Prepared by	Date
Project	Reviewed by	Date
Proj. No.	Approved by	Date
Equip. No.		

APPENDIX - C

12

Client	Prepared by	Date
Project	Reviewed by	Date
Proj. No.	Approved by	Date
Equip. No.		

Stress Computation:

Beams

Bounding force values are written below for each beam No. Since the force resultants are small, an allowable safe value of 18ksi is assumed and based on this value and the beam section modulus permissible values of allowable moments are computed. These values are compared with the actual values obtained from the response spectra. For beams with larger section properties or carrying less load than lighter beams separate calculations have not been performed.

The results from this analysis indicates that the beams are lightly stressed for both OBE & SSE cases. Stresses due to static load are negligibly small

Plates

Bounding value of the membrane stress and bending moment are used to verify that the plates are lightly stressed. A max. bounding stress of 3490 psi was computed.

Client	Prepared by	Date
Project	Reviewed by	Date
Proj. No.	Approved by	Date
Equip. No.		

(I)

Beam Elements: Groups

Group # 1 (Max values)

Beam

Units: P1 - lbs

V2 - lbs

V3 - lbs

P1 ≤ 2530

M2 - in lb

M3 - in lb

V2 ≤ 10

T1 - in lb

V3 ≤ 35

M2 ≤ 540

M3 ≤ 10

T1 ≤ 20

Group # 2

M2 ≤ 110

Group # 3.

M2 = 2040

Group # 4

M2 ≤ 10

SARGENT LUNDY

ENGINEERS
CHICAGO

Calcs. For

CALC. NO: CQD-002323
REV: 00 DATE: 06/03/82
PROJECT NUMBER: 4130-15

Safety-Related

Non-Safety-Related

PAGE 39 OF 67

Client	Prepared by	Date
Project	Reviewed by	Date
Proj. No.	Approved by	Date
Equip. No.		

Group # 5 -

Group # 6

$M2 \leq \text{320}$

$M3 \leq 160$

Group # 7

$M2 \leq \text{2205}$

$M3 \leq 25$

Group # 8

$M2 \leq \text{1069}$

$TL \leq 40.$

Group # 9

$M2 \leq 25$

Group # 10

$M3 \leq 300$

Group # 11

$M2 \leq 40$

$PI \leq 60$

SARGENT LUNDY

ENGINEERS
CHICAGO

Calcs. For

Safety-Related

Non-Safety-Related

PAGE 40 OF 67

Client

Project

Proj. No.

Equip. No.

Prepared by

Date

Reviewed by

Date

Approved by

Date

Group # 12

$P1 \leq 120$

$M2 \leq 20$

$M3 \leq 40$

Group # 13

$M3 \leq 50$

$M2 \leq 50$

Group # 14

$M3 = 75$

$M2 = 13$

Group # 15

$T1 \leq 40$

$M3 \leq 10$

$M2 \leq 500$

Group 18

$M2 = 2500$

Group 19

$M2 = 65$

$M3 \leq 10$

SARGENT LUNDYENGINEERS
CHICAGO

Calcs. For

CALC. NO: CQD-002323
REV: 00 DATE: 06/03/82
PROJECT NUMBER: 4130-15

Safety-Related

Non-Safety-Related

PAGE 41 OF 67

Client

Prepared by

Date

Project

Reviewed by

Date

Proj. No.

Equip. No.

Approved by

Date

Group # 20

$$M2 \leq 10$$

$$M3 \leq 500$$

Group # 22

$$M2 = 26$$

$$M3 = \cancel{41} 282$$

Group 23

$$M2 < 30$$

$$M3 \leq 30$$

Group 24

$$M2 = \cancel{52} 102.6$$

$$M3 = 380$$

Group 25

$$M2 \leq 25$$

$$M3 \leq 25$$

Group 26

$$M2 = \cancel{367} 380$$

$$M3 = 10$$

Client	Prepared by	Date
Project	Reviewed by	Date
Proj. No.	Approved by	Date
Equip. No.		

Z VALUES FOR BEAMS.

(3)

(2)

1	10.667 0.042	0.2352 10.67
2	0.062	36
3	0.0071	216
4	0.105	0.05
5	The Beam consists of 2 type 4 in $1\frac{1}{4} \times 2 \times 3\frac{3}{4}$	
6	.27/(1)	0.013/.12
7	.392/	1.09/
8	.348/	.3-8/
9	0.077/.09	5.809/3
10	.432/1.5	.0432/.09
11	2 uni-truts in $10.5" \times 1" \times .179"$ channel. (4)	
12	Default (4)	
13	Default (4)	
14	Default (4)	
15	Default (7) Combination of $3 \times 2 \times 1\frac{1}{4}$ in $2 \times 3 \times 1\frac{1}{4}$	
16	}	
17		
18	Default (1)	
19	Default (9)	
20	Default (11) / (4)	
21	} end	
22	Def $\equiv 8$	
23	Default (6)	
24	Default (6)	
25	P4001 Uni-trut channel.	
26	Default (8)	

SARGENT LUNDYENGINEERS
CHICAGO

Calcs. For

CALC. NO: CQD-002323
REV: 00 DATE: 06/03/82
PROJECT NUMBER: 4130-15

Safety-Related

Non-Safety-Rel.

PAGE 44 OF 67

Client	Prepared by	Date
Project	Reviewed by	Date
Proj. No.	Approved by	Date
Equip. No.		

Beam Group # 6

$$P1 \leq 50$$

$$V2 \leq 1$$

$$V3 \leq 20$$

$$M2 \leq 420$$

$$M3 \leq 173$$

Beam Group # 9

$$P1 \leq 36$$

$$V2 \leq 1$$

$$V3 \leq 5$$

$$M2 \leq 36$$

$$M3 \leq 10$$

$$T1 \leq .01$$

Beam Group # 7

$$P1 \leq 20$$

$$V2 \leq 10$$

$$V3 \leq 40$$

$$M2 \leq 2930$$

$$M3 \leq 371$$

$$T1 \leq 26$$

Beam Group # 10

$$P1 \leq 20$$

$$V2 \leq 102$$

$$V3 \leq 10$$

$$M2 \leq 10$$

$$M3 \leq 407$$

Beam Group # 8

$$P1 \leq 10$$

$$V2 \leq 15$$

$$V3 \leq 15$$

$$T1 \leq 40$$

$$M2 \leq 989/1069$$

$$M3 \leq 1741$$

Beam Group # 11

$$P1 \leq 80$$

$$V2 \leq 20$$

$$V3 \leq 5$$

$$M2 \leq 60$$

$$M3 \leq 203$$

$$T1 \leq 10$$

SARGENT LUNDYENGINEERS
CHICAGO

Calcs. For

CALC. NO: CQD-002323
REV: 00 DATE: 06/03/82
PROJECT NUMBER: 4130-15

Safety-Related

Non-Safety-Rela

PAGE 45 OF 67

Client

Prepared by

Date

Project

Reviewed by

Date

Proj. No.

Equip. No.

Approved by

Date

(II)

Beam Group # 12

Beam Group # 15

$$P1 \leq 147$$

$$P1 \leq 10$$

$$V2 \leq 10$$

$$V2 \leq 1$$

$$V3 \leq 10$$

$$V3 \leq 45$$

$$M2 \leq 20$$

$$T1 \leq 1837191.1$$

$$M3 \leq 163$$

$$M2 \leq 142.3/500$$

$$T1 \leq 1$$

$$M3 \leq 30$$

Beam Group # 13

Beam Group # 18

$$P1 \leq 10$$

$$P1 \leq 25$$

$$V2 \leq 10$$

$$V2 \leq 5$$

$$V3 \leq 10$$

$$V3 \leq 60$$

$$M2 \leq 1/55$$

$$T1 \leq 10$$

$$M3 \leq 55$$

$$M2 \leq 3090$$

$$T1 \leq 1$$

$$M3 \leq 10$$

Beam Group # 14

Beam Group # 19

$$P1 \leq 10$$

$$P1 \leq 45$$

$$V2 \leq 10$$

$$V2 \leq 1$$

$$V3 \leq 1$$

$$V3 \leq 10$$

$$M2 \leq 9/13$$

$$M2 \leq 60$$

$$M3 \leq 78$$

$$M3 \leq 2.2$$

$$T1 \leq 1$$

$$T1 \leq 1$$

Client	Prepared by	Date
Project	Reviewed by	Date
Proj. No.	Approved by	Date
Equip. No.		

Beam Group # 20

$P1 \leq 20$

$V2 \leq 50$

$V3 \leq 1$

$M2 \leq 30$

$M3 \leq 800$

$T1 \leq 20$

Beam Group # 24

$P1 \leq 36$

$V2 \leq 24$

$V3 \leq 5.3$

$T1 \leq 101$

$M2 \leq 130$

$M3 \leq 430$

Beam Group 22

$P1 \leq 20$

$V2 \leq 20$

$T1 \leq 1$

$M2 \leq 44$

$M3 \leq 54/120$

$V2 \leq 12$

$V3 \leq 2$

Beam Group # 25

$P1 \leq 5$

$V2 \leq 1$

$V3 \leq 0.23$

$M2 \leq 11/25$

$M3 \leq 1/25$

$T1 \leq 1$

Beam Group # 23

$P1 \leq 20$

$V2 \leq 5$

$V3 \leq 1$

$T1 \leq 1$

$M3 \leq 22/30$

$M2 \leq 5/30$

Beam "Group" # 26

$P1 \leq 12$

$V2 \leq 5.3$

$V3 \leq 24$

$T1 \leq 1$

$M2 \leq 421$

$M3 \leq 174$

Client	Prepared by	Date
Project	Reviewed by	Date
Proj. No.	Equip. No.	Approved by
		Date

Z VALUES FOR BEAMS

	(3)	(2)	M3*	M2*
1	0.042	10.67	756	
2	0.062	36.	1116	
3	0.0071	216.	128	
4	0.105	0.05		900
5	The Beam consists of 2 type 4 $\times 1\frac{1}{4}$ " $\times 2$ " $\times 3$ "			
6	0.27/1	0.013/.12		1950
7	0.392/2	1.09/1.5	3528	
8	0.348/1.4	0.348/1.4	4474	
9	0.077/.09	5.809/3	15400	
10	0.432/1.5	0.0432/0.09		8640
11	2 unistruts $\times 10.5$ " $\times 1$ " $\times .179$ " channel (4)			
12	Default (4)			
13	Default (4)			
14	Default (4)			
15	Default (7) Combination of $4 \times 2 \times 2 \times \frac{1}{4}$ " $\times 2 \times 3 \times \frac{1}{4}$ "			
16				
17				
18	Default (1)			
19	Default (9)			
20	Default (11)/(4)			
21				
22				
23	→ 8			
24	Default (6)			
25	Default (6)			
26	P4001 unistrut channel/Default (4)			
27	Default (8)			

* Allowable moments based on a stress of 18000 psi.
Default indicates the beam in question is at least as stiff as the default value indicates.

SARGENT LUNDYENGINEERS
CHICAGO

Calcs. For

CALC. NO: CQD-002323
REV: 00 DATE: 06/03/82
PROJECT NUMBER: 4130-15

Safety-Related

Non-Safety-Related

48 OF 48
PAGE 48 OF 67

Client	Prepared by	Date
Project	Reviewed by	Date
Proj. No.	Approved by	Date
Equip. No.		

Plates

Plate stresses are small ; bounding values are:

$$M = 10 \text{ in lb}$$

$$N = 100 \text{ psi}$$

$$\sigma = \left\{ \frac{10(6)}{(0.125)^2} + 100 \right\} \text{ psi}$$

$$= 3940 \text{ psi}$$

Plate and Beam stresses due to static load are negligibly small and are therefore not considered.

Client	Prepared by	Date
Project	Reviewed by	Date
Proj. No. 11130-15 Equip. No.	Approved by	Date

WELD STRESSES

plate element 17, maximum stresses in the top filler plates which are welded are as follows

	M_{xx}	M_{yy}	M_{xy}
OBE	0.69	0.94	0.225
SSE	0.52	0.71	.154

Welds are 1" long $\frac{1}{8}$ " wide @ 12"

$$Z_x = \frac{[0.707(0.125)]^3 (1)}{12 \frac{0.707(0.125)}{2}} = 0.0013012$$

$$Z_y = \frac{(0.707)(0.125)^3}{12 (0.5)} = 0.01473$$

$$\sigma_b = \frac{0.69(12)}{0.0013} + \frac{0.71(12)}{0.01473}$$

$$= 6947.5 \text{ psi}$$

This stress is well below the allowable value of 18ksi. Thus the adequacy of the welds is assured.



Calcs. For	
Safety-Related	Non-Safety-Related

Client	Prepared by	Date
Project	Reviewed by	Date
Proj. No.	Approved by	Date
Equip. No.		

APPENDIX D

SARGENT LUNDY

ENGINEERS
CHICAGO

Calcs. For

CALC. NO: CQD-002323
REV: 00 DATE: 06/03/82
PROJECT NUMBER: 4130-15

Safety-Related

Non-Safety-Related

PAGE 50 OF 67

Client

Prepared by

Date

Project

Reviewed by

Date

Proj. No.

Equip. No.

Approved by

Date

RESPONSE SPECTRA CURVES FOR OBE & SSE

CURVES USED

OBE 1%

SSE 2%

HORIZONTAL CURVES ARE ENVELOPED FOR N-S & E-W
DIRECTIONS IN THE ANALYSIS.

SARGENT & LUNDY

ENGINEERS

14 JUL 76

SL180

273

ZIMMER1 SOIL-STRUCT. INTER. CASE SLAB 3 X
DESIGNER O.E. LOV CHECKER R. P. Jain
DESIGN SPECTRA AT JOINT/SLAB
PEAKS WIDENED BY 10% ON EACH SIDE
DAMPING 0.005 0.010 0.020 0.050
PAGE


CALC. NO: CQD-002323

REV: 00 DATE: 06/03/82

PROJECT NUMBER: 4130-15

FREQUENCY IN C

PAGE 51 OF 67



O.B.E. Horiz. Response Spectra N-S Component

SPECTRA NO. 3-A

ELEVATION 546'-0"

LOCATION Reactor, Auxiliary, Turbine

REVISION NO. 0


SARGENT & LUNDY
ENGINEERS

14 JUL 76
SL180

2%

ZIMMERI SOIL-STRUCT. HOR. CASE, CLASS 3
DESIGNER O.E. Lev CHECKER B. P. Jain
DESIGN SPECTRA AT JOINT/SLAB
PEAKS WIDENED BY 10% ON EACH SIDE
DAMPING 0.005 0.010 0.020 0.050
PAGE CALC. NO: CQD-002323
REV: 00 DATE: 06/03/82
PROJECT NUMBER: 4130-15

FREQUENCY IN C/P. PAGE 52 OF 67



O.B.E. Horiz. Response Spectra E-W Component SPECTRUM NO. 3-B


ELEVATION 546'-0"

LOCATION Reactor, Auxiliary, Turbine
Buildings Slab

REVISION NO. 0

28 JUL 76
8290EL

ZIMMER, 413015, SOIL-STRUCT, HORIZ, DSE
DESIGNER O.E. - Lev CHECKER B.P. Jain
DESIGN SPECTRA AT JOINT/SLAB 3 X-COMP
PEAKS WIDENED BY 10% ON EACH SIDE
DAMPING 0.010 0.020 0.050 0.100
PAGE CALC. NO: COD-002323
REV: 00 DATE: 06/03/82
PROJECT NUMBER: 4130-15



D. B. E. [Signature]

N-S Component

SPECTRA, Response Spectra

546 -0'

ELEVATION

Generator, Auxiliary, Turbine
Buildings Slab

REVISION NO. 0


SARGENT & LUNDY

ENGINEERS

28 JUL 76

8290EL

ZIMMER.413015.SOIL-STRUCT.HORIZ.DEE
DESIGNER O.E. Lev CHECKER B.P. Jain
DESIGN SPECTRA AT JOINT/SLAB 3 Y-COMP
PEAKS WIDENED BY 10% ON EACH SIDE
DAMPING 0.010 0.020 0.050 0.100
PAGE CALC. NO: CQD-002323
REV: 00 DATE: 06/03/82
PROJECT NUMBER: 4130-15



E.E. Horiz. Response Spectra E-W Component

SPECTRA NO. 3-D

ELEVATION 546'-0"

LOCATION Reactor, Auxiliary, Turbine
Buildings Slab

REVISION NO. 0

SARGENT & LUNDY

ENGINEERS

01 AUG 76


6730EL

ZIMMER, 413015, SOIL-STRUCT. V.S. 3.0BE
DESIGNED BY D. L. J. CHECKER D.P. Jain
DESIGN SPECTRA AT JOINT/SLAB 22 X-COMP
PEAKS WIDENED BY 15% ON EACH SIDE
DAMPING 0.010 0.020 0.050 0.100

PAGE CALC. NO: CQD-002323
REV: 00 DATE: 06/03/82
PROJECT NUMBER: 4130-15

FREQUENCY IN C

PAGE 55 OF 67



D.B.E. VERT RESPONSE SPECTRA

ELEVATION 546'-0", 525'-7", 503'-6"

LOCATION Reactor Bldg. Slab

SPECTRA NO. 1F, 2-F, 3-F

REVISION NO. 0


SARGENT & LUNDY
ENGINEERS

16 JUL 76
2170EL

17%

ZIMMER 1.413015, SBIL-STRUCT. V.S 3.88E
DESIGNER O.E. Lev CHECKER B.P. Jain
DESIGN SPECTRA AT JOINT/SLAB 31 X-COMP
PEAKS WIDENED BY 15% ON EACH SIDE
DAMPING 0.005 0.010 0.020 0.050
PAGE CALC. NO: CQD-002323
REV: 00 DATE: 06/03/82
PROJECT NUMBER: 4130-15

FREQUENCY IN C PAGE 56 OF 67



O.B.E. Vert. Response Spectra

ELEVATION 546'-0", 525'-7"

LOCATION Auxiliary Bldg. Slab

SPECTRA NO. 2-E, 3-E

REVISION NO. 0

Client	Prepared by	Date
Project	Reviewed by	Date
Proj. No. Equip. No.	Approved by	Date

APPENDIX - E

INSTRUMENT WEIGHTS/MASSSES

Inst. #	Description
IE22 - R601 (W)	GE Pump Suction pressure indicator 180 vertical edgewise 2.3 X 6 X 7 1.2 pounds
IE22 - R604 (C)	GE Cond. Test line valve indicator 180 vertical edgewise 2.3 X 6 X 7 1.2 pounds
IE22 - R606	GE Electrical indicator 180 vertical edgewise 2.3 X 6 X 7 1.2 pounds
III - RH501	GE Electrical indicator 180 vertical edgewise 2.3 X 6 X 7 1.2 pounds

III - RH 502	GE Electrical indicator 180 vertical edgewise 2.3 x 6 x 7 1.2 pounds
III - HP 500	GE Electrical indicator 180 vertical edgewise 2.3 x 6 x 7 1.2 pounds
IESI - C002	GE Electrical indicator 180 vertical edgewise 2.3 x 6 x 7 1.2 pounds
IESI - R601	GE Tb STm exhaust pressure indicator 180 vertical edgewise 2.3 x 6 x 7 1.2 pounds
IESI - R602	GE Tb STm inlet pressure indicator 180 vertical edgewise 2.3 x 6 x 7 1.2 pounds

IESI - RG03

GE
Tb STM - exhaust
180 vertical edgewise
2.3 x 6 x 7
1.2 pounds

IESI - RG04

GE
pump suction indicator
180 vertical edgewise
2.3 x 6 x 7
1.2 pounds

IPI - CM081A

GE
electrical indicator
180 vertical edgewise
2.3 x 6 x 7
1.2 pounds

ITI - CM024

GE
Supp. chamber air Temp. indicator
180 vertical edgewise
2.3 x 6 x 7
1.2 pounds

LI - CM009

GE
Supp. chamber WTR indicator
180 vertical edgewise
2.3 x 6 x 7
1.2 pounds

IESI-K601	Barley Square Root Converter 750020 AAAA 1 1.25 X 7 X 1 1 pound
IESI-R600	Barley Meter pump discharge Controller 701003 AAEL 2.75 X 7.25 X 17.75 5 pounds
IB21-R623 A,B (Barley Reactor level & reactor pressure recorder 732232 BB AA 1WAB 6 X 6 X 15 20 pounds
IB21-R615	Barley Meter RCIC flow Controller 731112 AZ AA 1 6 X 6 X 15 20 pounds
B21-R610	GE vessel water level fuel zone level indicator 2 X 6 X 5 19 pounds

IE12 - R603

GE
RHR flow indicator
180 vertical edge wise
2.3x6x7
1.2 pounds

IFIR - LD099

westronics
Drywell floor drain sump level
D4E
6x6x5
18 pounds

IFIR - LD100

westronics
Drywell equipment drain sump, level
D4E
6x6x5
18 pounds

IUR - CM113

westronics
Drywell pressure wide range and Temperature
D4E
6x6x15
18 pounds

IUR - CM090

westronics
Supp. pool water level wide range
D4E
6x6x15
18 pounds

IRR - CM114

westronics

Drywell Radiation level

D4E

6X6X15

18 pounds

IAIR - CM115

westronics

Drywell Concentration

D4E

6X6X15

18 pounds

IPI - CM02B

GE

Electrical indicator

180 vertical edge wise

2.3X6X7

1.2 pounds

IPI - CM088A

GE

Electrical indicator

180 vertical edgewise

2.3X6X7

1.2 pounds

IPI - FW139

GE

Electrical indicator

180 vertical edgewise

2.3X6X7

1.2 pounds

1UAI - ANG01AA	electro device Annunciator window box 4 x 4 x 12.5 15 pounds
----------------	---

1UAI - ANG01AB	electro device Annunciator window box 4 x 4 x 12.5 15 pounds
----------------	---

1UAI - ANG01AC	electro device Annunciator window box 8 x 4 x 13.0 30 pounds
----------------	---

1UAI - ANG01AD	electro device Annunciator window box 8 x 4 x 13.5 30
----------------	--

1UAI - ANG01AW	electro device Annunciator window box 4 x 4 x 12.5 15 pounds
----------------	---

1UAI - ANG01Y	electro device Annunciator window box 7 x 4 x 9.0 26.25
---------------	--

IUAZ - AN601Z

electro device

Annunciator window box

314 x 120

30 pounds

NODAL LOADS (STATIC) OVER MASSES (DYNAMIC) MASS MOMENT OF INERTIA

NUMBER OF INPUT LOADING CARDS-- 22

NODE NUMBER	LOAD CASE	X-AXIS FORCE	Y-AXIS FORCE	Z-AXIS FORCE	X-AXIS MOMENT	Y-AXIS MOMENT	Z-AXIS MOMENT
22	0	.62000-01	.62000-01	.62000-01	.34700+01	.34700+01	.34700+01
26	0	.12900-01	.12900-01	.12900-01	.00000	.00000	.00000
32	0	.36000-01	.36000-01	.36000-01	.20300+01	.20300+01	.20300+01
33	0	.52000-01	.52000-01	.52000-01	.83000+00	.83000+00	.83000+00
34	0	.20000-01	.20000-01	.20000-01	.31200+00	.31200+00	.31200+00
36	0	.26000-01	.26000-01	.26000-01	.00000	.00000	.00000
47	0	.36000-01	.36000-01	.36000-01	.20300+01	.20300+01	.20300+01
48	0	.86000-01	.86000-01	.86000-01	.48400+01	.48400+01	.48400+01
49	0	.72000-01	.72000-01	.72000-01	.40500+01	.40500+01	.40500+01
51	0	.26000-01	.26000-01	.26000-01	.00000	.00000	.00000
62	0	.54000-01	.54000-01	.54000-01	.30400+01	.30400+01	.30400+01
63	0	.76000-01	.76000-01	.76000-01	.42800+01	.42800+01	.42800+01
64	0	.68000-01	.68000-01	.68000-01	.38300+01	.38300+01	.38300+01
66	0	.26000-01	.26000-01	.26000-01	.00000	.00000	.00000
77	0	.41000-01	.41000-01	.41000-01	.23100+01	.23100+01	.23100+01
78	0	.10500+00	.10500+00	.10500+00	.58900+01	.58900+01	.58900+01
79	0	.64000-01	.64000-01	.64000-01	.36000+01	.36000+01	.36000+01
81	0	.26000-01	.26000-01	.26000-01	.00000	.00000	.00000
92	0	.75000-01	.75000-01	.75000-01	.42200+01	.42200+01	.42200+01
93	0	.73000-01	.73000-01	.73000-01	.11600+01	.11600+01	.11600+01
94	0	.28000-01	.28000-01	.28000-01	.45000+00	.45000+00	.45000+00
96	0	.26000-01	.26000-01	.26000-01	.00000	.00000	.00000

* AFTER NODAL POINT INDICATES OUTPUT IN SPECIAL COORDINATES, READ NODAL INPUT DATA FOR MORE INFORMATIONS.

STRUCTURE LOAD CASE	ELEMENT A	LOAD B	MULTIPLIERS C D
1	.000	.000	.000 .000