

THE CINCINNATI GAS & ELECTRIC COMPANY



CINCINNATI, OHIO 45201

April 12, 1983

LOZ-83-0015

E. A. BORGMANN
SENIOR VICE PRESIDENT

Docket No. 50-358

U.S. Nuclear Regulatory Commission
Region III
799 Roosevelt Road
Glen Ellyn, IL 60137

Attention: Mr. J.G. Keppler
Regional Administrator

Gentlemen:

RE: WM. H. ZIMMER NUCLEAR POWER STATION - UNIT 1
10CFR50.55(e), ITEM M-40, INDETERMINATE
HEAT TREATMENT FOR SMALL BORE PIPE
W.O. 57300, JOB E-5590, FILE NO. 956C, M-40

This letter constitutes an interim report concerning the subject condition initially reported to the Commission on April 22, 1982 as a potentially reportable deficiency under the requirements of 10CFR50.55(e).

As stated in our previous report, QA-2253, dated February 8, 1983, CG&E intends to perform destructive tests to determine the heat treatment for samples of the four heats of piping listed on Nonconformance Report (NR) E-4337. Construction Work Authorization Requests (CWAR's) 86 through 89 have been submitted for approval to perform this work.

Completion of testing and required corrective actions are contingent upon NRC approval of the CWAR's or release of the NRC November 12, 1982 "Order to Show Cause and Order Immediately Suspending Construction". A follow-up report will be submitted by June 15, 1983.

8304210445 830412
PDR ADOCK 05000358
S PDR

APR 18 1983


IE27

Mr. J.G. Keppler
Regional Administrator
April 11, 1983
LOZ-83-0015
Page 2

We trust the above will be found acceptable as an interim report under 10CFR50.55(e).

Very truly yours,

THE CINCINNATI GAS & ELECTRIC COMPANY

By 
E.A. BORGMANN
SENIOR VICE PRESIDENT

RNT/FSH/bcf

cc: NRC Office of Inspection & Enforcement
Washington, D.C. 20555
NRC Senior Resident Inspector
ATTN: W.F. Christianson
NRC Zimmer Project Inspector
Region III