

**LICENSEE EVENT REPORT**

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

CONTROL BLOCK: 1 6 1 (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0 1 A L J M F 2 2 0 0 - 0 0 0 0 0 0 - 0 0 3 4 1 1 1 1 4 5

7 8 9 14 15 25 26 30 57 CAT 58

CON'T

0 1 REPORT SOURCE L 6 0 5 0 0 0 3 6 4 7 0 3 1 8 8 3 8 0 4 1 4 8 3 9

7 8 60 61 68 69 74 75 80

DOCKET NUMBER EVENT DATE REPORT DATE

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

02 At 2300 on 3/18/83, the instrumentation channel associated with service water discharge

03 flow transmitter FT-571 was declared inoperable when the main control board recorder

04 indicated low. Tech. Spec. 3.3.3.10, in part, requires this channel to be operable.

05 Tech. Spec. 3.3.3.10 action statement requirements were met. Health/safety of the

06 public was not affected.

07

08

7 8 9

09		SYSTEM CODE W A		CAUSE CODE E	CAUSE SUBCODE X	COMPONENT CODE I N S T R U				COMP. SUBCODE T	VALVE SUBCODE Z
7	8	9	10	11	12	13	14	15	16	17	18
LER/RO REPORT NUMBER		EVENT YEAR 8 3		SEQUENTIAL REPORT NO. 0 1 6		OCCURRENCE CODE 0 3		REPORT TYPE L		REVISION NO. 0	
21	22	23	24	25	26	27	28	29	30	31	32
ACTION TAKEN D		FUTURE ACTION X		EFFECT ON PLANT Z		SHUTDOWN METHOD Z		HOURS 0 0 0 0		ATTACHMENT SUBMITTED N	
33	34	35	36	37	38	39	40	41	42	43	44
NPRD-4 FORM SUB. N		PRIME COMP. SUPPLIER N		COMPONENT MANUFACTURER F 1 8 0		ACTION TAKEN D		FUTURE ACTION X		EFFECT ON PLANT Z	
45	46	47	48	49	50	51	52	53	54	55	56

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 This event was caused by water damage to the flow transmitter which is located in a  
1 1 service water valve box. Following the repair of the transmitter, the FT-571 instru-  
1 2 mentation channel was declared operable at 1640 on 3/19/83. An engineering review will  
1 3 be made to determine means for improving reliability.  
1 4

FACILITY STATUS										% POWER										OTHER STATUS										METHOD OF DISCOVERY										DISCOVERY DESCRIPTION									
1	5	E	28	1	0	0	29	NA	30	A	31	Operational Event																		32																			
ACTIVITY CONTENT										RELEASED OF RELEASE										AMOUNT OF ACTIVITY										LOCATION OF RELEASE																			
1	6	Z	33	Z	34	NA	35			NA	36																																						
PERSONNEL EXPOSURES										PERSONNEL INJURIES										LOSS OF OR DAMAGE TO FACILITY										PUBLICITY																			
1	7	0	0	0	37	0	0	0	40	NA	41	NA	42	NA	43	NA	44	8304220203 830414 PDR ADOCK 05000364 S PDR																															
ISSUED										NRC USE ONLY																																							
2	0	N	44	NA																																													

NAME OF PREPARER W. G. Hairston, III

PHONE: (205) 899-5156