

CONTROL BLOCK: ☐ ☐ ☐ ☐ ☐ ☐ (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)01 S C N E E 3 0 0 - 0 0 0 0 0 - 0 0 4 1 1 1 1 4 5
7 8 9 LICENSEE CODE 14 15 LICENSE NUMBER 25 26 LICENSE TYPE 30 37 CAT 38

CONT

01 REPORT SOURCE L 05 0 0 0 0 2 8 7 0 3 1 4 8 3 0 4 1 3 8 3 9
7 8 DOCKET NUMBER 68 69 EVENT DATE 74 75 REPORT DATE 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

02 On March 14, 1983, during an Engineered Safeguards (ES) test, a supply valve

03 failed to open, making it and the Reactor Building Cooling (RBC) Train "B"

04 inoperable. Another independent ES system, the Reactor Building Spray, alone

05 is capable of limiting the containment pressure after a Loss of Coolant Acci-

06 dent. Also, "A" and "C" RBC units would still be available to remove heat.

07 Thus, the health and safety of the public were not affected by this incident.

08

09 SYSTEM CODE C B 11 CAUSE CODE E 12 CAUSE SUBCODE A 13 COMPONENT CODE V A L V E X 14 COMP. SUBCODE E 15 VALVE SUBCODE G 16

17 LER/RO REPORT NUMBER 8 3 18 EVENT YEAR 8 3 19 SEQUENTIAL REPORT NO. 0 0 5 20 OCCURRENCE CODE 0 1 21 REPORT TYPE T 22 REVISION NO. 0

23 ACTION TAKEN E 24 FUTURE ACTION X 25 EFFECT ON PLANT Z 26 SHUTDOWN METHOD Z 27 HOURS 0 0 0 28 ATTACHMENT SUBMITTED N 29 NRC-4 FORM SUB. N 30 PRIME COMP. SUPPLIER L 31 COMPONENT MANUFACTURER G 0 8 0

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

10 The cause of this incident was component failure. It was found that the main

11 feeder breaker to the valve tripped on overcurrent during testing. The

12 breaker was then reset and the overcurrent trip setting was increased. The

13 practice of setting the overcurrent trip setting at the lowest possible value

14 on the ES valves will be evaluated.

15 FACILITY STATUS E 28 % POWER 1 0 0 29 OTHER STATUS NA 30 METHOD OF DISCOVERY B 31 DISCOVERY DESCRIPTION Operator observation-during testing 32

16 ACTIVITY CONTENT RELEASED OF RELEASE Z 33 AMOUNT OF ACTIVITY NA 34 LOCATION OF RELEASE NA 36

17 PERSONNEL EXPOSURES NUMBER 0 0 0 37 TYPE Z 38 DESCRIPTION NA 39

18 PERSONNEL INJURIES NUMBER 0 0 0 40 DESCRIPTION NA 41

19 LOSS OF OR DAMAGE TO FACILITY TYPE Z 42 DESCRIPTION NA 43

20 PUBLICITY ISSUED N 44 DESCRIPTION NA 45

NRC USE ONLY

NAME OF PREPARER Jocelyn C. Petty

PHONE: (704) 373-0335