

DUKE POWER COMPANY

P.O. BOX 33189
CHARLOTTE, N.C. 28242

HAL B. TUCKER
VICE PRESIDENT
NUCLEAR PRODUCTION

April 15, 1983 9:46

TELEPHONE
(704) 373-4531

Mr. James P. O'Reilly, Regional Administrator
U. S. Nuclear Regulatory Commission
Region II
101 Marietta Street NW, Suite 2900
Atlanta, Georgia 30303

Re: McGuire Nuclear Station Unit 1
Docket No. 50-369

Dear Mr. O'Reilly:

Reportable Occurrence Report RO-369/83-13 was to have been submitted by April 15, 1983. This 30 day reportable occurrence (pursuant to T.S. 6.9.1.13) concerns T.S. 3.5.1.2, "Each upper head injection accumulator system shall be operable with:...b. the water-filled accumulator containing a minimum of 1850 cubic feet of borated water...", which was violated on March 15, 1983. At this time certain items have not yet been resolved with Westinghouse and, therefore, preparation of a complete report is not possible. It is expected that these items will be resolved and a complete report submitted by April 29, 1983.

Very truly yours,

H.B. Tucker / BT

Hal B. Tucker

PBN:jfw

cc: Document Control Desk
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Records Center
Institute of Nuclear Power Operations
1100 Circle 75 Parkway, Suite 1500
Atlanta, Georgia 30339

Mr. W. T. Orders
NRC Resident Inspector
McGuire Nuclear Station

8304220386 830415
PDR ADOCK 05000369
S PDR

OFFICIAL COPY

TE 22