

# LICENSEE EVENT REPORT

CONTROL BLOCK: 1 (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

7	8	9	P	A	P	B	S	2	0	0	-	0	0	0	0	-	0	0	3	4	1	1	1	1	4	5																
			LICENSEE CODE										LICENSE NUMBER										LICENSE TYPE										CAT 58									

7	8	9	L	6	0	5	0	-	0	2	7	7	0	3	2	3	8	3	8	0	4	0	8	8	3	9						
			DOCKET NUMBER										EVENT DATE										REPORT DATE									

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES 10

0 2 Investigation on 3/23/83 into spike on torus level recorder determined

0 3 that test apparatus had been left in service from 3/20/83 with instrument

0 4 drain valve left open providing potential containment leak path. The

0 5 leakage rate of torus water would be 5 gpm at DBA pressure (49.1 psig)

0 6 thus it would take 25 days to drain water to level where air would escape,

0 7 Make-up water and redundant level indication available therefore

0 8 safety significance minimal.

7	8	9	1	F	11	A	12	C	13	I	N	S	T	R	U	14	E	15	Z	16							
			SYSTEM CODE			CAUSE CODE			CAUSE SUBCODE			COMPONENT CODE					COMP. SUBCODE		VALVE SUBCODE								
			<span style="border: 1px solid black; border-radius: 50%; padding: 2px;">17</span>			<span style="border: 1px solid black; border-radius: 50%; padding: 2px;">18</span>			<span style="border: 1px solid black; border-radius: 50%; padding: 2px;">19</span>			<span style="border: 1px solid black; border-radius: 50%; padding: 2px;">20</span>					<span style="border: 1px solid black; border-radius: 50%; padding: 2px;">21</span>		<span style="border: 1px solid black; border-radius: 50%; padding: 2px;">22</span>								
			LER/RO REPORT NUMBER			EVENT YEAR			SEQUENTIAL REPORT NO.			OCCURRENCE CODE					REPORT TYPE		REVISION NO.								
			<span style="border: 1px solid black; border-radius: 50%; padding: 2px;">23</span>			<span style="border: 1px solid black; border-radius: 50%; padding: 2px;">24</span>			<span style="border: 1px solid black; border-radius: 50%; padding: 2px;">25</span>			<span style="border: 1px solid black; border-radius: 50%; padding: 2px;">26</span>					<span style="border: 1px solid black; border-radius: 50%; padding: 2px;">27</span>		<span style="border: 1px solid black; border-radius: 50%; padding: 2px;">28</span>								
			ACTION TAKEN			FUTURE ACTION			EFFECT ON PLANT			SHUTDOWN METHOD			HOURS					ATTACHMENT SUBMITTED		NPRD-4 FORM SUB.		PRIME COMP. SUPPLIER		COMPONENT MANUFACTURER	
			<span style="border: 1px solid black; border-radius: 50%; padding: 2px;">29</span>			<span style="border: 1px solid black; border-radius: 50%; padding: 2px;">30</span>			<span style="border: 1px solid black; border-radius: 50%; padding: 2px;">31</span>			<span style="border: 1px solid black; border-radius: 50%; padding: 2px;">32</span>			<span style="border: 1px solid black; border-radius: 50%; padding: 2px;">33</span>					<span style="border: 1px solid black; border-radius: 50%; padding: 2px;">34</span>		<span style="border: 1px solid black; border-radius: 50%; padding: 2px;">35</span>		<span style="border: 1px solid black; border-radius: 50%; padding: 2px;">36</span>			
			ACTION TAKEN			FUTURE ACTION			EFFECT ON PLANT			SHUTDOWN METHOD			HOURS					ATTACHMENT SUBMITTED		NPRD-4 FORM SUB.		PRIME COMP. SUPPLIER		COMPONENT MANUFACTURER	

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS 27

1 0 This event was caused by personnel error. Instrument technician

1 1 failed to isolate test equipment after completing calibration. Upon

1 2 discovery drain valve closed, test equipment removed and line capped.

1 3 Personnel involved were disciplined. Supervisors met with instrument

1 4 techs to stress importance of performing valving properly.

7	8	9	G	28	0	0	0	29	U/3 Refueling	A	31	Operator Observation	32	
			FACILITY STATUS			% POWER			OTHER STATUS			DISCOVERY DESCRIPTION		
			<span style="border: 1px solid black; border-radius: 50%; padding: 2px;">33</span>			<span style="border: 1px solid black; border-radius: 50%; padding: 2px;">34</span>			<span style="border: 1px solid black; border-radius: 50%; padding: 2px;">35</span>			<span style="border: 1px solid black; border-radius: 50%; padding: 2px;">36</span>		
			ACTIVITY CONTENT			AMOUNT OF ACTIVITY			LOCATION OF RELEASE					
			<span style="border: 1px solid black; border-radius: 50%; padding: 2px;">37</span>			<span style="border: 1px solid black; border-radius: 50%; padding: 2px;">38</span>			<span style="border: 1px solid black; border-radius: 50%; padding: 2px;">39</span>			<span style="border: 1px solid black; border-radius: 50%; padding: 2px;">40</span>		
			PERSONNEL EXPOSURES			DESCRIPTION								
			<span style="border: 1px solid black; border-radius: 50%; padding: 2px;">41</span>			<span style="border: 1px solid black; border-radius: 50%; padding: 2px;">42</span>			<span style="border: 1px solid black; border-radius: 50%; padding: 2px;">43</span>			<span style="border: 1px solid black; border-radius: 50%; padding: 2px;">44</span>		
			PERSONNEL INJURIES			DESCRIPTION								
			<span style="border: 1px solid black; border-radius: 50%; padding: 2px;">45</span>			<span style="border: 1px solid black; border-radius: 50%; padding: 2px;">46</span>			<span style="border: 1px solid black; border-radius: 50%; padding: 2px;">47</span>			<span style="border: 1px solid black; border-radius: 50%; padding: 2px;">48</span>		
			LOSS OF OR DAMAGE TO FACILITY			DESCRIPTION								
			<span style="border: 1px solid black; border-radius: 50%; padding: 2px;">49</span>			<span style="border: 1px solid black; border-radius: 50%; padding: 2px;">50</span>			<span style="border: 1px solid black; border-radius: 50%; padding: 2px;">51</span>			<span style="border: 1px solid black; border-radius: 50%; padding: 2px;">52</span>		
			PUBLICITY			DESCRIPTION								
			<span style="border: 1px solid black; border-radius: 50%; padding: 2px;">53</span>			<span style="border: 1px solid black; border-radius: 50%; padding: 2px;">54</span>			<span style="border: 1px solid black; border-radius: 50%; padding: 2px;">55</span>			<span style="border: 1px solid black; border-radius: 50%; padding: 2px;">56</span>		
			ISSUED			DESCRIPTION								
			<span style="border: 1px solid black; border-radius: 50%; padding: 2px;">57</span>			<span style="border: 1px solid black; border-radius: 50%; padding: 2px;">58</span>			<span style="border: 1px solid black; border-radius: 50%; padding: 2px;">59</span>			<span style="border: 1px solid black; border-radius: 50%; padding: 2px;">60</span>		