

LICENSEE EVENT REPORT

CONTROL BLOCK: 1 (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0 1 N C B E P 2 0 0 - 0 0 0 0 0 - 0 0 3 4 1 1 1 1 4 5
7 8 9 LICENSEE CODE 14 15 LICENSE NUMBER 25 26 LICENSE TYPE 30 57 CAT 58

CON'T
0 1 REPORT SOURCE L 6 0 5 0 - 0 3 2 4 7 0 3 2 1 8 3 8 0 4 1 5 8 3 9
7 8 60 61 DOCKET NUMBER 68 69 EVENT DATE 74 75 REPORT DATE 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 During unit power operation, a routine channel check of reactor level instrumentation

0 3 revealed reactor level instrument 2-B21-LT-N017D-1 was indicating a level of 197" while

0 4 redundant instrumentation indicated a level of 187". N017D-1 supplies a low level

0 5 input to the RPS and PCIS to initiate a reactor scram and a group 2, 6, 7, and 8

0 6 isolation signal at > / = 162.5". This event did not affect the health and safety

0 7 of the public.

0 8 Technical Specifications 2.2.1, 3.3.2, 6.9.1.9b

0 9 SYSTEM CODE I A 11 CAUSE CODE E 12 CAUSE SUBCODE B 13 COMPONENT CODE V A L V E X 14 COMP. SUBCODE G 15 VALVE SUBCODE D 16
7 8 9 10 11 12 13 14 15 16 17 18 19 20

17 LER/RO REPORT NUMBER 8 3 21 22 EVENT YEAR 23 0 2 4 24 25 26 SEQUENTIAL REPORT NO. 27 0 3 28 29 OCCURRENCE CODE 30 L 31 REPORT TYPE 32 0 32 REVISION NO. 33 0 34

ACTION TAKEN B 18 FUTURE ACTION Z 19 EFFECT ON PLANT Z 20 SHUTDOWN METHOD Z 21 HOURS 0 0 0 0 22 ATTACHMENT SUBMITTED N 23 NPRD-4 FORM SUB. Y 24 PRIME COMP. SUPPLIER A 25 COMPONENT MANUFACTURER R 3 6 9 26
33 34 35 36 37 38 39 40 41 42 43 44 45 46 47

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 A small stem packing leak on the N017D-1 reference leg excess flow check valve bypass

1 1 valve allowed the reference leg level to decrease and cause N017D-1 to see a higher

1 2 than actual level. The subject valve stem packing was adjusted to eliminate the

1 3 leakage and N017D-1, Model No. 1152, was returned to service. No further action

1 4 regarding this event is planned.

1 5 FACILITY STATUS E 28 % POWER 1 0 0 29 OTHER STATUS NA 30 METHOD OF DISCOVERY A 31 DISCOVERY DESCRIPTION Operator Surveillance 32
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50

1 6 ACTIVITY CONTENT Z 33 RELEASED OF RELEASE Z 34 AMOUNT OF ACTIVITY NA 35 LOCATION OF RELEASE NA 36
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50

1 7 PERSONNEL EXPOSURES NUMBER 0 0 0 37 TYPE Z 38 DESCRIPTION NA 39
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50

1 8 PERSONNEL INJURIES NUMBER 0 0 0 40 DESCRIPTION NA 41
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50

1 9 LOSS OF OR DAMAGE TO FACILITY TYPE Z 42 DESCRIPTION NA 43
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50

2 0 PUBLICITY ISSUED N 44 DESCRIPTION NA 45
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50

NAME OF PREPARER M. J. Pastva, Jr. PHONE: 919-457-9521

8304220412 830415
PDR ADOCK 05000324
S PDR

NRC USE ONLY

GPO 917-926