

LICENSEE EVENT REPORT

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

CON'T

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

03 for the 33, 150 and 300 foot elevations had failed. An operator was dispatched to

64 the meteorological tower where it was found that the local indication had also

0 5 failed. The wind speed monitors were declared inoperable, and at 1745 hours Action

6	6
---	---

 Statement 3.3.3.4 was entered.

0	7
---	---

0	8
---	---

0	9
7	8

SYSTEM CODE CAUSE CODE CAUSE SUBCODE COMPONENT CODE COMP SUBCODE VALVE SUBCODE

A D 11 C 12 Z 13 I N S T R U 14 E 15 Z 16

9 10 11 12 13 14 15 16

(17) LER RO REPORT NUMBER EVENT YEAR
82—
21 22 23

SEQUENTIAL REPORT NO. 014/
24 25 26 27

OCCURRENCE CODE 03
28 29

REPORT TYPE X—
30 31

REVISION NO. 1
32

ACTION TAKEN		FUTURE ACTION		EFFECT ON PLANT		SHUTDOWN METHOD		HOURS				ATTACHMENT SUBMITTED		NPRD-4 FORM SUB.		PRIME COMP. SUPPLIER		COMPONENT MANUFACTURER				
Z	18	Z	19	Z	20	Z	21	0	0	0	0	Y	23	N	24	L	25	C	4	1	5	26
33	34	35	36	37	38	39	40	41	42	43	44	45	46	47	48	49	50	51	52	53	54	55

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

10 | Freezing rain had iced-up the anemometers, causing the loss of wind speed indication.

On March 7, 1982 the anemometers thawed with rising ambient temperature, and Control

Room indication was regained. At 1415 hours all wind speed monitors were declared

operable and Action Statement 3.3.3.4 was terminated. Thermostat controlled heat tapes

1	4
---	---

 have been installed on the anemometers to prevent freezing.

FACILITY STATUS				% POWER			OTHER STATUS		METHOD OF DISCOVERY		DISCOVERY DESCRIPTION	
1	5	H	28	0	0	0	29	N/A	A	31	Operator Observation	

ACTIVITY		CONTENT		RELEASED		OF RELEASE		AMOUNT OF ACTIVITY		LOCATION OF RELEASE	
1	6	Z	(33)	Z	(34)	N/A		(35)		N/A	

		PERSONNEL EXPOSURES			
		NUMBER	TYPE	DESCRIPTION	
1	7	0	0	0	(37) Z (38) N/A

PERSONNEL INJURIES		NUMBER		DESCRIPTION	
1	8	0	0	0	(40)

N/A

1		2		3		4		5		6		7		8		9		10		11		12		
LOSS OF OR DAMAGE TO FACILITY (43)																								
TYPE		DESCRIPTION																						
1	9	2	(42)																					N/A

[illegible]

2	0	N	(44)	N/A
7	8	9	10	

8304220437 830330
PDR ADOCK 05000272
S PDR

NRC USE ONLY

NAME OF PREPARER R. Heller

PHONE: (609) 935-6000 Ext. 3078