



Commonwealth Edison
LaSalle County Nuclear Station
Rural Route #1, Box 220
Marseilles, Illinois 61341
Telephone 815/357-6761

April 12, 1983

James G. Keppler
Regional Administrator
Region III
U.S. Nuclear Regulatory Commission
799 Roosevelt Road
Glen Ellyn, IL 60137

Dear Sir:

In accordance with LaSalle County Station Unit 1 Facility Operating License NPF-11, Appendix B, Section 3.2, we are submitting to you a copy of the NPDES noncompliances for LaSalle County Nuclear Generating Station Permit No. IL0048151.

G. J. Diederich
Superintendent
LaSalle County Station

JDW
GJD/FRL/JDW/rg

Enclosure

cc: DVR Report

8304220459 830412
PDR ADOCK 05000373
S PDR

APR 15 1983

1E22



Commonwealth Edison
LaSalle County Nuclear Station
Rural Route #1, Box 220
Marseilles, Illinois 61341
Telephone 815/357-6761

March 21, 1983

U.S. Environmental Protection Agency
Region V, Enforcement Division
ATTN: Chief, Compliance Unit
230 South Dearborn Street
Chicago, IL 60604


Illinois Environmental Protection Agency
Division of Water Pollution Control
Compliance Management Unit
2200 Churchill Road
Springfield, IL 62706

Dear Sir:

Subject: NPDES Noncompliances for LaSalle County Nuclear
Generating Station - Permit No. IL0048151

In accordance with Standard Condition 12, we wish to submit the following notice of noncompliances, which are listed chronologically in the attached table.

If there are any questions, please contact Joe Williams of my staff at (815) 357-6761, extension 201.


G. J. Diederich
Station Superintendent

REL JDN
GJD/FRL/JDW/lrw

cc: Director of Water Quality, Environmental Affairs
Manager, Nuclear Stations Division

LASALLE COUNTY NUCLEAR GENERATING STATION
N.P.D.E.S. PERMIT NO: IL0048151
NONCOMPLIANCE REPORT

DISCHARGE NUMBER AND DESCRIPTION: 001C Low Volume Waste Radwaste Discharge
Tanks

PARAMETER AND PERMIT LIMIT: Total Iron, 1.0 mg/l

NONCOMPLIANCE, DATE, AND DURATION: 8.0 mg/l, 14MAR83, 11-1/2 Hours

CAUSE OF NONCOMPLIANCE: Problems with the OWZ common evaporator have
caused excessive carryover.

CORRECTIVE ACTION: The cause will be investigated as part of
Work Request #L22865.

DATE RECOGNIZED AS A VIOLATION:

17MAR83

DATE INVESTIGATED:

21MAR83