

THE CINCINNATI GAS & ELECTRIC COMPANY



CINCINNATI, OHIO 45201

March 31, 1983

E. A. BORGMANN  
SENIOR VICE PRESIDENT

Mail Stop 316  
Nuclear Regulatory Commission  
Phillips Building  
7920 Norfolk Avenue  
Bethesda, Maryland 20814

ATTN: Mr. L. L. Kintner  
Project Manager

RE: WM. H. ZIMMER NUCLEAR POWER STATION - UNIT 1  
EVALUATION OF FEEDWATER LINE FOR SEISMIC EVENTS  
W.O. 57300, JOB E-5590, FILE 956


Gentlemen:

In response to previous discussions on the possible effects of the feedwater lines on the main steam lines, this letter will confirm the action to be taken.

CG&E will evaluate the ability of the feedwater lines to withstand the effects of the SSE, or demonstrate that the consequences of a feedwater line failure and its impact into the main steam lines will result in acceptable offsite doses.

Very truly yours,

THE CINCINNATI GAS & ELECTRIC COMPANY

By   
E. A. Borgmann  
SENIOR VICE PRESIDENT

HCB/PEB/gj

cc: NRC Region III  
Mr. J. G. Keppler  
NRC Region IV  
Mr. Pat Sears  
R. F. Scheibel, Sargent & Lundy  
R. J. Pruski, Sargent & Lundy  
J. D. Flynn

H. R. Sager  
J. R. Schott  
G. Ficke  
D. J. Frederick  
P. E. Bogen  
H. G. Gadd (pink)  
ATTN: General File

Boo1

8304220506 830331  
PDR ADOCK 05000358  
PDR  
A