

## (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

LER ATTACHMENT - RO #2-83-34

Facility: BSEP Unit No. 2

Event Date: March 18, 1983

As a result of an event involving this instrumentation on Unit No. 1, as reported in LER 1-81-07 and a post-TMI requirement, plant modification packages (80-79 and 80-016 for Unit No. 1 and 80-78 and 80-017 for Unit No. 2) have been developed. These modifications will install condensing pots in the reference legs of these instruments in order to increase their accuracy and reliability, and remove the requirement to have flow in their reference legs to ensure they are full.