

THE CINCINNATI GAS & ELECTRIC COMPANY



CINCINNATI, OHIO 45201

March 31, 1983

50-358

E. A. BORGMANN
SENIOR VICE PRESIDENT

Mail Stop 316
Nuclear Regulatory Commission
Phillips Building
7920 Norfolk Avenue
Bethesda, Maryland 20814

ATTN: Mr. L. L. Kintner
Project Manager

RE: WM. H. ZIMMER NUCLEAR POWER STATION - UNIT 1
EVALUATION FOR POSSIBLE RESTRICTIONS ON
TURBINE ROOM CRANE OPERATION
W.O. 57300, JOB E-5590, FILE 956

Gentlemen:

In response to previous discussions on restricting operation of the Turbine Room Crane, this letter will confirm the action to be taken by CG&E.

A reduced allowable lifted load will be used for the Turbine Room Crane in the area of the Main Steam Line in the Turbine Room; specifically, the area from Column Row "L" to "P" and from Column Row 16 to 24. This reduced lifted load will be the maximum load the turbine room crane can support during an SSE event. The crane and supporting structure stresses will not exceed the provisions of Standard Review Plan 3.8.4 for the crane dead load and SSE load combinations. The reduced lifted load restriction will only apply during unit operation.

Very truly yours,

THE CINCINNATI GAS & ELECTRIC COMPANY

8304220512 830331
PDR ADOCK 05000358
A PDR

By

E. A. Borgmann
SENIOR VICE PRESIDENT

Boo1

HCB/PEB/qj

cc: NRC Region III
Mr. J.G. Keppler
NRC Region IV
Mr. P. Sears
R. F. Scheibel, Sargent & Lundy
R. J. Pruski, Sargent & Lundy
J. D. Flynn
H. C. Brinkmann

H. R. Sager
J. R. Schott
G. Ficke
D. J. Frederick
P. E. Bogen
H. G. Gadd (pink)
ATTN: General File