



Carolina Power & Light Company

Brunswick Nuclear Project  
P. O. Box 10429  
Southport, N.C. 28461-0429  
May 9, 1991

FILE: B09-13510C

U.S. Nuclear Regulatory Commission  
ATTN: Document Control Desk  
Washington, D. C. 20555


BRUNSWICK STEAM ELECTRIC PLANT UNIT 1  
DOCKET NO. 50-325  
LICENSE NO. DPR-71  
SPECIAL REPORT PER TECHNICAL SPECIFICATION 3.7.7.2 AND  
PURSUANT TO TECHNICAL SPECIFICATION 6.9.2 (1-SR-91-002)

Gentlemen:

At approximately 0730 hours (EST) on March 28, 1991, a sprinkler system Limiting Condition for Operation (LCO) was initiated on the Diesel Generator No. 1 Preaction System. Both Units 1 and 2 were at 100% power operation at this time. The subject LCO was entered to facilitate disassembly and repair of the Emergency Diesel Generator No. 1 (EDG-1). A continuous fire watch was established at this time.

The Diesel Generator No. 1 Preaction System was isolated to prevent accidental flooding of EDG-1 because of the close proximity of sprinkler heads to the involved work. Due to the scope of the work, the fourteen-day time frame of the LCO was exceeded on April 11, 1991. Repair of EDG-1 was subsequently completed and the LCO was cancelled on April 18, 1991, at 1000 hours (EST). Until cancellation of the LCO, the continuous fire watch remained in effect.

Very truly yours,

  
J. W. Spencer, General Manager  
Brunswick Nuclear Project

WRT/

cc: Mr. S. D. Ebner  
Mr. N. B. Le  
BSEP NRC Resident Office  
NRC Document Control Desk

9105170256 910509  
PDR ADDCK 05000325  
S PDR

JE22 1/0