



Carolina Power & Light Company

P. O. Box 101, New Hill, North Carolina 27562
April 1, 1983

FILE: SH N-2/18
Item 98

MQAH 83-17

Mr. James P. O'Reilly
United States Nuclear Regulatory Commission
Region II
101 Marietta Street, Northwest
Atlanta, Georgia 30303

SHEARON HARRIS NUCLEAR POWER PLANT, UNITS 1 AND 2
DOCKET NOS. 50-400, 50-401
SHEARED PINION KEYS ON LIMITORQUE VALVE MOTOR OPERATORS

Dear Mr. O'Reilly:


This is to confirm the March 31, 1983 telephone conversation between Mr. K. V. Hate' and Mr. A. Hardin. Mr. Hardin was informed that the September 3, 1982 potentially reportable item, pertaining to sheared pinion keys on Limitorque valve motor operators, discovered by Westinghouse Electric Corporation, had been evaluated and considered to be not reportable per the provisions of 10CFR50.55(e) and 10CFR, Part 21.

Thank you for your consideration in this matter.

Yours very truly,

NJC/mt

cc: Mr. G. Maxwell
Mr. V. Stello


N. J. Chiangi - Manager
Quality Assurance/Quality Control
Harris Plant

IE19

OFFICIAL COPY

IE 27