



Pennsylvania Power & Light Company

Two North Ninth Street • Allentown, PA 18101 • 215 / 770-5151

February 18, 1983

Mr. R. C. Haynes
Director, Region I
U.S. Nuclear Regulatory Commission
631 Park Avenue
King of Prussia, PA 19406

SUSQUEHANNA STEAM ELECTRIC STATION
LICENSEE EVENT REPORT ~~02-056/03X-1~~ 83-019/03L-0
ER 100450 FILE 841-23
PLA - 1538

Docket No. 50-387
License No. NPF-14

Dear Mr. Haynes:

Attached please find a copy of Licensee Event Report No. ~~02-056/03X-1~~ 83-019/03L-0. This event was determined to be reportable per Technical Specification 6.9.1.9.b, in that Drywell Vacuum Breaker PSV-1504E2 position could not be verified from the Control Room due to a faulty limit switch.

H. W. Keiser
Superintendent of Plant-Susquehanna

RJS/klm

Attachment

cc: Director of Nuclear Reactor Regulation
Attention: Mr. A. Schwencer, Chief
Licensing Branch No. 2
Division of Licensing
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

G. Rhoads
Resident Inspector
U.S. Nuclear Regulatory Commission
P.O. Box 52
Shickshinny, PA 18655

8304270264 830218
PDR ADOCK 05000387
S PDR

Ierr