



MISSISSIPPI POWER & LIGHT COMPANY

Helping Build Mississippi

P. O. BOX 1640, JACKSON, MISSISSIPPI 39205

April 21, 1983

JAMES P. McGAUGHY, JR.
VICE PRESIDENT

Office of Inspection & Enforcement
U. S. Nuclear Regulatory Commission
Region II
101 Marietta St., N.W., Suite 2900
Atlanta, Georgia 30303

Attention: Mr. J. P. O'Reilly, Regional Administrator


Dear Mr. O'Reilly:

SUBJECT: Grand Gulf Nuclear Station
Unit 1
Docket No. 50-416
License No. NPF-13
File 0260/L-835.0
Special Report 83-022/0 - Fire
Break in a Cable Tray
Removed
AECM-83/0248

On March 17, 1983, a fire break in a cable tray at elevation 177 feet of the Control Building was removed for implementation of a design change work package. An hourly fire watch was established in accordance with Technical Specification 3.7.7.

The fire break will be restored upon completion of the work. The fire watch will be continued in the interim. The estimated restoration date is May 23, 1983. This is a Special Report submitted pursuant to Technical Specification 6.9.2.

Yours truly,


FOR J. P. McGaughy, JR.

JPM:sap

cc: Mr. J. B. Richard
Mr. R. B. McGehee
Mr. T. B. Conner
Mr. G. B. Taylor

Mr. Richard C. DeYoung, Director
Office of Inspection & Enforcement
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Document Control Desk
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

8304280098 830421
PDR ADOCK 05000416
S PDR

Member Middle South Utilities System

OFFICIAL COPY

IE 22

03 APR 25 AID: 1

ENRPO REGION II
ATLANTA, GEORGIA