



ARKANSAS POWER & LIGHT COMPANY
POST OFFICE BOX 551 LITTLE ROCK, ARKANSAS 72203 (501) 371-4000

April 19, 1983

1CAN048309

Mr. W. C. Seidle, Chief
Reactor Project Branch #2
U. S. Nuclear Regulatory Commission
Region IV
611 Ryan Plaza Drive, Suite 1000
Arlington, Texas 76011



Subject: Arkansas Nuclear One - Unit 1
Docket No. 50-313
License No. DPR-51
Licensee Event Report
No. 83-007/03X-1

Gentlemen:

In accordance with Arkansas Nuclear One - Unit 1 Technical Specification 6.12.3.2.a, attached is the subject report concerning Reactor Building pressure switches PS-2403 and PS-2401 which were found to be out of tolerance. This is a revision to a previous report submitted on April 6, 1983.

Very truly yours,

John R. Marshall
Manager, Licensing

IE-27

JRM:RJS:s1

Attachment

cc: Mr. Richard C. DeYoung
Office of Inspection and Enforcement
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Mr. Norman M. Haller, Director
Office of Management & Program Analysis
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

8304280285 830419
PDR ADOCK 05000313
S PDR