



# MISSISSIPPI POWER & LIGHT COMPANY

Helping Build Mississippi

P. O. BOX 1640, JACKSON, MISSISSIPPI 39205

April 20, 1983

JAMES P. McGAUGHY, JR.  
VICE PRESIDENT

Office of Inspection & Enforcement  
U. S. Nuclear Regulatory Commission  
Region II  
101 Marietta St., N.W., Suite 2900  
Atlanta, Georgia 30303

Attention: Mr. J. P. O'Reilly, Regional Administrator


Dear Mr. O'Reilly:

SUBJECT: Grand Gulf Nuclear Station  
Unit 1  
Docket No. 50-416  
License No. NPF-13  
File 0260/L-835.0  
Update Report - Auxiliary  
Building Equipment Hatch  
Removed to Allow Transport  
of Materials  
LER 83-044/99 X-1  
AECM-83/0230

This is an update to a previous report submitted on March 1, 1983. The event for which the report was submitted occurred on January 24, 1983, when an equipment hatch at elevation 139 feet in the Auxiliary Building west corridor, was removed to allow transport of materials to elevation 119 feet. An hourly fire watch was established in accordance with Technical Specification 3.7.7. The report was submitted as a Special Report pursuant to Technical Specification 6.9.2.

All corrective action related to this event is complete. Attached is LER 83-044/99 X-1, which is a final report.

Yours truly,

  
FOR J. P. McGaughy, Jr.

JPM:sap  
Attachment

cc: (See Next Page)

8304280297 830420  
PDR ADDCK 05000416  
S PDR

Member Middle South Utilities System

OFFICIAL COPY  
IE 22

MISSISSIPPI POWER & LIGHT COMPANY

AECM-83/0230

Page 2

cc: Mr. J. B. Richard (w/a)  
Mr. R. B. McGehee (w/o)  
Mr. T. B. Conner (w/o)  
Mr. G. B. Taylor (w/o)

Mr. Richard C. DeYoung, Director (w/a)  
Office of Inspection & Enforcement  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555

Document Control Desk (w/a)  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555