



Telegram

1-011662A116 04/26/83

ICS IPMMVIT MVN

04121 04-26 1257P CDT MVIQ

ICS IPMMVIZ

1-011075C116 04/26/83

TLX CONSPower JKN

170 CONSUMERS POWER JACKSON MI

PMS

U.S. REGULATORY COMMISSION

PALISADES PLANT SECT. CHIEF

799 ROOSEVELT AVE

GLEN ELLYN IL 60137

MSG # CBW590

19509
BK 19509 MON FILE MAIL
CC () TB () LB () NFL () NON-PUB () INFO ()
13:18 EDT 04-26
PHONE-AC 312 932 2500
PHONED TO MT BY glc
DATE DLD 4-26 TIME 1323
DLY ATPS

TO: U S NUCLEAR REGULATORY COMMISSION
ATTN: PALISADES PLANT SECTION CHIEF
799 ROOSEVELT AVENUE
GLEN ELLYN, ILLINOIS

FROM: R M KRICH, PALISADES

W.U. 1201-SF (R5-69)



Telegram

CC: R B DEWITT, P-26-117B, JACKSON
D J VANDEWALLE, P-24-614B, JACKSON

THIS CONFIRMS PROMPT NOTIFICATION OF AN OCCURRENCE REPORTABLE PER T.S. 6.9.2A(2). ON APRIL 25, 1983, AT 1052, WITH SAFETY INJECTION TANK

T-82C INOPERABLE DUE TO ROUTINE SAMPLING, AN ADDITIONAL SAFETY INJECTION TANK,

T-82B, BECAME INOPERABLE DUE TO LOW LEVEL. THIS OCCURRENCE OF TWO INOPERABLE

SAFETY INJECTION TANKS AT THE SAME TIME LASTED APPROXIMATELY 4 MINUTES AT

WHICH TIME T-82B WAS RESTORED TO OPERABILITY PER T.S. 3.3.2.

INITIAL REPORT

WAS MADE VIA THE NRC HOT LINE ON APRIL 25, 1983.

TIME: 13:13 04/26/83 EDT

CONNECT TIME : 84 SECONDS

1250 EST

1303 EST

8305030155 830426
PDR ADDCK 05000255
S PDR

W.U. 1201-SF (R5-69)

APR 28 1983