



Carolina Power & Light Company

Brunswick Steam Electric Plant
P. O. Box 10429
Southport, NC 28461-0429

April 20, 1983

FILE: B09-13510C
SERIAL: BSEP/83-1240

Mr. James P. O'Reilly, Administrator
U. S. Nuclear Regulatory Commission
Region II, Suite 3100
101 Marietta Street N.W.
Atlanta, GA 30303

BRUNSWICK STEAM ELECTRIC PLANT, UNIT NO. 1
DOCKET NO. 50-325
LICENSE NO. DPR-71
SPECIAL REPORT PER TECHNICAL SPECIFICATION 3.7.8

Dear Mr. O'Reilly:

During a Unit No. 1 refueling outage, four fire barrier LCOs (two with issuance dates of March 20, 1983, and two with issuance dates of March 22, 1983) were generated to permit work in the Augmented Off-Gas and Control Buildings required for the installation of two plant modifications. Due to the complexity of the work required with these modifications, the seven-day specified time frame of these LCOs has been exceeded. Until completion of the involved modification work and cancellation of the subject LCOs, appropriate stationed fire watches will remain in effect. This report is submitted pursuant to Technical Specification 6.9.2.

Very truly yours,

C. R. Dietz, General Manager
Brunswick Steam Electric Plant

RMP/dj/LETDJ4

Enclosure

cc: Mr. R. C. DeYoung
NRC Document Control Desk

8305030505 830420
PDR ADDCK 05000325
S PDR

OFFICIAL COPY

IE 22