



Carolina Power & Light Company

Brunswick Steam Electric Plant

P. O. Box 10429

Southport, NC 28461-0429

April 20, 1983

FILE: B09-13510C

SERIAL: BSEP/83-1236

Mr. James P. O'Reilly, Administrator
U. S. Nuclear Regulatory Commission
Region II, Suite 3100
101 Marietta Street N.W.
Atlanta, GA 30303

BRUNSWICK STEAM ELECTRIC PLANT, UNIT NO. 2

DOCKET NO. 50-324


LICENSE NO. DPR-62

SPECIAL REPORT PER TECHNICAL SPECIFICATION 3.7.8

Dear Mr. O'Reilly:

During Unit No. 2 power operation three fire barrier LCOs (two with an issuance date of March 17, 1983, and one with an issuance date of March 20, 1983) were generated to permit work in the Control, Diesel Generator, and Augmented Off-Gas Buildings required for the installation of three respective plant modifications. Due to the complexity of the work involved with these modifications, the seven-day specified time frame of these LCOs has been exceeded. Until completion of the involved plant modification work and cancellation of the subject LCOs, continuous stationed fire watches will be maintained. This report is submitted pursuant to Technical Specification 6.9.2.

Very truly yours,


C. R. Dietz, General Manager
Brunswick Steam Electric Plant

RMP/dj/LETDJ4

Enclosure

cc: Mr. R. C. DeYoung
NRC Document Control Desk

8305030530 830420
PDR ADDCK 05000324
S PDR

OFFICIAL COPY
IE 22

33 APR 28 4 5: 40

NRC REGIONAL OFFICE
ATLANTA, GEORGIA