

U.S. NUCLEAR REGULATORY COMMISSION

LICENSEE EVENT REPORT

CONTROL BLOCK / / / / / / / (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

/0/1/ /V/A/N/A/S/1/ (2) /0/0/-/0/0/0/0/0/-/0/0/ (3) / / / / / / (4) / / / (5)
LICENSEE CODE LICENSE NUMBER LICENSE TYPE CAT

/0/1/ REPORT /L/ (6) /0/5/0/0/0/3/3/8/ (7) /0/4/0/5/8/3/ (8) /0/4/2/1/8/3/ (9)
SOURCE DOCKET NUMBER EVENT DATE REPORT DATE

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

/0/2/ / On April 5, 1983, with Unit 1 in Mode 1, the Individual Rod Position Indication /
/0/3/ / (IRPI) for Control Bank "C" rod D-12 deviated from its group demand position by /
/0/4/ / greater than 12 steps. Control rod D-12 was not misaligned, IRPI drift caused /
/0/5/ / the disagreement. The Action Statement of the applicable LCO, T.S. 3.1.3.2, was /
/0/6/ / met by restoring the channel to operable status within 8 hours. The public /
/0/7/ / health and safety were not affected. This event is reportable pursuant to T.S. /
/0/8/ / 6.9.1.9.b. /

SYSTEM CAUSE CAUSE COMP. VALVE
CODE CODE SUBCODE COMPONENT CODE SUBCODE SUBCODE

/0/9/ /I/D/ (11) /E/ (12) /E/ (13) /I/N/S/T/R/U/ /I/ /Z/
LER/RO EVENT YEAR SEQUENTIAL OCCURRENCE REPORT REVISION
REPORT NO. NO.
(17) NUMBER /8/3/ /-/ /0/1/9/ / / /0/3/ /L/ /-/ /0/

ACTION FUTURE EFFECT SHUTDOWN ATTACHMENT NPRD-4 PRIME COMP. COMPONENT
TAKEN ACTION ON PLANT METHOD HOURS SUBMITTED FORM SUB. SUPPLIER MANUFACTURER

/E/ (18) /Z/ (19) /Z/ (20) /Z/ (21) /0/0/0/0/ (22) /N/ (23) /N/ (24) /N/ (25) /W/1/2/0/
(26)

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

/1/0/ / IRPI drift is a generic Westinghouse Analog Position Indication Systems problem. /
/1/1/ / The IRPI channel for Control Bank "C" rod D-12 was recalibrated and returned to /
/1/2/ / service 50 minutes after being declared inoperable. /
/1/3/ / /
/1/4/ / /

FACILITY METHOD OF
STATUS %POWER OTHER STATUS DISCOVERY DISCOVERY DESCRIPTION (32)
/1/5/ /E/ (28) /1/0/0/ (29) / NA / (30) /A/ (31) / Operator Observation /

ACTIVITY CONTENT
RELEASED OF RELEASE AMOUNT OF ACTIVITY (35) LOCATION OF RELEASE (36)
/1/6/ /Z/ (33) /Z/ (34) / NA / / NA /

PERSONNEL EXPOSURES
NUMBER TYPE DESCRIPTION (39)
/1/7/ /0/0/0/ (37) /Z/ (38) / NA /

PERSONNEL INJURIES
NUMBER DESCRIPTION (41)
/1/8/ /0/0/0/ (40) / NA /

LOSS OF OR DAMAGE TO FACILITY (43)
TYPE DESCRIPTION
/1/9/ /Z/ (42) / NA /

PUBLICITY
ISSUED DESCRIPTION (45)
/2/0/ /N/ (44) / NA /

NRC USE ONLY

NAME OF PREPARER

E. WAYNE HARRELL

PHONE (703) 894-5151