

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38

1 2 3 4 5

LICENSEE CODE LICENSE NUMBER LICENSE TYPE CAT

CON'T

01
7 8

REPORT SOURCE 1 6 0 5 0 0 0 3 9 5 7 0 3 2 5 8 3 8 0 4 2 2 8 3 9

80 DOCKET NUMBER 81 82 83 84 85 86 87 88 89 90 EVENT DATE 91 92 93 94 95 96 97 98 REPORT DATE 99

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 | On March 25, 1983, with the Plant in Mode 5, mechanical water chiller (XHX-001B) |

0 3 | tripped. The chiller is a support component of the Emergency Core Cooling System |

0 4 | (ECCS). Train "B" of the ECCS was declared inoperable. There were no adverse |

0 5 | consequences resulting from the event as the Train "A" Chiller (XHX-001A) remained |

0 6 | operable and carried Train "A" of the ECCS. |

0	7	
---	---	--

U	8	
---	---	--

SYSTEM CODE CAUSE CODE CAUSE SUBCODE COMPONENT CODE COMP. SUBCODE VALVE SUBCODE
 0 9 S F ⑪ B ⑫ A ⑬ H T E X C H ⑭ C ⑮ Z ⑯

[illegible]

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 The trip is attributed to an intermittently failing valve control switch which

1 1 caused the valve (XVB-3126) to isolate cooling water to the chiller condenser,

1 2 thereby causing the chiller to trip due to an overtemperature condition. The

1 3 switch is to be repaired.

1	4	
---	---	--

FACILITY STATUS		% POWER	OTHER STATUS (30)	METHOD OF DISCOVERY	DISCOVERY DESCRIPTION (32)
1	5	G (28)	0 0 0 (29)	N/A	A (31) Operator Observation

ACTIVITY CONTENT RELEASED OF RELEASE		AMOUNT OF ACTIVITY	LOCATION OF RELEASE
1	6	N/A	N/A

		PERSONNEL EXPOSURES				
		NUMBER	TYPE	DESCRIPTION	(39)	
1	7	0 0 0	(37) Z	(38) N/A		

PERSONNEL INJURIES		DESCRIPTION (41)	
NUMBER			
1	8	0	0
		0	(40)
N/A			

		11		12		
LOSS OF OR DAMAGE TO FACILITY		TYPE		DESCRIPTION		(43)
1	9	(42)		N/A		8305030637 830422 PDR ADOCK 05000395 S PDR

PUBLICITY
 ISSUED DESCRIPTION (45)

NAME OF PREPARER

H. C. Fields

PHONE: (803) 345-5209