



Telegram

1-006484C115 04/25/83
ICS IPMMVIF MVN
01401 04-25 1027A CDT MVIE
ICS IPMMVIZ

1-004662M115 04/25/83
TLX CONSPower JKN

167 CONSUMERS POWER JACKSON MI 10:47 EST 04-25

PMS

U S NUCLEAR REGULATORY COMMISSION
PALISADES PLT SEC CHIEF
799 ROOSEVELT AVENUE *Read*
GLEN ELLYN IL 60137

MSG # MLB585

BK 19509 MGM FILE MAIL ✓
CC() TB() LB() ✓ NFL() NON-PUB() INFO()
362 932-2500
DC
4-25 BY 19
TIME 1213P

TO: U S NUCLEAR REGULATORY COMMISSION
ATTN: PALISADES PLANT SECTION CHIEF
799 ROOSEVELT AVENUE
GLEN ELLYN, ILLINOIS

FROM: R M KRICH, PALISADES

W.U. 1201-SF (R5-69)



Telegram

CC: R B DEWITT, P-26-117B, JACKSON
D J VANDEWALLE, P-24-614B, JACKSON

THIS CONFIRMS PROMPT NOTIFICATION OF AN OCCURRENCE REPORTABLE PER
T.S. 6.9.2.A(2). ON APRIL 23, 1983, AT 0535, WITH SAFETY INJECTION
TANK
T-82D INOPERABLE DUE TO ROUTINE SAMPLING. AN ADDITIONAL SAFETY INJEC
TION TANK.
T-82B, BECAME INOPERABLE DUE TO LOW LEVEL. THIS OCCURRENCE OF TWO IN
OPERABLE
SAFETY INJECTION TANKS AT THE SAME TIME LASTED APPROXIMATELY 5 MINUT
ES.
PREPARATIONS FOR POWER REDUCTION WERE BEGUN AND CONTINUED UNTIL T-82B
WAS
RESTORED TO OPERABILITY PER T.S. 3.3.2. INITIAL REPORT WAS MADE VIA
THE NRC
HOT LINE ON APRIL 23, 1983. NOTIFICATION TO THE NRC SENIOR RESIDENT
INSPECTOR
WAS MADE ON APRIL 25, 1983.

1027 EST

1033 EST

8305030642 830425
PDR ADOCK 05000255
S PDR

W.U. 1201-SF (R5-69)

APR 27 1983

IE29