



THE CLEVELAND ELECTRIC ILLUMINATING COMPANY

P.O. BOX 5000 - CLEVELAND, OHIO 44101 - TELEPHONE (216) 622-9800 - ILLUMINATING BLDG. - 55 PUBLIC SQUARE

Serving The Best Location in the Nation

MURRAY R. EDELMAN

VICE PRESIDENT
NUCLEAR

April 29, 1983

Mr. James G. Keppler
Regional Administrator, Region III
Office of Inspection and Enforcement
U.S. Nuclear Regulatory Commission
799 Roosevelt Road
Glen Ellyn, Illinois 60137

PRINCIPAL STAFF			
RA	W	INF	
D/RA	SCS		
A/RA	PA		
PPR	SM		
DRMA	SC		
DMER			
DE			
MLV			
OL			
		FILE	

orig + 1

RE: Perry Nuclear Power Plant
Docket Nos. 50-440; 50-441
Reactor Pressure Vessel Water
Level Transmitters [RDC 49(82)]

Dear Mr. Keppler:

Our interim report, dated April 8, 1982, concerning incorrectly sized water level transmitters in the Unit 1 and Unit 2 reactor pressure vessels, stated that the wide range transmitters would be replaced with the correct narrow range transmitters by May 1, 1983. Due to restricted access to the vessels because of construction work in the containment dome, it is now anticipated that the replacement of the water level transmitters will be completed by May 1, 1984. Our final report will be submitted when the replacement of the transmitters is completed.

Please call if there are any additional questions.

Sincerely,

Cyril M. Shuster for

Murray R. Edelman
Vice President
Nuclear Group

MRE:pab

cc: Mr. M. L. Gildner
NRC Site Office

Director
Office of Inspection and Enforcement
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

U.S. Nuclear Regulatory Commission
c/o Document Management Branch
Washington, D.C. 20555

Records Center, SEE-IN
Institute of Nuclear Power Operations
1100 Circle 75 Parkway, Suite 1500
Atlanta, Georgia 30339

8305040465 830429
PDR ADOCK 05000440
S PDR

IE27
MAY 2 1983