

Docket No. 50-346

License No. NPF-3

Serial No. 938

May 2, 1983



RICHARD P. CROUSE
Vice President
Nuclear
(419) 258-5221

Director of Nuclear Reactor Regulation
Attention: Mr. John F. Stolz
Operating Reactor Branch No. 4
Division of Operating Reactors
United States Nuclear Regulatory Commission
Washington, DC 20555

Dear Mr. Stolz:

Under separate cover, we are transmitting three (3) original and forty (40) conformed copies of an application for Amendment to Facility Operating License No. NPF-3 for the Davis-Besse Nuclear Power Station Unit No. 1.

This application requests that the Davis-Besse Nuclear Power Station Unit 1 Technical Specifications, Appendix A, be revised to reflect the changes attached. The proposed changes involve:

1. Section 4.8.1.2
2. Table 4.3-11
3. Table 3.6-2

The three attachments identify the proposed changes and their safety evaluation. Item 1 concerns Surveillance Requirements for the automatic load sequencer. Item 2 concerns monthly testing of the Auxiliary Feed-water System automatic actuation logic and manual initiation circuit. Item 3 concerns cycling requirements for the Main Steam Isolation Valves in Mode 4.

This amendment request involves one change to a previously submitted (July 10, 1980 Serial No. 731) amendment request still under review and two Class III types. Enclosed is a check for \$8,000 as requested by 10 CFR 170.22.

Very truly yours,

RPC:GAB:lah
Attachments

cc: DB-1 NRC Resident Inspector

THE TOLEDO EDISON COMPANY EDISON PLAZA 300 MADISON AVENUE TOLEDO, OHIO 43652

8305040491 830502
PDR ADDCK 05000346
P PDR

A001
w/check!
\$ 8000.00