

(PLEASE PRINT OR TYPE A L REQUIRED INFORMATION)

0	1	N	E	C	P	R	1	2	0	0	-	0	0	0	0	0	-	0	0	3	4	1	1	1	1	4			5	
7	8	LICENSEE CODE						14	15	LICENSE NUMBER										25	26	LICENSE TYPE				30	57	CAT	58	

CON'T

REPORT SOURCE: 01 L 6 0 5 0 0 0 2 9 8 7 0 4 0 3 8 3 8 0 4 2 9 8 3 9
7 8 60 61 DOCKET NUMBER 68 69 EVENT DATE 74 75 REPORT DATE 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 During normal operation, indication and control power for reactor building exhaust
0 3 valve HV-260MV failed thus the valve would not automatically close on an isolation
0 4 signal for secondary containment as required by 3.2.D.2 of the Technical Specifications
0 5 This occurrence presented no adverse consequences from the standpoint of public health
0 6 and safety. Redundant systems were operable and available. Lamp and fuse replaced.
0 7
0 8

0	9		S	D	(11)	E	(12)	F	(13)	I	N	S	T	R	U	(14)	I	(15)	Z	(16)		
7		8	9		10	11		12		13					18		19		20			
			EVENT YEAR				SEQUENTIAL REPORT NO.				OCCURRENCE CODE		REPORT TYPE				REVISION NO.					
(17)	LER/RQ REPORT NUMBER		8	3		—	0	0	3	/	0	3	L	—	0							
			21	22	23		24		26	27	28	29	30	31	32							
ACTION TAKEN	FUTURE ACTION	EFFECT ON PLANT	SHUTDOWN METHOD	HOURS	(22)	ATTACHMENT SUBMITTED	NPRD-4 FORM SUB	PRIME COMP. SUPPLIER	COMPONENT MANUFACTURER													
B	(18)	Z	(19)	Z	(20)	Z	(21)	0	0	0	0	N	(23)	N	(24)	N	(25)	G	0	8	0	(26)
33		34		35		36		37			40	41		42		43		44				47

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1	0	Burned out lamp filaments in contact with each other caused short circuit and power
1	1	fuse to blow. Replaced lamp and fuse.
1	2	
1	3	
1	4	

FACILITY STATUS			% POWER			OTHER STATUS			METHOD OF DISCOVERY			DISCOVERY DESCRIPTION		
1	5	E	28	1	0	0	29	NA	43	B	31	Operator Observation		
ACTIVITY			CONTENT			AMOUNT OF ACTIVITY			LOCATION OF RELEASE					
1	6	Z	33	Z	34	NA	44		45	NA			80	
PERSONNEL EXPOSURES			NUMBER			TYPE			DESCRIPTION					
1	7	0	0	0	0	37	Z	38	NA	39				
PERSONNEL INJURIES			NUMBER			DESCRIPTION								
1	8	0	0	0	0	40	NA	41						
LOSS OF OR DAMAGE TO FACILITY			TYPE			DESCRIPTION								
1	9	Z	42	NA	43									
PUBLICITY			REPORTED			DESCRIPTION								
2	0	N	44	NA	45									

8305060584 830429
PDR ADOCK 05000298
S PDR

NRC USE ONLY

NAME OF PREPARER

K. R. Wire

PHONE

402-825-3811